

May 31, 2001

Mr. Dale E. Young, Vice President
Crystal River Nuclear Plant (NA1B)
ATTN: Supervisor, Licensing and Regulatory Programs
15760 W. Power Line Street
Crystal River, Florida 34428-6708

SUBJECT: CRYSTAL RIVER UNIT 3 PROPOSED LICENSE AMENDMENT REQUEST NO. 252,
ONCE-THROUGH STEAM GENERATOR TUBE SURVEILLANCE PROGRAM,
TUBE REPAIR ROLL PROCESS (TAC NO. MB1519)

Dear Mr. Young:

By letter dated March 21, 2001 (3F0301-02), Florida Power Corporation (FPC) submitted an amendment application to revise the Crystal River Unit 3 (CR-3) Improved Technical Specification (ITS) 5.6.2.10, "Once-Through Steam Generator Tube Surveillance Program." The staff is currently reviewing your request, and noted that you are using Babcock and Wilcox Owners Group Topical Report, BAW-2374, Revision 1, "Risk Informed Assessment of Once Through Steam Generator Tube Thermal Loads Due to Breaks in Reactor Coolant System Upper Hot Leg Large-Bore Piping," as a basis for your request to revise ITS 5.6.2.10. The purpose of this letter is to inform you that the U.S. Nuclear Regulatory Commission (NRC) staff's review of BAW-2374, Revision 1, may not be completed such that it will support the FPC requested amendment completion date of August 30, 2001. In addition, since the staff review of BAW-2374, Revision 1, is not complete, it is not clear that the issues relative to the tube repair roll (re-roll) process noted by the staff during their review of BAW-2374, Revision 0 (see NRC's Safety Evaluation dated December 15, 2000, Oconee re-roll license amendment, ADAMS Accession Number ML003780594) will be adequately resolved.

Therefore, in an effort to support your request and complete this license amendment by August 30, 2001, we would like to suggest you consider a change in the amendment request and approach that we are taking to review your request. We suggest that you review the staff's approval of the steam generator tube re-roll process at Arkansas Nuclear One, Unit 1 (ANO-1) (see NRC's Safety Evaluation dated March 28, 2001, ANO-1 re-roll license amendment, ADAMS Accession Number ML010880115). The licensee (Entergy) made certain regulatory commitments to address the BAW-2374, Revision 0, open issues as part of this license amendment in their supplemental letter dated February 19, 2001 (ADAMS Accession Number ML010590157). An amendment submittal and review approach similar to ANO-1, would assist the staff in its review and improve its ability to meet your requested target date of August 30, 2001.

Sincerely,

/RA by R.Hernan Acting for/

John M. Goshen, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-302

cc: See next page

May 31, 2001

Mr. Dale E. Young, Vice President
Crystal River Nuclear Plant (NA1B)
ATTN: Supervisor, Licensing and Regulatory Programs
15760 W. Power Line Street
Crystal River, Florida 34428-6708

SUBJECT: CRYSTAL RIVER UNIT 3 PROPOSED LICENSE AMENDMENT REQUEST NO. 252,
ONCE-THROUGH STEAM GENERATOR TUBE SURVEILLANCE PROGRAM,
TUBE REPAIR ROLL PROCESS (TAC NO. MB1519)

Dear Mr. Young:

By letter dated March 21, 2001 (3F0301-02), Florida Power Corporation (FPC) submitted an amendment application to revise the Crystal River Unit 3 (CR-3) Improved Technical Specification (ITS) 5.6.2.10, "Once-Through Steam Generator Tube Surveillance Program." The staff is currently reviewing your request, and noted that you are using Babcock and Wilcox Owners Group Topical Report, BAW-2374, Revision 1, "Risk Informed Assessment of Once Through Steam Generator Tube Thermal Loads Due to Breaks in Reactor Coolant System Upper Hot Leg Large-Bore Piping," as a basis for your request to revise ITS 5.6.2.10. The purpose of this letter is to inform you that the U.S. Nuclear Regulatory Commission (NRC) staff's review of BAW-2374, Revision 1, may not be completed such that it will support the FPC requested amendment completion date of August 30, 2001. In addition, since the staff review of BAW-2374, Revision 1, is not complete, it is not clear that the issues relative to the tube repair roll (re-roll) process noted by the staff during their review of BAW-2374, Revision 0 (see NRC's Safety Evaluation dated December 15, 2000, Oconee re-roll license amendment, ADAMS Accession Number ML003780594) will be adequately resolved.

Therefore, in an effort to support your request and complete this license amendment by August 30, 2001, we would like to suggest you consider a change in the amendment request and approach that we are taking to review your request. We suggest that you review the staff's approval of the steam generator tube re-roll process at Arkansas Nuclear One, Unit 1 (ANO-1) (see NRC's Safety Evaluation dated March 28, 2001, ANO-1 re-roll license amendment, ADAMS Accession Number ML010880115). The licensee (Entergy) made certain regulatory commitments to address the BAW-2374, Revision 0, open issues as part of this license amendment in their supplemental letter dated February 19, 2001 (ADAMS Accession Number ML010590157). An amendment submittal and review approach similar to ANO-1, would assist the staff in its review and improve its ability to meet your requested target date of August 30, 2001.

Sincerely,
/RA by R.Hernan Acting for/
John M. Goshen, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-302

cc: See next page

DISTRIBUTION: PUBLIC JGoshen PDII-2 R/F
RidsOGCRp PMadden ACRS BClayton (Hard copy)
PWilson (e-mail) JTsao (e-mail) Ccarpenter LBerry (e-Mail)
LWert, RII WBateman (e-mail)

DOCUMENT NAME: C:\tac mb 1519 letter.wpd
ADAMS ACCESSION NUMBER: ML011510381

*See previous concurrence

OFFICE	PDII-2/PM	PDII-2/LA	EMCB*	PDII-2/SC
NAME	JGoshen:mw	BClayton	WBateman	RHernan for PMadden
DATE	05/31/01	05/31/01	05/30/01	05/31/01

OFFICIAL RECORD COPY

Mr. Dale E. Young
Florida Power Corporation

CRYSTAL RIVER UNIT NO. 3

cc:

Mr. R. Alexander Glenn
Associate General Counsel (MAC-BT15A)
Florida Power Corporation
P.O. Box 14042
St. Petersburg, Florida 33733-4042

Chairman
Board of County Commissioners
Citrus County
110 North Apopka Avenue
Inverness, Florida 34450-4245

Mr. Daniel L. Roderick
Plant General Manager
Crystal River Nuclear Plant (NA2C)
15760 W. Power Line Street
Crystal River, Florida 34428-6708

Ms. Sherry L. Bernhoff
Manager Regulatory Affairs
Crystal River Nuclear Plant (NA2H)
15760 W. Power Line Street
Crystal River, Florida 34428-6708

Mr. Michael A. Schoppman
Framatome Technologies Inc.
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Senior Resident Inspector
Crystal River Unit 3
U.S. Nuclear Regulatory Commission
6745 N. Tallahassee Road
Crystal River, Florida 34428

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

Mr. Richard L. Warden
Manager Nuclear Assessment
Crystal River Nuclear Plant (NA2C)
15760 W. Power Line Street
Crystal River, Florida 34428-6708

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Mr. Joe Myers, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100