

May 20, 1991

Docket Nos. 50-277
and 50-278

Mr. George J. Beck
Manager-Licensing, MC 5-2A-5
Philadelphia Electric Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, Pennsylvania 19087-0195

DISTRIBUTION w/enclosures:
Docket File FROsa
NRC & Local PDR ACRS (10)
PDI-2 Rdg. GPA/PA
SVarga OC/LFMB
JCalvo RBlough, RGN-I
WButler LDoerflein, R-I
MO'Brien(2) REmch
GSuh/RClark
OGC
DHagan, 3206
GHill(4), P1-37
Wanda Jones, 7103

Dear Mr. Beck:

SUBJECT: EMERGENCY DIESEL GENERATOR INSPECTION FREQUENCY FOR PEACH BOTTOM
ATOMIC POWER STATION, UNIT NOS. 2 AND 3 (TAC NOS. 79487 AND 79488)

The Commission has issued the enclosed Amendment Nos. 159 and 161 to Facility
Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power
Station, Unit Nos. 2 and 3. These amendments consist of changes to the
Technical Specifications in response to your application dated November 30,
1990.

These amendments revise the emergency diesel generator periodic inspection
interval from once per year to once per 18 months.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be
included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

/S/

Gene Y. Suh, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 159 to DPR-44
- 2. Amendment No. 161 to DPR-56
- 3. Safety Evaluation

cc w/enclosures:
See next page

NRC FILE CENTER COPY

*Previously Concurred

OFC	: PDI-2/CA	: PDI-2/PM	: *SELB/BC	: *OTSB/BC	: OGC	: PDI-2/D
NAME	: MO'Brien	: GSuh:tlc	: FRosa	:	: WButler	:
DATE	: 5/17/91	: 4/25/91	: 04/04/91	: 04/04/91	: 5/16/91	: 5/16/91

OFFICIAL RECORD COPY
Document Name: TACS 79487/488 PB

9106060074 910520
PDR ADDCK 05000277
P PDR

Handwritten initials and signature: CA, FDI, 11



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

May 20, 1991

Docket Nos. 50-277
and 50-278

Mr. George J. Beck
Manager-Licensing, MC 5-2A-5
Philadelphia Electric Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, Pennsylvania 19087-0195

Dear Mr. Beck:

SUBJECT: EMERGENCY DIESEL GENERATOR INSPECTION FREQUENCY FOR PEACH BOTTOM
ATOMIC POWER STATION, UNIT NOS. 2 AND 3 (TAC NOS. 79487 AND 79488)

The Commission has issued the enclosed Amendment Nos. 159 and 161 to Facility Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station, Unit Nos. 2 and 3. These amendments consist of changes to the Technical Specifications in response to your application dated November 30, 1990.

These amendments revise the emergency diesel generator periodic inspection interval from once per year to once per 18 months.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

A handwritten signature in cursive script that reads "Gene Y. Suh".

Gene Y. Suh, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 159 to DPR-44
2. Amendment No. 161 to DPR-56
3. Safety Evaluation

cc w/enclosures:
See next page

Mr. George J. Beck
Philadelphia Electric Company

Peach Bottom Atomic Power Station,
Units 2 and 3

cc:

J. W. Durham, Sr., Esquire
Sr. V.P. & General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Single Point of Contact
P. O. Box 11880
Harrisburg, Pennsylvania 17108-1880

Philadelphia Electric Company
ATTN: Mr. D. B. Miller, Vice President
Peach Bottom Atomic Power Station
Route 1, Box 208
Delta, Pennsylvania 17314

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Philadelphia Electric Company
ATTN: Regulatory Engineer, A1-2S
Peach Bottom Atomic Power Station
Route 1, Box 208
Delta, Pennsylvania 17314

Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Resident Inspector
U.S. Nuclear Regulatory Commission
Peach Bottom Atomic Power Station
P.O. Box 399
Delta, Pennsylvania 17314

Public Service Commission of Maryland
Engineering Division
ATTN: Chief Engineer
231 E. Baltimore Street
Baltimore, MD 21202-3486

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. Richard McLean
Power Plant and Environmental
Review Division
Department of Natural Resources
B-3, Tawes State Office Building
Annapolis, Maryland 21401

Mr. Roland Fletcher
Department of Environment
201 West Preston Street
Baltimore, Maryland 21201



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-277

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 159
License No. DPR-44

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Philadelphia Electric Company, et. al. (the licensee) dated November 30, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I.
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health or safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. DPR-44 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 159, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects - I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 20, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 159

FACILITY OPERATING LICENSE NO. DPR-44

DOCKET NO. 50-277

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

<u>Remove</u>	<u>Insert</u>
218b	218b
218c	218c

3.9.A4.9.A (Cont'd)

contamination is less than 10 mg/liter when checked in accordance with ASTM D2276-78, Method A, except that the filters specified in ASTM D2276-78, Sections 5.1.6 and 5.1.7, may have a nominal pore size of up to three (3) microns.

- g. Each fuel oil storage tank shall be drained, accumulated sediment removed, and the tanks cleaned using a sodium hypochlorite or equivalent solution, at least once every ten years.
- h. The fuel oil storage tank cathodic protection system shall be checked as follows:
 - 1) At least once every twelve months perform a test to determine whether the cathodic protection is adequate, and
 - 2) At least once every two months inspect the cathodic protection rectifiers.
- i. At least once per eighteen months, each diesel generator will be inspected in accordance with procedures prepared in conjunction with its manufacturer's recommendations for this class of standby service.

PBAPS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.9.A

4.9.A (Cont'd)

2. Unit Batteries

- a. Every week the specific gravity, the voltage and temperature of the pilot cell and overall battery voltage shall be measured and logged.
- b. Every three months the measurements shall be made of voltage of each cell to nearest 0.1 Volt, specific gravity of each cell, and temperature of every fifth cell. These measurements shall be logged.
- c. The station batteries shall be subjected to a performance test every third refueling outage and a service test during the other refueling outage. In lieu of the performance test every third refueling outage, any battery that shows "signs of degradation or has reached 85% of its service life" shall be subjected to an annual performance test. The service test need not be performed on the refueling outage during which the performance test was conducted. The specific gravity and voltage of each cell shall be determined after the discharge and logged.

3. Swing Buses

- a. Every two months the swing buses supplying power to the Low Pressure Coolant Injection System (LPCIS) valves shall be tested to assure that the transfer circuits operate as designed.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-278

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 161
License No. DPR-56

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Philadelphia Electric Company, et al. (the licensee) dated November 30, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I.
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health or safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. DPR-56 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 161, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects - I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 20, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 161

FACILITY OPERATING LICENSE NO. DPR-56

DOCKET NO. 50-278

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

<u>Remove</u>	<u>Insert</u>
218b	218b
218c	218c

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.9.A4.9.A (Cont'd)

contamination is less than 10 mg/liter when checked in accordance with ASTM D2276-78, Method A, except that the filters specified in ASTM D2276-78, Sections 5.1.6 and 5.1.7, may have a nominal pore size of up to three (3) microns.

- g. Each fuel oil storage tank shall be drained, accumulated sediment removed, and the tanks cleaned using a sodium hypochlorite or equivalent solution, at least once every ten years.
- h. The fuel oil storage tank cathodic protection system shall be checked as follows:
 - 1) At least once every twelve months perform a test to determine whether the cathodic protection is adequate, and
 - 2) At least once every two months inspect the cathodic protection rectifiers.
- i. At least once per eighteen months, each diesel generator will be inspected in accordance with procedures prepared in conjunction with its manufacturer's recommendations for this class of standby service.

PBAPS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.9.A

4.9.A (Cont'd)

2. Unit Batteries

- a. Every week the specific gravity, the voltage and temperature of the pilot cell and overall battery voltage shall be measured and logged.
- b. Every three months the measurements shall be made of voltage of each cell to nearest 0.1 Volt, specific gravity of each cell, and temperature of every fifth cell. These measurements shall be logged.
- c. The station batteries shall be subjected to a performance test every third refueling outage and a service test during the other refueling outage. In lieu of the performance test every third refueling outage, any battery that shows "signs of degradation or has reached 85% of its service life" shall be subjected to an annual performance test. The service test need not be performed on the refueling outage during which the performance test was conducted. The specific gravity and voltage of each cell shall be determined after the discharge and logged.

3. Swing Buses

- a. Every two months the swing buses supplying power to the Low Pressure Coolant Injection System (LPCIS) valves shall be tested to assure that the transfer circuits operate as designed.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NOS. 159 AND 161 TO FACILITY OPERATING

LICENSE NOS. DPR-44 and DPR-56

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

PEACH BOTTOM ATOMIC POWER STATION, UNIT NOS. 2 AND 3

DOCKET NOS. 50-277 AND 50-278

1.0 INTRODUCTION

By letter dated November 30, 1990, the Philadelphia Electric Company, Public Service Electric & Gas Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) submitted a request for changes to the Peach Bottom Atomic Power Station, Unit Nos. 2 and 3, Technical Specifications (TS). The requested changes would revise the emergency diesel generator periodic inspection interval from once per year to once per 18 months.

2.0 EVALUATION

The licensee states in its November 30, 1990 submittal that the purpose of the requested TS change is in part to provide greater flexibility for completing the tear-down inspection of the emergency diesel generators (EDGs) during planned station outages and to reduce the probability of a two unit shutdown if the allowed out-of-service time could not be satisfied. As documented in NRC Combined Inspection Report 50-277/90-13 and 50-278/90-13, the TS required tear-down inspections are quite extensive, require significant disassembly, and require about a 6 day EDG outage. The TS allowed out-of-service time for one EDG is seven days, and failure to return the EDG to service within seven days would require that both units be placed in shutdown, given that the four EDGs at the station are fully shared between both Units 2 and 3.

The requested TS change is consistent with the EDG vendor's recommendations as documented in the updated vendor manual. Licensee review of plant records indicated that the currently required annual maintenance inspection outage constitutes a significant portion of each diesel generator's unavailability rate. An extension of the inspection frequency to 18 months should therefore result in increased EDG availability. In addition, the licensee has implemented a diesel generator parameter trending program to identify potential problems from data collected during routine surveillance testing of the EDGs.

The staff has reviewed the proposed change in the inspection interval to once per 18 months and find it acceptable based on the consistency of the proposed change with the EDG vendor's recommendations. In addition, the proposed change will increase the likelihood that the required tear-down inspection of the EDGs will be performed with at least one unit in a shutdown condition.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Pennsylvania State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Gene Y. Suh

Date: May 20, 1991