

June 1, 2001

Mr. David A. Christian
Senior Vice President and
Chief Nuclear Officer
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2: REQUEST FOR
ADDITIONAL INFORMATION (RAI) REGARDING SECTIONS 3.0 AND 4.0 OF
THE IMPROVED TECHNICAL SPECIFICATIONS (ITS) FOR NORTH ANNA
POWER STATION, UNITS 1 AND 2 (TAC NOS. MB0799 AND MB0800)

Dear Mr. Christian:

The NRC staff reviewed your application dated December 11, 2000, to change the format and content of the Current Technical Specifications (TS) to be consistent with NUREG-1431, "Standard Technical Specifications - Westinghouse Plants," Revision 1, and certain generic changes to the NUREG.

On the basis of our review of the proposed changes for ITS Sections 3.0 and 4.0, we find that additional information identified in the enclosure is needed. This inquiry was discussed with Ms. Regina Borsh of your licensing staff on May 24, 2001, who agreed to provide the staff with a response within 60 days of the date of this letter.

Sincerely,

/RA/

Stephen R. Monarque, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

Enclosure: Request for Additional Information

cc w/encl: See next page

June 1, 2001

Mr. David A. Christian
Senior Vice President and
Chief Nuclear Officer
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2: REQUEST FOR
ADDITIONAL INFORMATION (RAI) REGARDING SECTIONS 3.0 AND 4.0 OF
THE IMPROVED TECHNICAL SPECIFICATIONS (ITS) FOR NORTH ANNA
POWER STATION, UNITS 1 AND 2 (TAC NOS. MB0799 AND MB0800)

Dear Mr. Christian:

The NRC staff reviewed your application dated December 11, 2000, to change the format and content of the Current Technical Specifications (TS) to be consistent with NUREG-1431, "Standard Technical Specifications - Westinghouse Plants," Revision 1, and certain generic changes to the NUREG.

On the basis of our review of the proposed changes for ITS Sections 3.0 and 4.0, we find that additional information identified in the enclosure is needed. This inquiry was discussed with Ms. Regina Borsh of your licensing staff on May 24, 2001, who agreed to provide the staff with a response within 60 days of the date of this letter.

Sincerely,

/RA/

Stephen R. Monarque, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PDII-1 Rdg. (paper copy) RidsOgcRp NocLe
RidsNrrDlpmLpdii-1 (paper copy) RidsAcrcAcnwMailCenter Angela Chu
EDunnington (paper copy) RidsRgn2MailCenter
PUBLIC SMonarque (paper copy)
ADAMS ACCESSION NUMBER: ML011520493

| | | | |
|--------|------------|-------------|------------|
| OFFICE | PM:PDII/S1 | LA :PDII/S1 | SC:PDII/S1 |
| NAME | SMonarque | EDunnington | REmch |
| DATE | 05/29/01 | 05/25/01 | 05/29/01 |

OFFICIAL RECORD COPY

Mr. David A. Christian
Virginia Electric and Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. C. Lee Lintecum
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Mr. David A. Heacock
Site Vice President
North Anna Power Station
P.O. Box 402
Mineral, Virginia 23117-0402

Mr. Donald P. Irwin, Esquire
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Mr. Richard H. Blount, II
Site Vice President
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883-0315

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P.O. Box 1197
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P. O. Box 2448
Richmond, Virginia 23218

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. William R. Matthews
Vice President - Nuclear Operations
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, Virginia 23060-6711

Mr. Stephen P. Sarver, Director
Nuclear Licensing & Operations Support
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060-6711

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
1024 Haley Drive
Mineral, Virginia 23117

REQUEST FOR ADDITIONAL INFORMATION
NORTH ANNA POWER STATION, UNITS 1 AND 2
IMPROVED TECHNICAL SPECIFICATIONS (ITS)
ITS SECTIONS 3.0 AND 4.0

SECTION 3.0

3.0-1 Justification for Deviation (JFD)-3.0-1 ITS 3.0 Surveillance Requirement (SR) Applicability SR 3.0.1 states that "Surveillance may be performed by means of any series of sequential, overlap, or total steps." This change has been proposed generically as WOG-142. Provide the sections of WOG-142 to show where this change is adopted from.

3.0-2 ITS-3.0 Limiting Condition for Operation (LCO) 3.0.2 incorporates Technical Specifications Task Force (TSTF)-122 by adding "Alternately, if intentional entry into ACTIONS...". However, in TSTF-122, WOG Standard Technical Specifications, the word "Alternately" should be "Additionally." Correction is needed.

SECTION 4.0

4.0-1 JFD-4.0-5 ITS 4.2.1 Fuel Assemblies states that a limited number of lead test assemblies that have not completed representative testing may be placed in nonlimiting core locations, vice nonlimiting core regions. Provide a figure of the reactor core to illustrate the difference between nonlimiting core locations and nonlimiting core regions.

4.0-2 JFD-4.0-1 ITS 4.3.2 Drainage states that the spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 288.83 Mean Sea Level, USGS datum. Explain with a figure of the fuel storage pool why this value is equal to 23 ft elevation.