

March 5, 1991

Docket No. 50-352

Mr. George J. Beck
Manager-Licensing, MC 5-2A-5
Philadelphia Electric Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, Pennsylvania 19087-0195

Dear Mr. Beck:

SUBJECT: LIMERICK GENERATING STATION, UNIT NO. 1

On September 25, 1989, we issued Amendment No. 32 to Facility Operating License No. NPF-39. The amendment revised Section 3.8.1.1 of the Technical Specifications (TSs) which specifies the operability and testing requirements for the diesel generators. It also revised Section 3.8.1.1.f on page 3/4 8-2.

On May 30, 1990, we issued Amendment No. 40 to License No. NPF-39 which made several administrative changes to the Limerick, Unit 1 TSs, including Section 3.8.1.1. In order to provide space for the revisions, a new page was added, page 3/4 8-2a. Section 3.8.1.1.f was relocated to this new page. Amendment No. 40 was not supposed to make any change to Section 3.8.1.1.f. However, the wording in Section 3.8.1.1.f issued with Amendment No. 40 did not reflect the change made in Amendment No. 32. Two pages are enclosed; the corrected page 3/4 8-2a and, for completeness, its overleaf, page 3/4 8-2.

We regret any inconvenience this may have caused you.

Sincerely,
Original signed by
Richard J. Clark

Richard J. Clark, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Technical Specification Pages
3/4 8-2 and 3/4 8-2a

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	WButler	DHagan, 3206	GPA/PA
NRC & Local PDRs	MO'Brien(2)	Ghill(4), P1-37	OC/LFMB
PDI-2 Reading	RClark	Wanda Jones, 7013	RBlough, RGN-I
SVarga	GSuh	JCalvo, 11F-22	LDoerflein, RGN-I
EGreenman	OGC	ACRS(10)	

OFC	: PDI-2/EA	: PDI-2/PM	: PDI-2/D	:
NAME	: MO'Brien	: RClark	: WButler	:
DATE	: 2/26/91	: 02/26/91	: 3/5/91	:

OFFICIAL RECORD COPY
Document Name: LI CORR. PGS 3/4 82, 82A

7103140282 710305
PDR ADOCK 05000352
P PDR

JFOI 11



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 5, 1991

Docket No. 50-352

Mr. George J. Beck
Manager-Licensing, MC 5-2A-5
Philadelphia Electric Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, Pennsylvania 19087-0195

Dear Mr. Beck:

SUBJECT: LIMERICK GENERATING STATION, UNIT NO. 1

On September 25, 1989, we issued Amendment No. 32 to Facility Operating License No. NPF-39. The amendment revised Section 3.8.1.1 of the Technical Specifications (TSs) which specifies the operability and testing requirements for the diesel generators. It also revised Section 3.8.1.1.f on page 3/4 8-2.

On May 30, 1990, we issued Amendment No. 40 to License No. NPF-39 which made several administrative changes to the Limerick, Unit 1 TSs, including Section 3.8.1.1. In order to provide space for the revisions, a new page was added, page 3/4 8-2a. Section 3.8.1.1.f was relocated to this new page. Amendment No. 40 was not supposed to make any change to Section 3.8.1.1.f. However, the wording in Section 3.8.1.1.f issued with Amendment No. 40 did not reflect the change made in Amendment No. 32. Two pages are enclosed; the corrected page 3/4 8-2a and, for completeness, its overleaf, page 3/4 8-2.

We regret any inconvenience this may have caused you.

Sincerely,

A handwritten signature in cursive script, appearing to read "Richard J. Clark".

Richard J. Clark, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Technical Specification Pages
3/4 8-2 and 3/4 8-2a

cc w/enclosure:
See next page

ELECTRICAL POWER SYSTEMS

LIMITING CONDITION FOR OPERATION (Continued)

ACTION: (Continued)

- e. In addition to the ACTIONS above:
1. For two train systems, with one or more diesel generators of the above required A.C. electrical power sources inoperable, verify within 2 hours and at least once per 12 hours thereafter that at least one of the required two train system subsystem, train, components, and devices is OPERABLE and its associated diesel generator is OPERABLE. Otherwise, restore either the inoperable diesel generator or the inoperable system subsystem to an OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
 2. For the LPCI systems, with two or more diesel generators of the above required A.C. electrical power sources inoperable, verify within 2 hours and at least once per 12 hours thereafter that at least two of the required LPCI system subsystems, trains, components, and devices are OPERABLE and its associated diesel generator is OPERABLE. Otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

This ACTION does not apply for those systems covered in Specifications 3.7.1.1. and 3.7.1.2.

ELECTRICAL POWER SYSTEMS

LIMITING CONDITION FOR OPERATION (Continued)

ACTION: (Continued)

- f. With one offsite circuit of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter; and if any of the diesel generators have not been successfully tested within the preceding 24 hours, demonstrate OPERABILITY of these diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4 for one diesel at a time, within 24 hours. Restore at least two offsite circuits to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and COLD SHUTDOWN within the following 24 hours.
- g. With two of the above required offsite circuits inoperable, demonstrate the OPERABILITY of all of the above required diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4, for one diesel generator at a time, within 8 hours unless the diesel generators are already operating; restore at least one of the inoperable offsite circuits to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours. With only one offsite circuit restored to OPERABLE status, restore at least two offsite circuits to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- h. With one offsite circuit and two diesel generators of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a. within 1 hour and at least once per 8 hours thereafter; demonstrate the OPERABILITY of the remaining diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4 for one diesel generator at a time, within 8 hours. Restore at least one of the above required inoperable A.C. sources to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. Restore at least two offsite circuits and at least three of the above required diesel generators to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. See also ACTION e.

Mr. George J. Beck
Philadelphia Electric Company

Limerick Generating Station
Units 1 & 2

cc:

J. W. Durham, Sr., Esquire
Sr. V.P. & General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. Thomas Gerusky, Director
Bureau of Radiation Protection
PA Dept. of Environmental Resources
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Mr. Rod Krich 52A-5
Philadelphia Electric Company
955 Chesterbrook Boulevard
Wayne, Pennsylvania 19087-5691

Single Point of Contact
P. O. Box 11800
Harrisburg, Pennsylvania 17108-188

Mr. Graham M. Leitch, Vice President
Limerick Generating Station
Post Office Box A
Sanatoga, Pennsylvania 19464

Mr. Garrett Edwards
Superintendent-Technical
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. John Doering
Plant Manager
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Mr. Gil J. Madsen
Regulatory Engineer
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Library
US Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Thomas Kenny
Senior Resident Inspector
US Nuclear Regulatory Commission
P. O. Box 596
Pottstown, Pennsylvania 19464

Mr. George A. Hunger
Project Manager
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. Larry Hopkins
Superintendent-Operations
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464