

October 24, 1991

Docket Nos. 50-352  
and 50-353

Mr. George J. Beck  
Manager-Licensing, MC 5-2A-5  
Philadelphia Electric Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, Pennsylvania 19087-0195

DISTRIBUTION w/enclosures:

Docket File	GHill(8), P1-37
NRC & Local PDR	Wanda Jones, 7103
PDI-2 Reading	CGrimes, 11E-21
SVarga	HRichings, 8E23
JCalvo	ACRS(10)
CMiller	GPA/PA
MO'Brien(2)	OC/LFMB
JShea/RClark(2)	RBlough, RGN-I
OGC	LDoerflein, RGN-I
DHagan, MS-3206	

SUBJECT: MAIN TURBINE BYPASS SYSTEM OPERABILITY REQUIREMENTS, LIMERICK  
GENERATING STATION, UNITS 1 AND 2 (TSCR NO. 90-12)(TAC NOS. 81367  
AND 81368)

The Commission has issued the enclosed Amendment No. 52 to Facility Operating License No. NPF-39 and Amendment No. 16 to Facility Operating License No. NPF-85 for the Limerick Generating Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated August 27, 1991.

These amendments revise the TSs by adding operability requirements, Limiting Conditions for Operation (LCOs) and Surveillance Requirements for the main turbine bypass system.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by  
Richard J. Clark

Richard J. Clark, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 52 to  
License No. NPF-39  
Amendment No. 16 to  
License No. NPF-85
2. Safety Evaluation

**NRC FILE CENTER COPY**

cc w/enclosures:  
See next page

OFC	: PDI-2/A	: PDI-2/B	: SRXB	: SRXB	: OGC	: PDI-2/D
NAME	: MO'Brien	: RClark:rb	: HRichings	: RJones	: myyoung	: CMiller
DATE	: 10/15/91	: 10/03/91	: 1/1/91	: 10/07/91	: 10/8/91	: 10/24/91

OFFICIAL RECORD COPY  
Document Name: TACS 81367/8

9111130059 911024  
PDR ADOCK 05000352  
PDR

DF01



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 24, 1991

Docket Nos. 50-352  
and 50-353

Mr. George J. Beck  
Manager-Licensing, MC 5-2A-5  
Philadelphia Electric Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, Pennsylvania 19087-0195

Dear Mr. Beck:

SUBJECT: MAIN TURBINE BYPASS SYSTEM OPERABILITY REQUIREMENTS, LIMERICK  
GENERATING STATION, UNITS 1 AND 2 (TSCR NO. 90-12)(TAC NOS. 81367  
AND 81368)

The Commission has issued the enclosed Amendment No. 52 to Facility Operating License No. NPF-39 and Amendment No. 16 to Facility Operating License No. NPF-85 for the Limerick Generating Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated August 27, 1991.

These amendments revise the TSs by adding operability requirements, Limiting Conditions for Operation (LCOs) and Surveillance Requirements for the main turbine bypass system.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to read "Richard J. Clark", written over a horizontal line.

Richard J. Clark, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 52 to  
License No. NPF-39  
Amendment No. 16 to  
License No. NPF-85
2. Safety Evaluation

cc w/enclosures:  
See next page

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*Charles L. Miller*

Charles L. Miller, Director  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: October 24, 1991



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PHILADELPHIA ELECTRIC COMPANY

DOCKET NO. 50-352

LIMERICK GENERATING STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 52  
License No. NPF-39

1. The Nuclear Regulatory Commission (the Commission) has found that
  - A. The application for amendment by Philadelphia Electric Company (the licensee) dated August 27, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-39 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 52, are hereby incorporated into this license. Philadelphia Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

Mr. George J. Beck  
Philadelphia Electric Company

Limerick Generating Station  
Units 1 & 2

cc:

J. W. Durham, Sr., Esquire  
Sr. V.P. & General Counsel  
Philadelphia Electric Company  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Mr. Thomas Gerusky, Director  
Bureau of Radiation Protection  
PA Dept. of Environmental Resources  
P. O. Box 2063  
Harrisburg, Pennsylvania 17120

Mr. Rod Krich 52A-5  
Philadelphia Electric Company  
955 Chesterbrook Boulevard  
Wayne, Pennsylvania 19087-5691

Single Point of Contact  
P. O. Box 11800  
Harrisburg, Pennsylvania 17108-188

Mr. Graham M. Leitch, Vice President  
Limerick Generating Station  
Post Office Box A  
Sanatoga, Pennsylvania 19464

Mr. Garrett Edwards  
Superintendent-Technical  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. John Doering  
Plant Manager  
Limerick Generating Station  
P.O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Gil J. Madsen  
Regulatory Engineer  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Library  
US Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Thomas Kenny  
Senior Resident Inspector  
US Nuclear Regulatory Commission  
P. O. Box 596  
Pottstown, Pennsylvania 19464

Mr. George A. Hunger  
Project Manager  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Larry Hopkins  
Superintendent-Operations  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

ATTACHMENT TO LICENSE AMENDMENT NO. 52

FACILITY OPERATING LICENSE NO. NPF-39

DOCKET NO. 50-352

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Overleaf pages are provided to maintain document completeness.\*

<u>Remove</u>	<u>Insert</u>
i	i*
ii	ii
xiii	xiii*
xiv	xiv
xxi	xxi
xxii	xxii*
1-7	1-7*
1-8	1-8
3/4 2-7	3/4 2-7*
3/4 2-8	3/4 2-8
3/4 2-9	3/4 2-9
3/4 2-10	3/4 2-10*
-	3/4 7-33
-	-
-	B 3/4 7-5
-	-

## INDEX

### DEFINITIONS

#### SECTION

<u>1.0 DEFINITIONS</u>	<u>PAGE</u>
1.1 ACTION.....	1-1
1.2 AVERAGE PLANAR EXPOSURE.....	1-1
1.3 AVERAGE PLANAR LINEAR HEAT GENERATION RATE.....	1-1
1.4 CHANNEL CALIBRATION.....	1-1
1.5 CHANNEL CHECK.....	1-1
1.6 CHANNEL FUNCTIONAL TEST.....	1-1
1.7 CORE ALTERATION.....	1-2
1.7a CORE OPERATING LIMITS REPORT.....	1-2
1.8 CRITICAL POWER RATIO.....	1-2
1.9 DOSE EQUIVALENT I-131.....	1-2
1.10 E-AVERAGE DISINTEGRATION ENERGY.....	1-2
1.11 EMERGENCY CORE COOLING SYSTEM (ECCS) RESPONSE TIME.....	1-2
1.12 END-OF-CYCLE RECIRCULATION PUMP TRIP SYSTEM RESPONSE TIME....	1-2
1.13 FRACTION OF LIMITING POWER DENSITY.....	1-3
1.14 FRACTION OF RATED THERMAL POWER.....	1-3
1.15 FREQUENCY NOTATION.....	1-3
1.16 IDENTIFIED LEAKAGE.....	1-3
1.17 ISOLATION SYSTEM RESPONSE TIME.....	1-3
1.18 LIMITING CONTROL ROD PATTERN.....	1-3
1.19 LINEAR HEAT GENERATION RATE.....	1-3
1.20 LOGIC SYSTEM FUNCTIONAL TEST.....	1-4
1.21 MAXIMUM FRACTION OF LIMITING POWER DENSITY.....	1-4

DEFINITIONS

---

<u>SECTION</u>		<u>PAGE</u>
<u>DEFINITIONS</u> (Continued)		
1.22 MEMBER(S) OF THE PUBLIC.....		1-4
1.23 MINIMUM CRITICAL POWER RATIO.....		1-4
1.24 OFFSITE DOSE CALCULATION MANUAL.....		1-4
1.25 OPERABLE - OPERABILITY.....		1-4
1.26 OPERATIONAL CONDITION - CONDITION.....		1-4
1.27 PHYSICS TESTS.....		1-4
1.28 PRESSURE BOUNDARY LEAKAGE.....		1-5
1.29 PRIMARY CONTAINMENT INTEGRITY.....		1-5
1.30 PROCESS CONTROL PROGRAM.....		1-5
1.31 PURGE - PURGING.....		1-5
1.32 RATED THERMAL POWER.....		1-6
1.33 REACTOR ENCLOSURE SECONDARY CONTAINMENT INTEGRITY.....		1-6
1.34 REACTOR PROTECTION SYSTEM RESPONSE TIME.....		1-6
1.35 REFUELING FLOOR SECONDARY CONTAINMENT INTEGRITY.....		1-6
1.36 REPORTABLE EVENT.....		1-7
1.37 ROD DENSITY.....		1-7
1.38 SHUTDOWN MARGIN.....		1-7
1.39 SITE BOUNDARY.....		1-7
1.40 (Deleted).....		1-7
1.41 SOURCE CHECK.....		1-7
1.42 STAGGERED TEST BASIS.....		1-8
1.43 THERMAL POWER.....		1-8
1.43A TURBINE BYPASS SYSTEM RESPONSE TIME.....		1-8
1.44 UNIDENTIFIED LEAKAGE.....		1-8



# INDEX

## LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>CONTAINMENT SYSTEMS (Continued)</u>	
3/4.6.4 VACUUM RELIEF	
Suppression Chamber - Drywell Vacuum Breakers.....	3/4 6-44
3/4.6.5 SECONDARY CONTAINMENT	
Reactor Enclosure Secondary Containment Integrity.....	3/4 6-46
Refueling Area Secondary Containment Integrity.....	3/4 6-47
Reactor Enclosure Secondary Containment Automatic Isolation Valves.....	3/4 6-48
Table 3.6.5.2.1-1 Reactor Enclosure Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-49
Refueling Area Secondary Containment Automatic Isolation Valves.....	3/4 6-50
Table 3.6.5.2.2-1 Refueling Area Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-51
Standby Gas Treatment System - Common System.....	3/4 6-52
Reactor Enclosure Recirculation System.....	3/4 6-55
3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL	
Primary Containment Hydrogen Recombiner Systems.....	3/4 6-57
Drywell Hydrogen Mixing System.....	3/4 6-58
Drywell and Suppression Chamber Oxygen Concentration....	3/4 6-59
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 SERVICE WATER SYSTEMS	
Residual Heat Removal Service Water System - Common System.....	3/4 7-1
Emergency Service Water System - Common System.....	3/4 7-3
Ultimate Heat Sink.....	3/4 7-5

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>PLANT SYSTEMS (Continued)</u>	
3/4.7.2 CONTROL ROOM EMERGENCY FRESH AIR SUPPLY SYSTEM - COMMON SYSTEM.....	3/4 7-6
3/4.7.3 REACTOR CORE ISOLATION COOLING SYSTEM.....	3/4 7-9
3/4.7.4 SNUBBERS.....	3/4 7-11
Figure 4.7.4-1 Sample Plan 2) For Snubber Functional Test.....	3/4 7-16
3/4.7.5 SEALED SOURCE CONTAMINATION.....	3/4 7-17
3/4.7.6 FIRE SUPPRESSION SYSTEMS	
Fire Suppression Water System.....	3/4 7-19
Spray and/or Sprinkler Systems.....	3/4 7-22
CO <sub>2</sub> Systems.....	3/4 7-24
Halon Systems.....	3/4 7-25
Fire Hose Stations.....	3/4 7-26
Table 3.7.6.5-1 Fire Hose Stations.....	3/4 7-27
Yard Fire Hydrants and Hose Cart Houses.....	3/4 7-29
Table 3.7.6.6-1 Yard Fire Hydrants and Hose Cart Houses.....	3/4 7-30
3/4.7.7 FIRE RATED ASSEMBLIES.....	3/4 7-31
3/4.7.8 MAIN TURBINE BYPASS SYSTEM.....	3/4 7-33
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1 A.C. SOURCES	
A.C. Sources - Operating.....	3/4 8-1
Table 4.8.1.1.2-1 Diesel Generator Test Schedule.....	3/4 8-8
A.C. Sources - Shutdown.....	3/4 8-9
3/4.8.2 D. C. SOURCES	
D. C. Sources - Operating.....	3/4 8-10

## INDEX

### BASES

#### SECTION

#### PAGE

#### CONTAINMENT SYSTEMS (Continued)

3/4.6.3	PRIMARY CONTAINMENT ISOLATION VALVES.....	B 3/4 6-4
3/4.6.4	VACUUM RELIEF.....	B 3/4 6-4
3/4.6.5	SECONDARY CONTAINMENT.....	B 3/4 6-5
3/4.6.6	PRIMARY CONTAINMENT ATMOSPHERE CONTROL.....	B 3/4 6-6

#### 3/4.7 PLANT SYSTEMS

3/4.7.1	SERVICE WATER SYSTEMS - COMMON SYSTEMS.....	B 3/4 7-1
3/4.7.2	CONTROL ROOM EMERGENCY FRESH AIR SUPPLY SYSTEM - COMMON SYSTEM.....	B 3/4 7-1a
3/4.7.3	REACTOR CORE ISOLATION COOLING SYSTEM.....	B 3/4 7-1a
3/4.7.4	SNUBBERS.....	B 3/4 7-2
3/4.7.5	SEALED SOURCE CONTAMINATION.....	B 3/4 7-3
3/4.7.6	FIRE SUPPRESSION SYSTEMS.....	B 3/4 7-4
3/4.7.7	FIRE RATED ASSEMBLIES.....	B 3/4 7-4
3/4.7.8	MAIN TURBINE BYPASS SYSTEM.....	B 3/4 7-5

#### 3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1, 3/4.8.2, and 3/4.8.3	A.C. SOURCES, D.C. SOURCES, AND ONSITE POWER DISTRIBUTION SYSTEMS.....	B 3/4 8-1
3/4.8.4	ELECTRICAL EQUIPMENT PROTECTIVE DEVICES.....	B 3/4 8-3

#### 3/4.9 REFUELING OPERATIONS

3/4.9.1	REACTOR MODE SWITCH.....	B 3/4 9-1
3/4.9.2	INSTRUMENTATION.....	B 3/4 9-1
3/4.9.3	CONTROL ROD POSITION.....	B 3/4 9-1
3/4.9.4	DECAY TIME.....	B 3/4 9-1
3/4.9.5	COMMUNICATIONS.....	B 3/4 9-1

## INDEX

### BASES

<u>SECTION</u>	<u>PAGE</u>
<u>REFUELING OPERATIONS (Continued)</u>	
3/4.9.6 REFUELING PLATFORM.....	B 3/4 9-2
3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE POOL.....	B 3/4 9-2
3/4.9.8 and 3/4.9.9 WATER LEVEL - REACTOR VESSEL and WATER LEVEL - SPENT FUEL STORAGE POOL.....	B 3/4 9-2
3/4.9.10 CONTROL ROD REMOVAL.....	B 3/4 9-2
3/4.9.11 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION.....	B 3/4 9-2
<u>3/4.10 SPECIAL TEST EXCEPTIONS</u>	
3/4.10.1 PRIMARY CONTAINMENT INTEGRITY.....	B 3/4 10-1
3/4.10.2 ROD WORTH MINIMIZER.....	B 3/4 10-1
3/4.10.3 SHUTDOWN MARGIN DEMONSTRATIONS.....	B 3/4 10-1
3/4.10.4 RECIRCULATION LOOPS.....	B 3/4 10-1
3/4.10.5 OXYGEN CONCENTRATION.....	B 3/4 10-1
3/4.10.6 TRAINING STARTUPS.....	B 3/4 10-1
<u>3/4.11 RADIOACTIVE EFFLUENTS</u>	
3/4.11.1 LIQUID EFFLUENTS	
The information on page B 3/4 11-1 has been intentionally omitted. Refer to note on this page.	B 3/4 11-1
(Deleted).....	B 3/4 11-2
Liquid Holdup Tanks.....	B 3/4 11-2
3/4.11.2 GASEOUS EFFLUENTS	
(Deleted).....	B 3/4 11-2
The information on page B 3/4 11-3 has been intentionally omitted. Refer to note on this page.	B 3/4 11-3
(Deleted).....	B 3/4 11-4

## DEFINITIONS

### REFUELING FLOOR SECONDARY CONTAINMENT INTEGRITY (Continued)

- b. All refueling floor secondary containment hatches and blowout panels are closed and sealed.
- c. The standby gas treatment system is in compliance with the requirements of Specification 3.6.5.3.
- d. At least one door in each access to the refueling floor secondary containment is closed.
- e. The sealing mechanism associated with each refueling floor secondary containment penetration, e.g., welds, bellows, or O-rings, is OPERABLE.
- f. The pressure within the refueling floor secondary containment is less than or equal to the value required by Specification 4.6.5.1.2a.

### REPORTABLE EVENT

- 1.36 A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 to 10 CFR Part 50.

### ROD DENSITY

- 1.37 ROD DENSITY shall be the number of control rod notches inserted as a fraction of the total number of control rod notches. All rods fully inserted is equivalent to 100% ROD DENSITY.

### SHUTDOWN MARGIN

- 1.38 SHUTDOWN MARGIN shall be the amount of reactivity by which the reactor is subcritical or would be subcritical assuming all control rods are fully inserted except for the single control rod of highest reactivity worth which is assumed to be fully withdrawn and the reactor is in the shutdown condition; cold, i.e. 68°F; and xenon free.

### SITE BOUNDARY

- 1.39 The SITE BOUNDARY shall be that line as defined in Figure 5.1.3-1a.

- 1.40 (Deleted)

### SOURCE CHECK

- 1.41 A SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to a radioactive source.

## DEFINITIONS

### STAGGERED TEST BASIS

- 1.42 A STAGGERED TEST BASIS shall consist of:
- A test schedule for n systems, subsystems, trains, or other designated components obtained by dividing the specified test interval into n equal subintervals.
  - The testing of one system, subsystem, train, or other designated component at the beginning of each subinterval.

### THERMAL POWER

- 1.43 THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

### TURBINE BYPASS SYSTEM RESPONSE TIME

- 1.43A The TURBINE BYPASS SYSTEM RESPONSE TIME shall be that time interval from when the turbine bypass control unit generates a turbine bypass valve flow signal until the turbine bypass valves travel to their required position. The response time may be measured by any series of sequential, overlapping, or total steps such that the entire response time is measured.

### UNIDENTIFIED LEAKAGE

- 1.44 UNIDENTIFIED LEAKAGE shall be all leakage which is not IDENTIFIED LEAKAGE.

### UNRESTRICTED AREA

- 1.45 An UNRESTRICTED AREA shall be any area at or beyond the SITE BOUNDARY access to which is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials, or any area within the SITE BOUNDARY used for residential quarters or for industrial, commercial, institutional, and/or recreational purposes.

### VENTILATION EXHAUST TREATMENT SYSTEM

- 1.46 A VENTILATION EXHAUST TREATMENT SYSTEM shall be any system designed and installed to reduce gaseous radioiodine or radioactive material in particulate form in effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters for the purpose of removing iodines or particulates from the gaseous exhaust stream prior to the release to the environment (such a system is not considered to have any effect on noble gas effluents). Engineered Safety Feature (ESF) atmospheric cleanup systems are not considered to be VENTILATION EXHAUST TREATMENT SYSTEM components.

### VENTING

- 1.47 VENTING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is not provided or required during VENTING. Vent, used in system names, does not imply a VENTING process.

## POWER DISTRIBUTION LIMITS

### 3/4.2.2 APRM SETPOINTS

#### LIMITING CONDITION FOR OPERATION

3.2.2 The APRM flow biased neutron flux-upscale scram trip setpoint (S) and flow biased neutron flux-upscale control rod block trip setpoint ( $S_{RB}$ ) shall be established according to the following relationships:

	TRIP SETPOINT	ALLOWABLE VALUE
During two recirculation loop operation	$S \leq (0.58W + 59\%)T$ $S_{RB} \leq (0.58W + 50\%)T$	$S \leq (0.58W + 62\%)T$ $S_{RB} \leq (0.58W + 53\%)T$
During single recirculation loop operation	$S \leq (0.58W + 54\%)T$ $S_{RB} \leq (0.58W + 45\%)T$	$S \leq (0.58W + 57\%)T$ $S_{RB} \leq (0.58W + 48\%)T$

where: S and  $S_{RB}$  are in percent of RATED THERMAL POWER,

W = Loop recirculation flow as a percentage of the loop recirculation flow which produces a rated core flow of 100 million lbs/hr,

T = Lowest value of the ratio of FRACTION OF RATED THERMAL POWER divided by the CORE MAXIMUM FRACTION OF LIMITING POWER DENSITY.  
T is applied only if less than or equal to 1.0.

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

#### ACTION:

With the APRM flow biased neutron flux-upscale scram trip setpoint and/or the flow biased neutron flux-upscale control rod block trip setpoint less conservative than the value shown in the Allowable Value column for S or  $S_{RB}$ , as above determined, initiate corrective action within 15 minutes and adjust S and/or  $S_{RB}$  to be consistent with the Trip Setpoint values\* within 6 hours or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.

#### SURVEILLANCE REQUIREMENTS

4.2.2 The F RTP and the MFLPD shall be determined, the value of T calculated, and the most recent actual APRM flow biased neutron flux-upscale scram and flow biased neutron flux-upscale control rod block trip setpoints verified to be within the above limits or adjusted, as required:

- At least once per 24 hours,
- Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- Initially and at least once per 12 hours when the reactor is operating with MFLPD greater than or equal to F RTP.
- The provisions of Specification 4.0.4 are not applicable.

\*With MFLPD greater than the F RTP, rather than adjusting the APRM setpoints, the APRM gain may be adjusted such that the APRM readings are greater than or equal to 100% times MFLPD, provided that the adjusted APRM reading does not exceed 100% of RATED THERMAL POWER and a notice of adjustment is posted on the reactor control panel.

## POWER DISTRIBUTION LIMIT

### 3/4.2.3 MINIMUM CRITICAL POWER RATIO

#### LIMITING CONDITION FOR OPERATION

3.2.3 The MINIMUM CRITICAL POWER RATIO (MCPR) shall be equal to or greater than the MCPR limit times the  $K_f$ , both values shown in the CORE OPERATING LIMITS REPORT, provided that the end-of-cycle recirculation pump trip (EOC-RPT) system is OPERABLE per Specification 3.3.4.2 and the main turbine bypass system is OPERABLE per Specification 3.7.8, with:

$$\tau = \frac{(\tau_{ave} - \tau_B)}{\tau_A - \tau_B}$$

where:

$\tau_A$  = 0.86 seconds, control rod average scram insertion time limit to notch 39 per Specification 3.1.3.3,

$$\tau_B = 0.672 + 1.65 \left( \frac{N_1}{\sum_{i=1}^n N_i} \right)^{1/2} (0.016),$$

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i},$$

$n$  = number of surveillance tests performed to date in cycle,

$N_i$  = number of active control rods measured in the  $i^{th}$  surveillance test,

$\tau_i$  = average scram time to notch 39 of all rods measured in the  $i^{th}$  surveillance test, and

$N_1$  = total number of active rods measured in Specification 4.1.3.2.a.

#### APPLICABILITY:

OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.



## POWER DISTRIBUTION LIMITS

### LIMITING CONDITION FOR OPERATION (Continued)

#### ACTION

- a. With the end-of-cycle recirculation pump trip system inoperable per Specification 3.3.4.2, operation may continue provided that, within 1 hour, MCPR is determined to be greater than or equal to the MCPR limit as a function of the average scram time (shown in the CORE OPERATING LIMITS REPORT) EOC-RPT inoperable curve, times the  $K_f$  shown in the CORE OPERATING LIMITS REPORT.
- b. With MCPR less than the applicable MCPR limit shown in the CORE OPERATING LIMITS REPORT, initiate corrective action within 15 minutes and restore MCPR to within the required limit within 2 hours or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.
- c. With the main turbine bypass system inoperable per Specification 3.7.8, operation may continue provided that, within 1 hour, MCPR is determined to be greater than or equal to the MCPR limit as a function of the average scram time (shown in the CORE OPERATING LIMITS REPORT) main turbine bypass valve inoperable curve, times the  $K_f$  shown in the CORE OPERATING LIMITS REPORT.

#### SURVEILLANCE REQUIREMENTS

##### 4.2.3 MCPR, with:

- a.  $\tau = 1.0$  prior to performance of the initial scram time measurements for the cycle in accordance with Specification 4.1.3.2, or
- b.  $\tau$  as defined in Specification 3.2.3 used to determine the limit within 72 hours of the conclusion of each scram time surveillance test required by Specification 4.1.3.2,

shall be determined to be equal to or greater than the applicable MCPR limit determined from the CORE OPERATING LIMITS REPORT.

- a. At least once per 24 hours,
- b. Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- c. Initially and at least once per 12 hours when the reactor is operating with a LIMITING CONTROL ROD PATTERN for MCPR.
- d. The provisions of Specification 4.0.4 are not applicable.

Figures on pages  
3/4 2-10 thru 3/4 2-11  
have been removed  
from Technical Specifications,  
and relocated to the  
CORE OPERATING LIMITS REPORT.

Technical Specifications pages  
3/4 2-10a thru 3/4 2-11  
have been INTENTIONALLY OMITTED.

## PLANT SYSTEMS

### 3/4.7.8 MAIN TURBINE BYPASS SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

3.7.8 The main turbine bypass system shall be OPERABLE as determined by the number of operable main turbine bypass valves being greater than or equal to that specified in the CORE OPERATING LIMITS REPORT.

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

ACTION: With the main turbine bypass system inoperable, restore the system to OPERABLE status within 1 hour or take the ACTION required by Specification 3.2.3.c.

#### SURVEILLANCE REQUIREMENTS

---

4.7.8 The main turbine bypass system shall be demonstrated OPERABLE at least once per:

- a. 31 days by cycling each turbine bypass valve through at least one complete cycle of full travel,
- b. refueling cycle by performing a system functional test which includes simulated automatic actuation, and by verifying that each automatic valve actuates to its correct position, and
- c. refueling cycle by determining TURBINE BYPASS SYSTEM RESPONSE TIME to be less than or equal to the value specified in the CORE OPERATING LIMITS REPORT.

## PLANT SYSTEMS

### BASES

---

#### 3/4 7.8 MAIN TURBINE BYPASS SYSTEM

The required OPERABILITY of the main turbine bypass system is consistent with the assumptions of the feedwater controller failure analysis in the cycle specific transient analysis.

The main turbine bypass system is required to be OPERABLE to limit peak pressure in the main steam lines and to maintain reactor pressure within acceptable limits during events that cause rapid pressurization such that the Safety Limit MCPR is not exceeded. With the main turbine bypass system inoperable, continued operation is based on the cycle specific transient analysis which has been performed for the feedwater controller failure, maximum demand with bypass failure.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PHILADELPHIA ELECTRIC COMPANY

DOCKET NO. 50-353

LIMERICK GENERATING STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 16  
License No. NPF-85

1. The Nuclear Regulatory Commission (the Commission) has found that
  - A. The application for amendment by Philadelphia Electric Company (the licensee) dated August 27, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-85 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 16, are hereby incorporated into this license. Philadelphia Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*Charles L. Miller*

Charles L. Miller, Director  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: October 24, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 16

FACILITY OPERATING LICENSE NO. NPF-85

DOCKET NO. 50-353

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Overleaf pages are provided to maintain document completeness.\*

<u>Remove</u>	<u>Insert</u>
i	i*
ii	ii
xiii	xiii*
xiv	xiv
xxi	xxi
xxii	xxii*
1-7	1-7*
1-8	1-8
3/4 2-7	3/4 2-7*
3/4 2-8	3/4 2-8
3/4 2-9	3/4 2-9
3/4 2-10	3/4 2-10*
-	3/4 7-33
-	-
-	B 3/4 7-5
-	-

## INDEX

### DEFINITIONS

<u>SECTION</u>	<u>PAGE</u>
<u>1.0 DEFINITIONS</u>	
1.1 ACTION.....	1-1
1.2 AVERAGE PLANAR EXPOSURE.....	1-1
1.3 AVERAGE PLANAR LINEAR HEAT GENERATION RATE.....	1-1
1.4 CHANNEL CALIBRATION.....	1-1
1.5 CHANNEL CHECK.....	1-1
1.6 CHANNEL FUNCTIONAL TEST.....	1-1
1.7 CORE ALTERATION.....	1-2
1.7a CORE OPERATING LIMITS REPORT.....	1-2
1.8 CRITICAL POWER RATIO.....	1-2
1.9 DOSE EQUIVALENT I-131.....	1-2
1.10 $\bar{E}$ -AVERAGE DISINTEGRATION ENERGY.....	1-2
1.11 EMERGENCY CORE COOLING SYSTEM (ECCS) RESPONSE TIME.....	1-2
1.12 END-OF-CYCLE RECIRCULATION PUMP TRIP SYSTEM RESPONSE TIME....	1-2
1.13 FRACTION OF LIMITING POWER DENSITY.....	1-3
1.14 FRACTION OF RATED THERMAL POWER.....	1-3
1.15 FREQUENCY NOTATION.....	1-3
1.16 IDENTIFIED LEAKAGE.....	1-3
1.17 ISOLATION SYSTEM RESPONSE TIME.....	1-3
1.18 LIMITING CONTROL ROD PATTERN.....	1-3
1.19 LINEAR HEAT GENERATION RATE.....	1-3
1.20 LOGIC SYSTEM FUNCTIONAL TEST.....	1-4
1.21 MAXIMUM FRACTION OF LIMITING POWER DENSITY.....	1-4



DEFINITIONS

---

SECTION

<u>DEFINITIONS</u> (Continued)	<u>PAGE</u>
1.22 MEMBER(S) OF THE PUBLIC.....	1-4
1.23 MINIMUM CRITICAL POWER RATIO.....	1-4
1.24 OFFSITE DOSE CALCULATION MANUAL.....	1-4
1.25 OPERABLE - OPERABILITY.....	1-4
1.26 OPERATIONAL CONDITION - CONDITION.....	1-4
1.27 PHYSICS TESTS.....	1-4
1.28 PRESSURE BOUNDARY LEAKAGE.....	1-5
1.29 PRIMARY CONTAINMENT INTEGRITY.....	1-5
1.30 PROCESS CONTROL PROGRAM.....	1-5
1.31 PURGE - PURGING.....	1-5
1.32 RATED THERMAL POWER.....	1-6
1.33 REACTOR ENCLOSURE SECONDARY CONTAINMENT INTEGRITY.....	1-6
1.34 REACTOR PROTECTION SYSTEM RESPONSE TIME.....	1-6
1.35 REFUELING FLOOR SECONDARY CONTAINMENT INTEGRITY.....	1-6
1.36 REPORTABLE EVENT.....	1-7
1.37 ROD DENSITY.....	1-7
1.38 SHUTDOWN MARGIN.....	1-7
1.39 SITE BOUNDARY.....	1-7
1.40 (Deleted).....	1-7
1.41 SOURCE CHECK.....	1-7
1.42 STAGGERED TEST BASIS.....	1-8
1.43 THERMAL POWER.....	1-8
1.43A TURBINE BYPASS SYSTEM RESPONSE TIME.....	1-8
1.44 UNIDENTIFIED LEAKAGE.....	1-8

## INDEX

### LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>CONTAINMENT SYSTEMS (Continued)</u>	
3/4.6.4 VACUUM RELIEF	
Suppression Chamber - Drywell Vacuum Breakers.....	3/4 6-44
3/4.6.5 SECONDARY CONTAINMENT	
Reactor Enclosure Secondary Containment Integrity.....	3/4 6-46
Refueling Area Secondary Containment Integrity.....	3/4 6-47
Reactor Enclosure Secondary Containment Automatic Isolation Valves.....	3/4 6-48
Table 3.6.5.2.1-1 Reactor Enclosure Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-49
Refueling Area Secondary Containment Automatic Isolation Valves.....	3/4 6-50
Table 3.6.5.2.2-1 Refueling Area Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-51
Standby Gas Treatment System - Common System.....	3/4 6-52
Reactor Enclosure Recirculation System.....	3/4 6-55
3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL	
Primary Containment Hydrogen Recombiner Systems.....	3/4 6-57
Drywell Hydrogen Mixing System.....	3/4 6-58
Drywell and Suppression Chamber Oxygen Concentration....	3/4 6-59
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 SERVICE WATER SYSTEMS	
Residual Heat Removal Service Water System - Common System.....	3/4 7-1
Emergency Service Water System - Common System.....	3/4 7-3
Ultimate Heat Sink.....	3/4 7-5

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>PLANT SYSTEMS</u> (Continued)	
3/4.7.2 CONTROL ROOM EMERGENCY FRESH AIR SUPPLY SYSTEM - COMMON SYSTEM.....	3/4 7-6
3/4.7.3 REACTOR CORE ISOLATION COOLING SYSTEM.....	3/4 7-9
3/4.7.4 SNUBBERS.....	3/4 7-11
Figure 4.7.4-1 Sample Plan 2) For Snubber Functional Test.....	3/4 7-16
3/4.7.5 SEALED SOURCE CONTAMINATION.....	3/4 7-17
3/4.7.6 FIRE SUPPRESSION SYSTEMS	
Fire Suppression Water System.....	3/4 7-19
Spray and/or Sprinkler Systems.....	3/4 7-22
CO <sub>2</sub> Systems.....	3/4 7-24
Halon Systems.....	3/4 7-25
Fire Hose Stations.....	3/4 7-26
Table 3.7.6.5-1 Fire Hose Stations.....	3/4 7-27
Yard Fire Hydrants and Hose Cart Houses.....	3/4 7-29
Table 3.7.6.6-1 Yard Fire Hydrants and Hose Cart Houses.....	3/4 7-30
3/4.7.7 FIRE RATED ASSEMBLIES.....	3/4 7-31
3/4.7.8 MAIN TURBINE BYPASS SYSTEM.....	3/4 7-33
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1 A.C. SOURCES	
A.C. Sources - Operating.....	3/4 8-1
Table 4.8.1.1.2-1 Diesel Generator Test Schedule.....	3/4 8-8
A.C. Sources - Shutdown.....	3/4 8-9
3/4.8.2 D. C. SOURCES	
D. C. Sources - Operating.....	3/4 8-10

## INDEX

### BASES

#### SECTION

#### PAGE

#### CONTAINMENT SYSTEMS (Continued)

3/4.6.3	PRIMARY CONTAINMENT ISOLATION VALVES.....	B 3/4 6-4
3/4.6.4	VACUUM RELIEF.....	B 3/4 6-4
3/4.6.5	SECONDARY CONTAINMENT.....	B 3/4 6-5
3/4.6.6	PRIMARY CONTAINMENT ATMOSPHERE CONTROL.....	B 3/4 6-6

#### 3/4.7 PLANT SYSTEMS

3/4.7.1	SERVICE WATER SYSTEMS - COMMON SYSTEMS.....	B 3/4 7-1
3/4.7.2	CONTROL ROOM EMERGENCY FRESH AIR SUPPLY SYSTEM - COMMON SYSTEM.....	B 3/4 7-1
3/4.7.3	REACTOR CORE ISOLATION COOLING SYSTEM.....	B 3/4 7-1a
3/4.7.4	SNUBBERS.....	B 3/4 7-2
3/4.7.5	SEALED SOURCE CONTAMINATION.....	B 3/4 7-3
3/4.7.6	FIRE SUPPRESSION SYSTEMS.....	B 3/4 7-4
3/4.7.7	FIRE RATED ASSEMBLIES.....	B 3/4 7-4
3/4.7.8	MAIN TURBINE BYPASS SYSTEM.....	B 3/4 7-5

#### 3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1, 3/4.8.2, and 3/4.8.3	A.C. SOURCES, D.C. SOURCES, AND ONSITE POWER DISTRIBUTION SYSTEMS.....	B 3/4 8-1
3/4.8.4	ELECTRICAL EQUIPMENT PROTECTIVE DEVICES.....	B 3/4 8-3

#### 3/4.9 REFUELING OPERATIONS

3/4.9.1	REACTOR MODE SWITCH.....	B 3/4 9-1
3/4.9.2	INSTRUMENTATION.....	B 3/4 9-1
3/4.9.3	CONTROL ROD POSITION.....	B 3/4 9-1
3/4.9.4	DECAY TIME.....	B 3/4 9-1
3/4.9.5	COMMUNICATIONS.....	B 3/4 9-1

## INDEX

### BASES

<u>SECTION</u>	<u>PAGE</u>
<u>REFUELING OPERATIONS (Continued)</u>	
3/4.9.6 REFUELING PLATFORM.....	B 3/4 9-2
3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE POOL.....	B 3/4 9-2
3/4.9.8 and 3/4.9.9 WATER LEVEL - REACTOR VESSEL and WATER LEVEL - SPENT FUEL STORAGE POOL.....	B 3/4 9-2
3/4.9.10 CONTROL ROD REMOVAL.....	B 3/4 9-2
3/4.9.11 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION.....	B 3/4 9-2
<u>3/4.10 SPECIAL TEST EXCEPTIONS</u>	
3/4.10.1 PRIMARY CONTAINMENT INTEGRITY.....	B 3/4 10-1
3/4.10.2 ROD WORTH MINIMIZER.....	B 3/4 10-1
3/4.10.3 SHUTDOWN MARGIN DEMONSTRATIONS.....	B 3/4 10-1
3/4.10.4 RECIRCULATION LOOPS.....	B 3/4 10-1
3/4.10.5 OXYGEN CONCENTRATION.....	B 3/4 10-1
3/4.10.6 TRAINING STARTUPS.....	B 3/4 10-1
3/4.10.7 SPECIAL INSTRUMENTATION - INITIAL CORE LOADING....	B 3/4 10-1
<u>3/4.11 RADIOACTIVE EFFLUENTS</u>	
3/4.11.1 LIQUID EFFLUENTS	
The information on page B 3/4 11-1 has been intentionally omitted. Refer to note on this page.....	B 3/4 11-1
(Deleted).....	B 3/4 11-2
Liquid Holdup Tanks.....	B 3/4 11-2
3/4.11.2 GASEOUS EFFLUENTS	
(Deleted).....	B 3/4 11-2
The information on page B 3/4 11-3 has been intentionally omitted. Refer to note on this page.....	B 3/4 11-3
(Deleted).....	B 3/4 11-4

## REACTIVITY CONTROL SYSTEMS

### CONTROL ROD AVERAGE SCRAM INSERTION TIMES

#### LIMITING CONDITION FOR OPERATION

---

3.1.3.3 The average scram insertion time of all OPERABLE control rods from the fully withdrawn position, based on deenergization of the scram pilot valve solenoids as time zero, shall not exceed any of the following:

<u>Position Inserted From Fully Withdrawn</u>	<u>Average Scram Insertion Time (Seconds)</u>
45	0.43
39	0.86
25	1.93
05	3.49

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2.

#### ACTION:

With the average scram insertion time exceeding any of the above limits, be in at least HOT SHUTDOWN within 12 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.1.3.3 All control rods shall be demonstrated OPERABLE by scram time testing from the fully withdrawn position as required by Surveillance Requirement 4.1.3.2.

## DEFINITIONS

### STAGGERED TEST BASIS

- 1.42 A STAGGERED TEST BASIS shall consist of:
- A test schedule for n systems, subsystems, trains, or other designated components obtained by dividing the specified test interval into n equal subintervals.
  - The testing of one system, subsystem, train, or other designated component at the beginning of each subinterval.

### THERMAL POWER

- 1.43 THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

### TURBINE BYPASS SYSTEM RESPONSE TIME

- 1.43A The TURBINE BYPASS SYSTEM RESPONSE TIME shall be that time interval from when the turbine bypass control unit generates a turbine bypass valve flow signal until the turbine bypass valves travel to their required position. The response time may be measured by any series of sequential, overlapping, or total steps such that the entire response time is measured.

### UNIDENTIFIED LEAKAGE

- 1.44 UNIDENTIFIED LEAKAGE shall be all leakage which is not IDENTIFIED LEAKAGE.

### UNRESTRICTED AREA

- 1.45 An UNRESTRICTED AREA shall be any area at or beyond the SITE BOUNDARY access to which is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials, or any area within the SITE BOUNDARY used for residential quarters or for industrial, commercial, institutional, and/or recreational purposes.

### VENTILATION EXHAUST TREATMENT SYSTEM

- 1.46 A VENTILATION EXHAUST TREATMENT SYSTEM shall be any system designed and installed to reduce gaseous radiiodine or radioactive material in particulate form in effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters for the purpose of removing iodines or particulates from the gaseous exhaust stream prior to the release to the environment (such a system is not considered to have any effect on noble gas effluents). Engineered Safety Feature (ESF) atmospheric cleanup systems are not considered to be VENTILATION EXHAUST TREATMENT SYSTEM components.

### VENTING

- 1.47 VENTING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is not provided or required during VENTING. Vent, used in system names, does not imply a VENTING process.

## POWER DISTRIBUTION LIMITS

### 3/4.2.2 APRM SETPOINTS

#### LIMITING CONDITION FOR OPERATION

3.2.2 The APRM flow biased neutron flux-upscale scram trip setpoint (S) and flow biased neutron flux-upscale control rod block trip setpoint ( $S_{RB}$ ) shall be established according to the following relationships:

	TRIP SETPOINT	ALLOWABLE VALUE
During two recirculation loop operation	$S \leq (0.58W + 59\%)T$ $S_{RB} \leq (0.58W + 50\%)T$	$S \leq (0.58W + 62\%)T$ $S_{RB} \leq (0.58W + 53\%)T$
During single recirculation loop operation	$S \leq (0.58W + 54\%)T$ $S_{RB} \leq (0.58W + 45\%)T$	$S \leq (0.58W + 57\%)T$ $S_{RB} \leq (0.58W + 48\%)T$

where: S and  $S_{RB}$  are in percent of RATED THERMAL POWER,  
W = Loop recirculation flow as a percentage of the loop recirculation flow which produces a rated core flow of 100 million lbs/hr,  
T = Lowest value of the ratio of FRACTION OF RATED THERMAL POWER divided by the CORE MAXIMUM FRACTION OF LIMITING POWER DENSITY.  
T is applied only if less than or equal to 1.0.

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

#### ACTION:

With the APRM flow biased neutron flux-upscale scram trip setpoint and/or the flow biased neutron flux-upscale control rod block trip setpoint less conservative than the value shown in the Allowable Value column for S or  $S_{RB}$ , as above determined, initiate corrective action within 15 minutes and adjust S and/or  $S_{RB}$  to be consistent with the Trip Setpoint values\* within 6 hours or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.

#### SURVEILLANCE REQUIREMENTS

4.2.2 The F RTP and the MFLPD shall be determined, the value of T calculated, and the most recent actual APRM flow biased neutron flux-upscale scram and flow biased neutron flux-upscale control rod block trip setpoints verified to be within the above limits or adjusted, as required:

- At least once per 24 hours,
- Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- Initially and at least once per 12 hours when the reactor is operating with MFLPD greater than or equal to F RTP.
- The provisions of Specification 4.0.4 are not applicable.

\*With MFLPD greater than the F RTP, rather than adjusting the APRM setpoints, the APRM gain may be adjusted such that the APRM readings are greater than or equal to 100% times MFLPD, provided that the adjusted APRM reading does not exceed 100% of RATED THERMAL POWER and a notice of adjustment is posted on the reactor control panel.



## POWER DISTRIBUTION LIMIT

### 3/4.2.3 MINIMUM CRITICAL POWER RATIO

#### LIMITING CONDITION FOR OPERATION

---

3.2.3 The MINIMUM CRITICAL POWER RATIO (MCPR) shall be equal to or greater than the MCPR limit times the  $K_f$ , both values shown in the CORE OPERATING LIMITS REPORT, provided that the end-of-cycle recirculation pump trip (EOC-RPT) system is OPERABLE per Specification 3.3.4.2 and the main turbine bypass system is OPERABLE per Specification 3.7.8, with:

$$\tau = \frac{(\tau_{ave} - \tau_B)}{\tau_A - \tau_B}$$

where:

$\tau_A$  = 0.86 seconds, control rod average scram insertion time limit to notch 39 per Specification 3.1.3.3,

$$\tau_B = 0.672 + 1.65 \left( \frac{N_1}{\sum_{i=1}^n N_i} \right)^{1/2} (0.016),$$

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i},$$

$n$  = number of surveillance tests performed to date in cycle,

$N_i$  = number of active control rods measured in the  $i^{th}$  surveillance test,

$\tau_i$  = average scram time to notch 39 of all rods measured in the  $i^{th}$  surveillance test, and

$N_1$  = total number of active rods measured in Specification 4.1.3.2.a.

#### APPLICABILITY:

OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

## POWER DISTRIBUTION LIMITS

### LIMITING CONDITION FOR OPERATION (Continued)

#### ACTION

- a. With the end-of-cycle recirculation pump trip system inoperable per Specification 3.3.4.2, operation may continue provided that, within 1 hour, MCPR is determined to be greater than or equal to the MCPR limit as a function of the average scram time shown in the appropriate figure in the CORE OPERATING LIMITS REPORT, for EOC-RPT inoperable curve, times the  $K_f$  shown in the CORE OPERATING LIMITS REPORT.
- b. With MCPR less than the applicable MCPR limit shown in the CORE OPERATING LIMITS REPORT, initiate corrective action within 15 minutes and restore MCPR to within the required limit within 2 hours or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.
- c. With the main turbine bypass system inoperable per Specification 3.7.8, operation may continue provided that, within 1 hour, MCPR is determined to be greater than or equal to the MCPR limit as a function of the average scram time (shown in the CORE OPERATING LIMITS REPORT) main turbine bypass valve inoperable curve, times the  $K_f$  shown in the CORE OPERATING LIMITS REPORT.

#### SURVEILLANCE REQUIREMENTS

##### 4.2.3 MCPR, with:

- a.  $\tau = 1.0$  prior to performance of the initial scram time measurements for the cycle in accordance with Specification 4.1.3.2, or
- b.  $\tau$  as defined in Specification 3.2.3 used to determine the limit within 72 hours of the conclusion of each scram time surveillance test required by Specification 4.1.3.2,

shall be determined to be equal to or greater than the applicable MCPR limit determined from the appropriate figure in the CORE OPERATING LIMITS REPORT times the  $K_f$  shown in the CORE OPERATING LIMITS REPORT.

- a. At least once per 24 hours,
- b. Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- c. Initially and at least once per 12 hours when the reactor is operating with a LIMITING CONTROL ROD PATTERN for MCPR.
- d. The provisions of Specification 4.0.4 are not applicable.

Figures on pages  
3/4 2-10 thru 3/4 2-11  
have been removed from  
Technical Specifications, and  
relocated to the CORE OPERATING  
LIMITS REPORT.

Technical Specifications pages  
3/4 2-10a and 3/4 2-11  
have been INTENTIONALLY OMITTED.

## PLANT SYSTEMS

### 3/4.7.8 MAIN TURBINE BYPASS SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

3.7.8 The main turbine bypass system shall be OPERABLE as determined by the number of operable main turbine bypass valves being greater than or equal to that specified in the CORE OPERATING LIMITS REPORT.

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

ACTION: With the main turbine bypass system inoperable, restore the system to OPERABLE status within 1 hour or take the ACTION required by Specification 3.2.3.c.

#### SURVEILLANCE REQUIREMENTS

---

4.7.8 The main turbine bypass system shall be demonstrated OPERABLE at least once per:

- a. 31 days by cycling each turbine bypass valve through at least one complete cycle of full travel,
- b. refueling cycle by performing a system functional test which includes simulated automatic actuation, and by verifying that each automatic valve actuates to its correct position, and
- c. refueling cycle by determining TURBINE BYPASS SYSTEM RESPONSE TIME to be less than or equal to the value specified in the CORE OPERATING LIMITS REPORT.

## PLANT SYSTEMS

### BASES

---

#### 3/4 7.8 MAIN TURBINE BYPASS SYSTEM

The required OPERABILITY of the main turbine bypass system is consistent with the assumptions of the feedwater controller failure analysis in the cycle specific transient analysis.

The main turbine bypass system is required to be OPERABLE to limit peak pressure in the main steam lines and to maintain reactor pressure within acceptable limits during events that cause rapid pressurization such that the Safety Limit MCPR is not exceeded. With the main turbine bypass system inoperable, continued operation is based on the cycle specific transient analysis which has been performed for the feedwater controller failure, maximum demand with bypass failure.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 52 AND 16 TO FACILITY OPERATING

LICENSE NOS. NPF-39 AND NPF-85

PHILADELPHIA ELECTRIC COMPANY

LIMERICK GENERATING STATION, UNITS 1 AND 2

DOCKET NOS. 50-352 AND 50-353

1.0 INTRODUCTION

By letter dated August 27, 1991, the Philadelphia Electric Company (the licensee) submitted a request for changes to the Limerick Generating Station, Units 1 and 2, Technical Specifications (TS). The requested changes would add a new Section 3/4 7-8 to the TSs to add operability requirements, Limiting Conditions for Operation (LCOs) and Surveillance Requirements (SRs) for the main turbine bypass system.

2.0 DISCUSSION:

The main turbine bypass system for the Limerick Generating Station (LGS), Units 1 and 2, is a non-safety related system designed to control steam pressure when reactor steam generation exceeds main turbine requirements during plant startup, sudden load rejection, and cooldown. It allows a direct flow path for the excess steam flow from the reactor to the condenser without going through the main turbine. The bypass capacity of the system is rated for 25% of the Nuclear Steam Supply System rated flow. Sudden load reductions within the capacity of the main turbine bypass system can be accommodated without initiating a reactor scram. The main turbine bypass system consists of a nine valve steam chest connected to the main steam lines between the outboard main steam isolation valves and the turbine stop valves. Each of these nine valves is automatically operated by hydraulic cylinders. The bypass valves are normally closed and the turbine electrohydraulic control (EHC) pressure regulator controls the turbine control valves directing all steam flow to the turbine. If the speed governor or the load limiter restricts steam flow to the turbine, the regulator controls the system pressure by sequentially opening the bypass valves. When the bypass valves open, the steam flows from the bypass valve steam chest, through the connecting piping, to the pressure breakdown assemblies where a series of orifices are used to further reduce the steam pressure before the steam enters the condenser.

The main turbine bypass system receives a signal to open the bypass valves from the EHC pressure regulator whenever the actual steam pressure exceeds the preset steam pressure (lower than the set point pressure for the main steam relief valves). This occurs when the amount of steam generated by the reactor can not be entirely utilized by the main turbine. The bypass valves open sequentially, and are used during normal startup and shut down.

If there is a full load rejection, all nine valves will open to bypass a maximum of 25% of the design steam flow. The operability of the bypass system will be determined by the number of operable main turbine bypass valves being greater than or equal to that specified in the cycle specific Core Operating Limits Report (COLR).

### 3.0 EVALUATION

The current operating limit minimum critical power ratio (MCPR) for LGS Unit 1 and Unit 2 is based on the feedwater controller failure (FCF) without bypass transient. By periodically verifying the operability of the bypass system, the plant can take credit for the analysis of FCF with bypass, and thereby, operate with a lower operating MCPR limit. The latest NRC approved Boiling Water Reactor (BWR) Standard TS (NUREG-0123, Rev. 3, 1980) includes the main turbine bypass system operability requirements. As a result, most BWR plants already have the main turbine bypass system operability requirements in their TS. When the LGS, Unit 1 was licensed to operate, the MCPR limit posed no operational constraints; thus, the licensee declined to include operability requirements on the main turbine bypass system.

The main turbine bypass system limits the peak pressure in the main steam lines and maintains reactor pressure within acceptable limits during events that cause rapid pressurization. Chapter 15 of the LGS Updated Final Safety Analysis Report (UFSAR) includes an evaluation of the effects of reactor pressure increase on fuel thermal margin during possible pressurization events. These analyses specified the operating limit MCPRs for the initial core at which the safety limit MCPR would not be exceeded during the pressurization events. All subsequent operating limit MCPRs are determined by the cycle specific transient analysis for LGS Unit 1 and Unit 2, respectively. For example, Unit 2 shutdown March 22, 1991 for the first refueling, returning to service on June 5, 1991. During the refueling, fuel of a different design than was previously used in Units 1 and 2 was installed in the core. The replacement fuel assemblies consisted of 212 bundles of GE9B assemblies and 12 lead test assemblies (4 bundles of GE11, 4 bundles of ANF and 4 bundles of ABB fuel). The operating limit MCPR (not taking credit for the bypass valves) is 1.30 for the GE7B and GE9B fuel, 1.35 for the GE11 fuel and 1.47 for ABB and ANF fuel. By being able to take credit for an operable steam bypass system, the initial operating limit MCPR for the GE11 fuel is reduced from 1.35 to 1.27 and the limit for the ABB and ANF fuel is reduced from 1.47 to 1.39.

Of the pressurization events, the FCF, maximum demand is currently the most limiting. The cycle specific transient analysis indicates that the operating limit MCPR is lower for the FCF with an operable bypass system. Verifying the operability of the turbine bypass system in accordance with the proposed TS provides assurance that the system will operate and perform its intended function of ensuring that the safety limit MCPR is not exceeded should a FCF transient occur while operating at the reduced operating limit MCPR. Additionally, the proposed TS will ensure that when the bypass system is inoperable, the operating limit MCPR is established to provide sufficient margin such that the safety limit MCPR is not exceeded in the event of a FCF transient.

As noted previously, most BWRs already take credit for having an operable bypass sytem and have TSs to verify operability of the system. The proposed TSs for LGS require that if the main turbine bypass system is inoperable, the MCPR limits must be adjusted within one hour to the limits that do not take credit for the reduced peak pressures during a transient in which the bypass valves open as designed.

The proposed TS changes will ensure that the operating limit MCPR, as determined by the cycle specific transient analysis for LGS Unit 1 and Unit 2, respectively, will be established based on the operability of the main turbine bypass system such that the safety limit MCPR will not be exceeded in the event of the occurrence of the analyzed transients. Therefore, the proposed TS changes are acceptable.

#### 4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Pennsylvania State official was notified of the proposed issuance of the amendments. The State official had no comments.

#### 5.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (56 FR 47241). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

#### 6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Richard J. Clark

Date: October 24, 1991