

September 15, 1994

Mr. George A. Hunger, Jr.
Director-Licensing, R-52A-5
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, Pennsylvania 19087-0195

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE AND OPPORTUNITY FOR A HEARING (TAC NOS. M88609 AND
M88656)

Dear Mr. Hunger:

The Commission has requested the Office of the Federal Register to publish the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for a Hearing." This notice relates to your application for amendment dated January 14, 1994, which would revise the Technical Specifications to permit an increase in the allowable leak rate for the main steam isolation valves (MSIVs), and delete the MSIV Leakage Control System (LCS). The main steam drain lines and the main condenser would be utilized as an alternate MSIV leakage treatment system.

Sincerely,
/s/

Frank Rinaldi, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-352/50-353

Enclosure: Notice

cc w/enclosure:
See next page

DISTRIBUTION w/enclosure

| | | |
|-------------|-------------|----------------|
| Docket File | FRinaldi | Ewenzinger, RI |
| PUBLIC | MO'Brien(2) | CAnderson, RI |
| PDI-2 Rdg. | OGC | |
| SVarga | ACRS(10) | |
| CMiller | OPA | |
| MThadani | OC/LFDCB | |

| | | | | | |
|--------|----------|----------|----------|----------|-----|
| OFFICE | PDI-2/LA | PDI-2/PM | OGC | PDI-2/D | |
| NAME | MO'Brien | FRinaldi | MThadani | MThadani | |
| DATE | 9/17/94 | 9/17/94 | 9/15/94 | 9/15/94 | 1/1 |

OFFICIAL RECORD COPY
FILENAME: A:\LI88609.PRI

230026
9409260119 940915
PDR ADOCK 05000352
P PDR

NRG FILE CENTER COPY

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 15, 1994

Mr. George A. Hunger, Jr.
Director-Licensing, MN 52A-5
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, Pennsylvania 19087-0195

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE AND OPPORTUNITY FOR A HEARING (TAC NOS. M88609 AND
M88656)

Dear Mr. Hunger:

The Commission has requested the Office of the Federal Register to publish the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for a Hearing." This notice relates to your application for amendment dated January 14, 1994, which would revise the Technical Specifications to permit an increase in the allowable leak rate for the main steam isolation valves (MSIVs), and delete the MSIV Leakage Control System (LCS). The main steam drain lines and the main condenser would be utilized as an alternate MSIV leakage treatment system.

Sincerely,

A handwritten signature in cursive script, appearing to read "Frank Rinaldi".

Frank Rinaldi, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-352/50-353

Enclosure: Notice

cc w/enclosure:
See next page

Mr. George A. Hunger, Jr.
PECO Energy Company

Limerick Generating Station,
Units 1 & 2

cc:

J. W. Durham, Sr., Esquire
Sr. V.P. & General Counsel
PECO Energy Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. Rich R. Janati, Chief
Division of Nuclear Safety
PA Dept. of Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469

Mr. David P. Helker, MC 62A-1
Manager-Limerick Licensing
PECO Energy Company
965 Chesterbrook Boulevard
Wayne, Pennsylvania 19087-5691

Mr. James A. Muntz
Superintendent-Technical
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. David R. Helwig, Vice President
Limerick Generating Station
Post Office Box A
Sanatoga, Pennsylvania 19464

Mr. James L. Kantner
Manager-Experience Assessment
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. Robert Boyce
Plant Manager
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Library
US Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Larry Hopkins
Superintendent-Operations
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. Neil S. Perry
Senior Resident Inspector
US Nuclear Regulatory Commission
P. O. Box 596
Pottstown, Pennsylvania 19464

Mr. John Doering, Chairman
Nuclear Review Board
PECO Energy Company
965 Chesterbrook Boulevard
Mail Code 63C-5
Wayne, Pennsylvania 19087

Mr. Craig L. Adams
Superintendent - Services
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

UNITED STATES NUCLEAR REGULATORY COMMISSION
PHILADELPHIA ELECTRIC COMPANY
DOCKET NOS. 50-352 AND 50-353
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating License Nos. NFP-39 and NPF-85, issued to Philadelphia Electric Company (the licensee), for operation of the Limerick Generating Station, Units 1 and 2, located in Montgomery County, Pennsylvania.

The proposed amendment would revise the Technical Specifications to permit an increase in the allowable leak rate for the main steam isolation valves (MSIVs), and delete the MSIV Leakage Control System (LCS). The main steam drain lines and the main condenser would be utilized as an alternate MSIV leakage treatment system.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By October 26, 1994, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in

accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555 and at the local public document room located at the Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days

prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to Mohan C. Thadani, Acting Project Director: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to J. W. Durham, Sr., Esquire, Sr. V.P. and General Counsel, Philadelphia Electric Company, 2301 Market Street, Philadelphia, Pennsylvania 19101, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for a hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated January 14, 1994, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555, and at the local public document room located at the Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

Dated at Rockville, Maryland, this 20th day of September 1994.

FOR THE NUCLEAR REGULATORY COMMISSION



Mohan C. Thadani, Acting Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation