

**From:** Lawrence Burkhart  
**To:** Brian Sepelak  
**Date:** 5/30/01 10:21AM  
**Subject:** RAI - POWER UPRATE

Brain,

This is one additional questions regarding the steam generators. This may be just a clarification and may not be needed to be docketed.

In Enclosure 1 of the 1/18/2001 submittal (second sentence of the 2nd paragraph on page 3-29), the licensee stated that "...The Technical Specification plugging limit of 40-percent through wall is applied to anti-vibration bar (AVB) wear at both units, and to cold leg thinning at Unit 1...."

My question is: why is the 40-percent criterion not applicable to cold leg thinning at Unit 2? (unless cold leg thinning has not occurred in the Unit 2 steam generator tubes)

**Mail Envelope Properties** (3B1501DB.537 : 6 : 21370)

**Subject:** RAI - POWER UPRATE  
**Creation Date:** 5/30/01 10:21AM  
**From:** Lawrence Burkhart

**Created By:** LJB@nrc.gov

**Recipients**

firstenergycorp.com  
sepelakb (Brian Sepelak)

**Post Office**  
firstenergycorp.com

**Route**  
internet

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1303	05/30/01 10:21AM

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard