

November 9, 1995

Mr. George A. Hunger, Jr.
Director-Licensing, MC 62A-1
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, PA 19087-0195

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT,
LIMERICK GENERATING STATION, UNIT 1 (TAC NO. M92613)

Dear Mr. Hunger:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for exemption dated June 20, 1995. The proposed action would allow an exemption to permit the 10 CFR Part 50, Appendix J, Type A test to be extended from the sixth refueling outage to the seventh refueling outage.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,
/s/

Frank Rinaldi, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-352

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION

Docket File WPasciak, RGN-I
PUBLIC
PDI-2 Reading
SVarga/JZwolinski
FRinaldi
MO'Brien
OGC
ACRS

OFFICE	PDI-2/VA	PDI-2/PM	PDI-2/PM	OGC	PDI-2/D
NAME	MO'Brien	SDembek:rb	FRinaldi	ET602/CGR	JSt01z
DATE	10/26/95	10/26/95	10/27/95	11/2/95	11/8/95

OFFICIAL RECORD COPY
DOCUMENT NAME: LI192613.EA

140109

NO OFFICIAL COPY

9511150238 951109
PDR ADOCK 05000352
PDR

DP1



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 9, 1995

Mr. George A. Hunger, Jr.
Director-Licensing, MC 62A-1
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, PA 19087-0195

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT,
LIMERICK GENERATING STATION, UNIT 1 (TAC NO. M92613)

Dear Mr. Hunger:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for exemption dated June 20, 1995. The proposed action would allow an exemption to permit the 10 CFR Part 50, Appendix J, Type A test to be extended from the sixth refueling outage to the seventh refueling outage.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script that reads "Frank Rinaldi".

Frank Rinaldi, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-352

Enclosure: Environmental Assessment

cc w/encl: See next page

Mr. George A. Hunger, Jr.
PECO Energy Company

Limerick Generating Station,
Units 1 & 2

cc:

J. W. Durham, Sr., Esquire
Sr. V.P. & General Counsel
PECO Energy Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. Rich R. Janati, Chief
Division of Nuclear Safety
PA Dept. of Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469

Mr. David P. Helker, MC 62A-1
Manager-Limerick Licensing
PECO Energy Company
965 Chesterbrook Boulevard
Wayne, Pennsylvania 19087-5691

Mr. Michael P. Gallagher
Director - Site Engineering
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. Walter G. McFarland, Vice President
Limerick Generating Station
Post Office Box A
Sanatoga, Pennsylvania 19464

Mr. James L. Kantner
Manager-Experience Assessment
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. Robert Boyce
Plant Manager
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Library
US Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Ludwig E. Thibault
Senior Manager - Operations
Limerick Generating Station
P. O. Box A
Sanatoga, Pennsylvania 19464

Mr. Neil S. Perry
Senior Resident Inspector
US Nuclear Regulatory Commission
P. O. Box 596
Pottstown, Pennsylvania 19464

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Mr. Craig L. Adams
Director - Site Support Services
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Roy Denmark
Environmental Review Coordinator
841 Chestnut Street
Philadelphia, PA 19107

Chairman
Board of Supervisors
of Limerick Township
646 West Ridge Pike
Linfield, PA 19468

UNITED STATES NUCLEAR REGULATORY COMMISSIONPHILADELPHIA ELECTRIC COMPANYLIMERICK GENERATING STATION, UNIT 1DOCKET NO. 50-352ENVIRONMENTAL ASSESSMENT AND FINDING OFNO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from the requirements of 10 CFR Part 50, Appendix J (hereafter referred to as Appendix J) to Facility Operating License No. NPF-39 issued to Philadelphia Electric Company (the licensee), for operation of the Limerick Generating Station (LGS), Unit 1, located at the licensee's site in Chester and Montgomery Counties, Pennsylvania.

ENVIRONMENTAL ASSESSMENTIdentification of the Proposed Action:

The proposed action would allow an exemption from Appendix J, Section III.D.1.(a), which requires a set of three Type A tests (i.e., Containment Integrated Leakage Rate Test) to be performed at approximately equal intervals during each 10-year service period and specifies that the third test of each set be conducted when the plant is shutdown for the 10-year inservice inspection (ISI). The exemption would allow a one-time test interval extension from the current scheduled 62 months to approximately 89 months. It should also be noted that the licensee previously was granted a similar exemption on February 8, 1994 (59 FR 5758). This 1994 exemption allowed the licensee to perform its third Type A test during the 10-year plant ISI refueling outage by extending the test interval 15 months.

The licensee requested that the current exemption request supersede the previously granted exemption.

The proposed action is in accordance with the licensee's application for exemption dated June 20, 1995.

The Need for the Proposed Action:

The proposed action is needed to allow the licensee to realize cost savings and reduced worker radiation exposure. Subsequent to the licensee's submittal, a rulemaking was completed (see 60 FR 49495 September 26, 1995), which allows the Type A test to be performed at intervals up to once every 10 years (the actual period is based on historical performance of the containment). However, because the licensee's outage is scheduled to begin in January 1996, there is insufficient time for the licensee to implement the amended rule prior to the start of the outage.

Environmental Impacts of the Proposed Action:

The Commission has completed its evaluation of the proposed exemption and concludes that this action would not significantly increase the probability or amount of expected primary containment leakage; hence, the containment integrity would be maintained. The current requirement in Section III.D.1.(a) of Appendix J to perform the three Type A tests would continue to be met, except that the time interval between the second and third type A tests would be extended to approximately 89 months.

The licensee has analyzed the results of previous Type A tests to show good containment performance and will continue to be required to conduct the Type B and C local leak rate tests which historically have been shown to be the principal means of detecting containment leakage paths. It is also noted

that the licensee, as a condition of the proposed exemption, will perform the visual containment inspection although it is only required by Appendix J to be conducted in conjunction with Type A tests. The NRC staff considers that these inspections, though limited in scope, provide an important added level of confidence in the continued integrity of the containment boundary.

Based on the information presented in the licensee's application, the proposed extended test interval would not result in a non-detectable leakage rate in excess of the value established by Appendix J, or in any changes to the containment structure or plant systems. Consequently, the probability of accidents would not be increased, nor would the post-accident radiological releases be greater than previously determined. Neither would the proposed exemption otherwise affect radiological plant effluents. Accordingly, the Commission concludes that this proposed exemption would result in no significant radiological environmental impact.

With regard to potential nonradiological impacts, the proposed action does involve features located entirely within the restricted area as defined in 10 CFR Part 20. It does not affect nonradiological plant effluents and has no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed exemption.

Alternatives to the Proposed Action:

Since the Commission has concluded there is no measurable environmental impact associated with the proposed action, any alternatives with equal or greater environmental impact need not be evaluated. As an alternative to the proposed action, the staff considered denial of the proposed action. Denial

of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

Alternative Use of Resources:

This proposed exemption does not involve the use of any resources not previously considered in the Final Environmental Statement for the Limerick Generating Stations, Units 1 and 2, dated April 1984 as supplemented on August 1989.

Agencies and Persons Consulted:

In accordance with its stated policy, on September 26, 1995, the staff consulted with the Pennsylvania State official, David Ney of the Bureau of Radiation Protection, Department of Environmental Protection, regarding the environmental impact of the proposed action. The State official had no comments.

FINDING OF NO SIGNIFICANT IMPACT


Based upon the environmental assessment, the Commission concludes that the proposed exemption will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed exemption.

For further details with respect to the proposed action, see the licensee's letter dated June 20, 1995, which is available for public inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located

at the Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania
19464.

Dated at Rockville, Maryland, this 9th day of November 1995.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script that reads "John F. Stolz". The signature is written in black ink and is positioned above the typed name and title.

John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation