May 13, 1999

Mr. Garrett D. Edwards Director-Licensing, MC 62 PECO Energy Company **Nuclear Group Headquarters** Correspondence Control Desk P.O. Box No. 195 Wayne, PA 19087-0195

SUBJECT: LIMERICK GENERATING STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENT RE: DISCREPANCY RESOLUTION BETWEEN GENE SPECIFICATION FOR POWER SUPPLY MONITORING RELAYS AND EXISTING TECHNICAL SPECIFICATION ALLOWABLE VALUES (TAC NOS. M3991 AND MA3992)

Dear Mr. Edwards:

The Commission has issued the enclosed Amendment No. 134 to Facility Operating License No. NPF-39 and Amendment No. 96 to Facility Operating License No. NPF-85 for the Limerick Generating Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 30, 1998, as supplemented February 22, 1999.

These amendments revise the overvoltage, undervoltage, and underfrequency allowable values associated with the reactor protection system monitoring channels and add supporting details to the Technical Specification Bases 3/4.8.4.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

This completes our efforts on this issue, and we are, therefore, closing out TAC Nos. MA3991 and MA3992.

9905170269 990513 PDR ADOCK 05000352 PDR

Sincerely,

Original signed by: Bartholomew C. Buckley, Sr. Project Manager, Section 2 Project Directorate I **Division of Licensing Project Management** Office of Nuclear Reactor Regulation

RC FRE GENTER R

Docket Nos. 50-352 and 50-353

Enclosures: 1. Amendment No.134to License No. NPF-39

- 2. Amendment No. % to License No. NPF-85
- 3. Safety Evaluation



OFFICIAL RECORD COPY DOCUMENT NAME: LI3991.AMD

May 13, 1999

Mr. Garrett D. Edwards Director-Licensing, MC 6. 1 PECO Energy Company Nuclear Group Headquarters Correspondence Control Desk P.O. Box No. 195 Wayne, PA 19087-0195

SUBJECT: LIMERICK GENERATING STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENT RE: DISCREPANCY RESOLUTION BETWEEN GENE SPECIFICATION FOR POWER SUPPLY MONITORING RELAYS AND EXISTING TECHNICAL SPECIFICATION ALLOWABLE VALUES (TAC NOS. M3991 AND MA3992)

Dear Mr. Edwards:

The Commission has issued the enclosed Amendment No. 134 to Facility Operating License No. NPF-39 and Amendment No. % to Facility Operating License No. NPF-85 for the Limerick Generating Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 30, 1998, as supplemented February 22, 1999.

These amendments revise the overvoltage, undervoltage, and underfrequency allowable values associated with the reactor protection system monitoring channels and add supporting details to the Technical Specification Bases 3/4.8.4.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

This completes our efforts on this issue, and we are, therefore, closing out TAC Nos. MA3991 and MA3992.

Sincerely,

Original signed by: Bartholomew C. Buckley, Sr. Project Manager, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

cc w/encls: See next page

Enclosures: 1. Amendment No.134to License No. NPF-39

- 2. Amendment No. % to
- License No. NPF-85
- 3. Safety Evaluation

DISTRIBUT Docket File PUBLIC PDI-2 Read	ION: JClifford BBuckley ing OGC	d MO'Briel ey ACRS VRNorswo		n WBeckner ABlough, RGN-I orthy (E-Mail SE)	
OFFICE	PDI-2/PM BCB	PDI-2/LA		EELB	PDI-2/ŞC
NAME	BBuckley:rb	MO'Brien	RBachmann	SE dtd	JChifford
DATE	4 127/99	/ /99	4 1/ 199	03/15/99	5110199

OFFICIAL RECORD COPY DOCUMENT NAME: LI3991.AMD



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

May 13, 1999

Mr. Garrett D. Edwards Director-Licensing, MC 62A-1 PECO Energy Company Nuclear Group Headquarters Correspondence Control Desk P.O. Box No. 195 Wayne, PA 19087-0195

SUBJECT: LIMERICK GENERATING STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENT RE: DISCREPANCY RESOLUTION BETWEEN GENE SPECIFICATION FOR POWER SUPPLY MONITORING RELAYS AND EXISTING TECHNICAL SPECIFICATION ALLOWABLE VALUES (TAC NOS. M3991 AND MA3992)

Dear Mr. Edwards:

The Commission has issued the enclosed Amendment No. 134 to Facility Operating License No. NPF-39 and Amendment No. 96 to Facility Operating License No. NPF-85 for the Limerick Generating Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 30, 1998, as supplemented February 22, 1999.

These amendments revise the overvoltage, undervoltage, and underfrequency allowable values associated with the reactor protection system monitoring channels and add supporting details to the Technical Specification Bases 3/4.8.4.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

This completes our efforts on this issue, and we are, therefore, closing out TAC Nos. MA3991 and MA3992.

Sincerely,

Bartholower C. Buckley

Bartholomew C. Buckley, Sr. Project Manager, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

- Enclosures: 1. Amendment No.134to
 - License No. NPF-39
 - 2. Amendment No. % to License No. NPF-85
 - 3. Safety Evaluation

cc w/encls: See next page

Mr. Garrett D. Edwards PECO Energy Company Limerick Generating Station, Units 1 & 2

CC:

J. W. Durham, Sr., Esquire Sr. V.P. & General Counsel PECO Energy Company 2301 Market Street Philadelphia, PA 19101

Manager-Limerick Licensing, 62A-1 PECO Energy Company 965 Chesterbrook Boulevard Wayne, PA 19087-5691

Mr. James D. von Suskil, Vice President Limerick Generating Station Post Office Box A Sanatoga, PA 19464

Plant Manager Limerick Generating Station P.O. Box A Sanatoga, PA 19464

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Senior Resident Inspector U.S. Nuclear Regulatory Commission Limerick Generating Station P.O. Box 596 Pottstown, PA 19464

Director-Site Support Services Limerick Generating Station P.O. Box A Sanatoga, PA 19464

Chairman Board of Supervisors of Limerick Township 646 West Ridge Pike Linfield, PA 19468 Chief-Division of Nuclear Safety PA Dept. Of Environmental Resources P.O. Box 8469 Harrisburg, PA 17105-8469

Director-Site Engineering Limerick Generating Station P.O. Box A Sanatoga, PA 19464

Manager-Experience Assessment Limerick Generating Station P.O. Box A Sanatoga, PA 19464

Library U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Senior Manager-Operations Limerick Generating Station P.O. Box A Sanatoga, PA 19464

Dr. Judith Johnsrud National Energy Committee Sierra Club 433 Orlando Avenue State College, PA 16803



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

PECO ENERGY COMPANY

DOCKET NO. 50-352

LIMERICK GENERATING STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 134 License No. NPF-39

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by PECO Energy Company (the licensee) dated October 30, 1998, as supplemented February 22, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.



2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-39 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 134 , are hereby incorporated into this license. PECO Energy Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Kenerte Chilled

James W. Clifford, Chief, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 13, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 134

FACILITY OPERATING LICENSE NO. NPF-39

DOCKET NO. 50-352

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal **lines indicating the areas of change**.

Remove	Insert
3/4 8-28	3/4 8-28
B 3/4 8-3	B 3/4 8-3

REACTOR PROTECTION SYSTEM ELECTRICAL POWER MONITORING

LIMITING CONDITION FOR OPERATION

3.8.4.3 Two reactor protection system (RPS) electric power monitoring channels for each inservice RPS Inverter or alternate power supply shall be OPERABLE.

APPLICABILITY: At all times.

ACTION:

- a. With one RPS electric power monitoring channel for an inservice RPS Inverter or alternate power supply inoperable, restore the inoperable power monitoring channel to OPERABLE status within 72 hours or remove the associated RPS Inverter or alternate power supply from service.
- b. With both RPS electric power monitoring channels for an inservice RPS Inverter or alternate power supply inoperable, restore at least one electric power monitoring channel to OPERABLE status within 24 hours or remove the associated RPS Inverter or alternate power supply from service.

SURVEILLANCE REQUIREMENTS

4.8.4.3 The above specified RPS electric power monitoring channels shall be determined OPERABLE:

- a. By performance of a CHANNEL FUNCTIONAL TEST each time the plant is in COLD SHUTDOWN for a period of more than 24 hours, unless performed in the previous 6 months.
- b. At least once per 24 months by demonstrating the OPERABILITY of overvoltage, undervoltage, and underfrequency protective instrumentation by performance of a CHANNEL CALIBRATION including simulated automatic actuation of the protective relays, tripping logic, and output circuit breakers and verifying the following Allowable Values.
 - 1. Overvoltage \leq 127.6 VAC,
 - 2. Undervoltage \geq 110.7 VAC,
 - 3. Underfrequency \geq 57.05 Hz.

BASES

3/4.8.4 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES

Bypassing motor operated valves thermal overload protection ensures that the thermal overload protection will not prevent safety related valves from performing their function. For motor operated valves with spring return-to-center control switches, the thermal overload is bypassed by the automatic control signals associated with the Class 1E valves. For Class 1E motor operated valves with maintained contact control switches, the thermal overloads do not interrupt the valve motor power circuit, but they alarm on an overload condition in the control room. The Surveilance Requirements for demonstrating the bypassing of the thermal overload protection continuously are met by functionally testing the automatic operation of the motor operated valve and ensuring that the motor thermal overload protection design does not change and is in accordance with Regulatory Guide 1.106 "Thermal Overload Protection for Electric Motors on Motor Operated Valves", Revision 1, March 1977.

The RPS Electric Power Monitoring System is provided to isolate the RPS bus from the RPS/UPS inverter or an alternate power supply in the event of overvoltage, undervoltage, or underfrequency. This system protects the loads connected to the RPS bus from unacceptable voltage and frequency conditions. The essential equipment powered from the RPS buses includes the RPS logic, scram solenoids, and valve isolation logic.

The Allowable Values are derived from equipment design limits, corrected for calibration and instrument errors. The trip setpoints are then determined, accounting for the remaining instrument errors (e.g., drift). The trip setpoints derived in this manner provide adequate protection and include allowances for instrumentation uncertainties, calibration tolerances, and instrument drift.

The Allowable Values for the instrument settings are based on the RPS providing power within the design ratings of the associated RPS components (e.g., RPS logic, scram solenoids). The most limiting voltage requirement and associated line losses determine the settings of the electric power monitoring instrument channels.

LIMERICK - UNIT 1

Amendment No. 33, 93, Bases-Ltr 11/18/98, 134



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

PECO ENERGY COMPANY

DOCKET NO. 50-353

LIMERICK GENERATING STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 96 License No. NPF-85

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by PECO Energy Company (the licensee) dated October 30, 1998, as supplemented February 22, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-85 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 96, are hereby incorporated in the license. PECO Energy Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Vames W. Chilland

James W. Clifford, Chief, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 13, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 96

FACILITY OPERATING LICENSE NO. NPF-39

DOCKET NO. 50-352

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>

Insert

3/4 8-28 B 3/4 8-3 3/4 8-28 B 3/4 8-3

REACTOR PROTECTION SYSTEM ELECTRICAL POWER MONITORING

LIMITING CONDITION FOR OPERATION

3.8.4.3 Two reactor protection system (RPS) electric power monitoring channels for each inservice RPS Inverter or alternate power supply shall be OPERABLE.

APPLICABILITY: At all times.

ACTION:

- a. With one RPS electric power monitoring channel for an inservice RPS Inverter or alternate power supply inoperable, restore the inoperable power monitoring channel to OPERABLE status within 72 hours or remove the associated RPS Inverter or alternate power supply from service.
- b. With both RPS electric power monitoring channels for an inservice RPS Inverter or alternate power supply inoperable, restore at least one electric power monitoring channel to OPERABLE status within 24 hours or remove the associated RPS Inverter or alternate power supply from service.

SURVEILLANCE REQUIREMENTS

4.8.4.3 The above specified RPS electric power monitoring channels shall be determined OPERABLE:

- a. By performance of a CHANNEL FUNCTIONAL TEST each time the plant is in COLD SHUTDOWN for a period of more than 24 hours, unless performed in the previous 6 months.
- b. At least once per 24 months by demonstrating the OPERABILITY of overvoltage, undervoltage, and underfrequency protective instrumentation by performance of a CHANNEL CALIBRATION including simulated automatic actuation of the protective relays, tripping logic, and output circuit breakers and verifying the following Allowable Values.
 - 1. Overvoltage \leq 127.6 VAC,
 - 2. Undervoltage \geq 110.7 VAC,
 - 3. Underfrequency \geq 57.05 Hz.

BASES

3/4.8.4 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES

Bypassing motor operated valves thermal overload protection ensures that the thermal overload protection will not prevent safety related valves from performing their function. For motor operated valves with spring return-to-center control switches, the thermal overload is bypassed by the automatic control signals associated with the Class 1E valves. For Class 1E motor operated valves with maintained contact control switches, the thermal overloads do not interrupt the valve motor power circuit, but they alarm on an overload condition in the control room. The Surveillance Requirements for demonstrating the bypassing of the thermal overload protection continuously are met by functionally testing the automatic operation of the motor operated valve and ensuring that the motor thermal overload protection design does not change and is in accordance with Regulatory Guide 1.106 "Thermal Overload Protection for Electric Motors on Motor Operated Valves", Revision 1, March 1977.

The RPS Electric Power Monitoring System is provided to isolate the RPS bus from the RPS/UPS inverter or an alternate power supply in the event of overvoltage, undervoltage, or underfrequency. This system protects the loads connected to the RPS bus from unacceptable voltage and frequency conditions. The essential equipment powered from the RPS buses includes the RPS logic, scram solenoids, and valve isolation logic.

The Allowable Values are derived from equipment design limits, corrected for calibration and instrument errors. The trip setpoints are then determined, accounting for the remaining instrument errors (e.g., drift). The trip setpoints derived in this manner provide adequate protection and include allowances for instrumentation uncertainties, calibration tolerances, and instrument drift.

The Allowable Values for the instrument settings are based on the RPS providing power within the design ratings of the associated RPS components (e.g., RPS logic, scram solenoids). The most limiting voltage requirement and associated line losses determine the settings of the electric power monitoring instrument channels.



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 134 AND 96 TO FACILITY OPERATING

LICENSE NOS. NPF-39 AND NPF-85

PECO ENERGY COMPANY

LIMERICK GENERATING STATION, UNITS 1 AND 2

DOCKET NOS. 50-352 AND 50-353

1.0 INTRODUCTION

By letter dated October 30, 1998, as supplemented February 22, 1999, the PECO Energy Company (the licensee) submitted a request for changes to the Limerick Generating Station, Units 1 and 2, Technical Specifications (TSs). The requested changes would revise the overvoltage (OV), undervoltage (UV), and underfrequency (UF) allowable values associated with the reactor protection system monitoring channels and add supporting details to the Technical Specification Bases 3/4.8.4. The February 22, 1999, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

2.0 DISCUSSION

The Reactor Protection System (RPS) Monitoring System protects the loads connected to the RPS bus from unacceptable voltage and frequency conditions. The system isolates the RPS bus from the RPS/UPS (uninterrupted power supply) inverter or an alternate power supply in the event of overvoltage, undervoltage, or underfrequency. The RPS buses power the RPS logic, scram solenoids, and valve isolation logic. The TS Surveillance Requirements 4.8.4.3.b.1, 4.8.4.3.b.2, and 4.8.4.3.b.3 list the OV, UV, and UF allowable values for the protective instrumentation for the RPS electric monitoring channels. During a revision to a calculation for an RPS Breaker Panel - RPS/UPS system bus relay settings, the licensee discovered a discrepancy between existing TS 4.8.4.3 and General Electric (GE) Design Specification 22A3083AB. By letter dated October 30, 1998, as supplemented February 22, 1999, the licensee requested approval of the TS change to revise the allowable values listed in TS 4.8.4.3 and add supporting details in the TS Bases Section 3/4.8.4.

3.0 EVALUATION

The proposed change corrects a discrepancy between the GE Design Specification for power supply monitoring relays and the existing TS allowable values listed in TS 4.8.4.3. Currently, TS 4.8.4.3 identifies the required values for the RPS electric monitoring relays; OV, UV, and UF. The licensee's investigation into the licensing basis identified nominal values of +/- 10% of 120 Vac and -5% of 60 Hz for the allowable values. These values are included in NUREG-0123, from which the TSs for Limerick were developed.

9905170273 990513 PDR ADDCK 05000352 P PDR The existing TS values are as follows:

Overvoltage \leq 132Vac Undervoltage \geq 109Vac Underfrequency \geq 57Hz

The proposed TS values are as follows:

Overvoltage \leq 127.5Vac Undervoltage \geq 110.7Vac Underfrequency \geq 57.05Hz

The GE Design Specification 22A3083AB provides the criteria for setting the respective relays to ensure critical RPS components are not subjected to abnormal voltages and frequency. Part of this methodology is to include voltage drops between the relays and the components. This guidance was not previously included in the calculation of allowable values for OV and UV. When the voltage drops are added into the current TS allowable values for OV and UV relays, the resultant voltages were not adequate to protect the RPS electrical components. The allowable value is the maximum (or minimum) value at which the instrument may be set, which will assure its actuation prior to a parameter exceeding the design limit (DL). OV DL and UV DL are determined based on the requirements of GE Spec 22A3083, which include the voltage drops. OV DL and UV DL thus calculated are ≤ 128.5Vac for OV and ≥109.8Vac for UV. The new allowable values are determined by including relay accuracy (RA) and calibration accuracy (CA) in their calculations. CA refers to errors introduced by the inaccuracies of calibrating equipment and the allowances for error introduced by the calibration procedures. After subtracting CA and RA values (0.87V) from OV DL (128.5V), the allowable value for OV is ≤ 127.6Vac. Similarly, after adding CA and RA values (0.86V) to UV DL (109.8V), the allowable value for UV is ≥ 110.7Vac. DL for UF is 57 HZ (60 Hz - 5%). Similarly, after adding CA and RA values (0.05 Hz) to UF DL (57 HZ), the allowable value for UF is ≥ 57.05 HZ. The allowable value is listed in the TS. The proposed changes bring the TSs into agreement with plant design specifications and will ensure that adequate protection is provided for RPS components.

The proposed change also includes an addition to the TS Bases Section 3/4.8.4 providing details as to how the allowable values are derived and the basis for the instrument settings.

Summary

The staff concludes the following:

- 1. The proposed TS change provides more conservative allowable values for OV, UV, and UF.
- 2. The proposed change brings the TSs into agreement with GE Design Specifications and will assure that adequate protection continues to be provided for the RPS components.

Based on the NRC staff review of the licensee's submittals, the staff finds the proposed changes to the TS and the associated Bases acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Pennsylvania State official was notified of the proposed issuance of the amendments. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change the surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (63 FR 64120). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: N. Trehan B. Buckley

Date: May 13, 1999