

EXHIBIT 1

Case No. 2-1998-023

JT31

EXHIBIT 1

INVESTIGATION STATUS RECORD

| | | | |
|-----------------------|---|--------------|---|
| Facility: | WATTS BAR | Case Agent: | CLAXTON, GARY H |
| Case Number: | 2-1998-023 | Date Opened: | 11/04/1998 |
| Docket Number(s): | 05000390, 05000391 | ECD: | 11/1999 |
| | | Priority: | High |
| Case Type: | Reactor Power | Status: | Report (final) In OI:Region II for Review |
| Primary Alleg Source: | NRC Inspector / Technical Staff | | |
| Allegation Number(s): | NRR-1998-A-0011, RII-1998-A-0144 | | |
| Subject/Allegation: | ALLEGED FALSIFICATION OF TEST DATA REGARDING ICE CONDENSER SCREWS | | |

Monthly Status Report:

11/04/1998: Extensive inspection effort by regional inspectors has determined that the Tennessee Valley Authority (TVA) metallurgical reports regarding cracks in ice condenser screws may have been edited to prevent the NRC from learning of a widespread problem with the Westinghouse screws. Initial lab results indicated that overtorquing and installation problems resulted in cracking in some screws. However, screws from Watts Bar stores were also examined and determined to have cracks also. The testing of the stores (unused) screws was deleted in a second lab report sent to Westinghouse. Status: FWP ECD (90-day): 02/1999

| | | |
|------------------|-----------------------------|--------------------|
| Completion Date: | Total Staff Hours: | 1,199.0 |
| Issue Date: | Months Open: | 12.0 |
| DOJ Action(s): | OE Action: | |
| OI Violation(s): | False Statement - No Result | DOJ Referral Date: |

▶ 2-1998-023

EXHIBIT /
PAGE / OF / PAGE(S)