

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.4.1.3	Verify one door in each access to secondary containment is closed, except during normal entry and exit.	31 days
SR 3.6.4.1.4	Verify each standby gas treatment (SGT) subsystem will draw down the secondary containment to $\geq 0.25$ inch of vacuum water gauge within the required time.	18 months on a STAGGERED TEST BASIS
SR 3.6.4.1.5	Verify each SGT subsystem can maintain $\geq 0.25$ inch of vacuum water gauge in the secondary containment for 1 hour at a flow rate $\leq 4400$ cfm.	18 months on a STAGGERED TEST BASIS

This page intentionally left blank