

DISTRIBUTION:

AEC PDR

LOCAL PDR

DOCKET

RP READING

BWR-1 FILE

Attorney, OGC:

MHaflich

WMassar

RSBoyd

VAMoore

RO (3)

SHanauer

DSkovholt

PCollins

MMaigret

(w/extras)

Change No. 6

License No. DPR-28

WButler

JStolz

RClark

RIreland

WHaass

RVollmer

NDube

MJinks (w/4

encls.)

Gowsley

HMuedler

JRBuchanan

TWLaughlin

FKaras, SECY

APR 11 1973

Docket No. 50-277

Vermont Yankee Nuclear Power Corp.
ATTN: Mr. Albert A. Cree, President
77 Grove Street
Rutland, Vermont 05701

Gentlemen:

In your letter of April 3, 1973 (L. H. Heider to Directorate of Licensing), you state that you have completed the modification of the actuation logic for the Primary Containment Isolation System, which we approved in our letter dated March 6, 1973 (V. A. Moore to Albert Cree). In our letter of March 6, 1973, we stated that appropriate changes to the Technical Specifications will be made when you complete the modifications. These changes add a 40% steam flow trip to the containment isolation system in place of a high water level trip when the reactor is not in the run mode, as protection against reactor vessel blowdown from inadvertent opening of all bypass valves. This change in the trip actuation logic is designed to reduce the potential for unnecessary isolations of the primary system. As we concluded in our letter of March 6, 1973, the modifications you have made and the above cited changes to the Technical Specifications do "not present significant hazards considerations not described or implicit in the safety analysis report and that there is reasonable assurance that the health and safety of the public will not be endangered by the proposed change."

Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specifications of Facility Operating License DPR-28 for the Vermont Yankee Nuclear Power Station are changed by removing the pages numbered 41, 44, and 64, all dated 12/1/71, and replacing them with the enclosed revised pages 41, 44, and 64, all dated 4/11/73.

Sincerely,
Original signed by
Walter Butler

for

Voss A. Moore, Assistant Director
for Boiling Water Reactors
Directorate of Licensing

Enclosure:
Revised pages to
Technical Specifications

LB

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| cc: | L:BWR-1 | L:BWR-1 | L:AD:BWR |
| FILE next page | <i>[Signature]</i> | <i>[Signature]</i> | <i>[Signature]</i> |
| SURNAME | Gowsley:ld | WRButler | VAMoore |
| DATE | 4/10/73 | 4/10/73 | 4/10/73 |

APR 11 1973

cc:

Mr. D. E. Vandenburg, Vice President
Mr. Lawrence E. Minnick, Vice President
Vermont Yankee Nuclear Power Corp.
Turnpike Road, Route 9
Westboro, Massachusetts 01581

John A. Ritscher, Esq.
Ropes and Gray
225 Franklin Street
Boston, Massachusetts 02110

Gregor I. McGregor, Esq.
Assistant Attorney General
Department of the Attorney General
State House, Room 370
Boston, Massachusetts 02133

Honorable James M. Jeffords
Attorney General
State of Vermont
Montpelier, Vermont 05602

Anthony Z. Roisman, Esq.
Berlin, Roisman and Kessler
1712 N Street, N.W.
Washington, D.C. 20036

Jonathan N. Brownell, Esq.
Paterson, Gibson, Noble & Brownell
26 State Street
Montpelier, Vermont 05602

David Schoenbrod, Esq.
Richard E. Ayres, Esq.
National Resources Defense Council
15 West 44th Street
New York, New York 10036

Brooks Memorial Library
Ms. June Bryant
224 Main Street
Brattleboro, Vermont 05301

Peter S. Paine, Jr., Esq.
Cleary, Gottlieb, Steen & Hamilton
52 Wall Street
New York, New York 10005

J. Eric Anderson, Esq.
Fitts and Olson
16 High Street
Brattleboro, Vermont 05301

William H. Ward, Esq.
Assistant Attorney General
Office of the Attorney General
State Capitol Building
Topeka, Kansas 66612

Donald W. Stever, Jr., Esq.
Office of the Attorney General
State House Annex
Concord, New Hampshire 03301

John W. Stevens, Director
Conservation Society of Southern Vermont
P. O. Box 256
Townshend, Vermont 05353

Chairman, Vermont Public Service Corp.
Seven School Street
Montpelier, Vermont 05602

| | | | | | | |
|-----------|--|--|--|--|--|--|
| OFFICE ▶ | | | | | | |
| SURNAME ▶ | | | | | | |
| DATE ▶ | | | | | | |

VYNPS

TABLE 3.2.2.1

PRIMARY CONTAINMENT ISOLATION INSTRUMENTATION

| <u>Minimum Number of Operable Instrument Channels per Trip System</u> | <u>Trip Function</u> | <u>Trip Setting</u> | <u>Required Action When Minimum Condition for Operation are not Satisfied (Note 2)</u> |
|-----------------------------------------------------------------------|------------------------------------|-----------------------------------------------|----------------------------------------------------------------------------------------|
| 2 | Low-Low Reactor Vessel Water Level | $\geq 6' 10.5''$ above the top of active fuel | A |
| 2 of 4 in each of 2 channels | Steam Line Area High Temperature | $\leq 200^{\circ}\text{F}$ | B |
| 2/steamline | Steam Line High Flow | $\leq 120\%$ of rated flow | B |
| 2 (Note 1) | Main Steam Line Low Pressure | ≥ 850 psig | B |
| 2 (Note 6) | Steam Line High Flow | $\leq 40\%$ of rated power | B |
| 2 | Low Reactor Vessel Water Level | Same as Reactor Protection System | A |
| 2 | Main Steam Line High Radiation | ≤ 7 X background at rated power | B |
| 2 | High Drywell Pressure | Same as Reactor Protection System | A |
| 1 | Trip System Logic | | A |

VYNPS

TABLE 3.2.2 NOTES

1. The main steam line low pressure need be available only in the "Run" mode.
2. If the minimum number of operable instrument channels is not available for one trip system, that trip system shall be tripped. If the minimum number of operable instrument channels is not available for both trip systems, the appropriate actions listed below shall be taken:
 - A. Initiate an orderly shutdown and have reactor in the cold shutdown condition in 24 hours.
 - B. Initiate an orderly load reduction and have reactor in "Hot Standby" within 8 hours.
3. Close isolation valves in system and comply with Specification 3.5.
4. One trip system arranged in a two-out-of-two logic.
5. One trip system arranged in a one-out-of-two twice logic.
6. The main steam line high flow is available only in the "Refuel", "Shutdown", and "Startup" modes.

3.2 Bases, continued

Pressure instrumentation is provided which trips when reactor pressure drops below 850 psig. A trip of this instrumentation results in closure of Group 1 isolation valves. In the refuel, shutdown, and startup modes, this trip function is provided when main steam line flow exceeds 40% of rated capacity. This function is provided primarily to provide protection against a pressure regulator malfunction which would cause the control and/or bypass valves to open. With the trip set at 850 psig, inventory loss is limited so that fuel is not uncovered and peak clad temperatures are much less than 1295°F; thus, there is no release of fission products other than those in the reactor water.

The HPCI and/or RCIC high flow, steam supply pressure, and temperature instrumentation is provided to detect a break in the HPCI and/or RCIC piping. Tripping of this instrumentation results in actuation of HPCI and/or RCIC isolation valves; i.e., Group 4 and/or Group 5 valves. The trip settings are such that core uncovering is prevented and fission product release is within limits.

The instrumentation which initiates CSCS action is arranged in a dual channel system. As for other vital instrumentation arranged in this fashion, the specification preserves the effectiveness of the system even during periods when maintenance or testing is being performed. Permanently installed circuits and equipment may be used to trip instrument channels. In the non-fail safe systems which require energizing the circuitry, tripping an instrument channel may take the form of providing the required relay function by use of permanently installed circuits. This is accomplished in some cases by closing logic circuits with the aid of the permanently installed test jacks or other circuitry which would be installed for this purpose.

The control rod block functions are provided to prevent excessive control rod withdrawal so that MCHFR does not decrease to 1.0. The trip logic for this function is 1 out of n; e.g., any trip on one of the six APRM's, six IRM's or four SRM's will result in a rod block. The minimum instrument channel requirements for the IRM may be reduced by one for a short period of time to allow for maintenance, testing or calibration. The RBM is an operational guide and aid only and is not needed for rod withdrawal.

The APRM rod block trip is flow referenced and prevents a significant reduction in MCHFR especially during operation at reduced flow. The APRM provides gross core protection; i.e., limits the gross core power increase from withdrawal of control rods in the normal withdrawal sequence. The trips are set so that MCHFR is maintained greater than 1.0.

The IRM rod block function provides local as well as gross core protection. The scaling arrangement is such that trip setting is less than a factor of 10 above the indicated level. Analysis of the worst case accident results in rod block action before MCHFR approaches 1.0.

A downscale indication on an APRM or IRM is an indication the instrument has failed or the instrument is not sensitive enough. In either case the instrument will not respond to changes in control rod motion and thus control rod motion is prevented.