Simulator Scenario Quality Assurance Checklist Form ES-301-4

à a

Facility:	Braidwood Unit 1 & 2 Date of Exam: 10/23/00 Scenario Numbers: 00	0-1/ 00-2/ 00-5 Ope	erating	Test	No.:1	
	QUALITATIVE ATTRIBUTES			Initial	s	
			a	b	с	
1.	The initial conditions are realistic, in that some equipment and/or instrume of service, but it does not cue the operators into expected events.	entation may be out	1	jes	1173	
2.	The scenarios consist mostly of related events.		51	rs	MES	
3.	Each event description consists of					
	 the point in the scenario when it is to be initiated the malfunction(s) that are entered to initiate the event the symptoms/cues that will be visible to the crew the expected operator actions (by shift position) the event termination point (if applicable) 		F	YS	MER	
4.	No more than one non-mechanistic failure (e.g., pipe break) is incorporate without a credible preceding incident such as a seismic event.	d into the scenario	5	ys.	Mag	
5.	The events are valid with regard to physics and thermodynamics.			XLS	Mag	
6.	Sequencing and timing of events is reasonable, and allows the examination team to obtain complete evaluation results commensurate with the scenario objectives.					
7.	7. If time compression techniques are used, the scenario summary clearly so indicates. Operators have sufficient time to carry out expected activities without undue time constraints. Cues are given.					
8.	The simulator modeling is not altered.		1	the	Mas	
9.	The scenarios have been validated.		K	xx	MEA	
10.	10. Every operator will be evaluated using at least one new scenario. All other scenarios have been modified in accordance with Section D.4 of ES-301.					
11.	1. All individual operator competencies can be evaluated, as verified using Form ES-301-6 (submit the form along with the simulator scenarios). /					
12.	12. Each applicant will be significantly involved in the minimum number of transients and events specified on Form ES-301-5 (submit the form along with the simulator scenarios).					
13.	3. The level of difficulty is appropriate to support licensing decisions for each crew position.					
	TARGET QUANTITATIVE ATTRIBUTES (PER SCENARIO)	Actual Attributes				
1.	Total malfunctions (5-8)	5 / 7 / 8	4	tis	MGB	
2.	Malfunctions after EOP entry (1-2)	2/2/2	4	101	MAB	
3.	Abnormal events (2-4)	3 / 5 / 4	1	ks	MAG	
4.	Major transients (1-2)	2 / 1 / 2	31	Jes	MGh	
5.	EOPs entered/requiring substantive actions (1-2)	2/3/1		Jes	MER	
6.	EOP contingencies requiring substantive actions (0-2)	2/0/0	2	1	MER	
7.	Critical tasks (2-3)	3 / 2 / 2	1	rex.	MA	
			7(n 1	

ES-301

3

۰,

Simulator Scenario Quality Assurance Checklist Form ES-301-4

Scenario Numbers: 00-4/ 00-3/ 00-6 Operating Test No. 2 Facility: Braidwood Unit 1 & 2 Date of Exam: 10/23/00 QUALITATIVE ATTRIBUTES Initials а b с The initial conditions are realistic, in that some equipment and/or instrumentation may be out 1. of service, but it does not cue the operators into expected events. The scenarios consist mostly of related events. 2. Each event description consists of 3. the point in the scenario when it is to be initiated the malfunction(s) that are entered to initiate the event the symptoms/cues that will be visible to the crew the expected operator actions (by shift position) the event termination point (if applicable) No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario 4. without a credible preceding incident such as a seismic event. The events are valid with regard to physics and thermodynamics. 5. Sequencing and timing of events is reasonable, and allows the examination team to obtain 6. complete evaluation results commensurate with the scenario objectives. If time compression techniques are used, the scenario summary clearly so indicates. 7. Operators have sufficient time to carry out expected activities without undue time constraints. Cues are given. 8. The simulator modeling is not altered. 9. The scenarios have been validated. Every operator will be evaluated using at least one new scenario. All other scenarios have 10. been modified in accordance with Section D.4 of ES-301. All individual operator competencies can be evaluated, as verified using Form ES-301-6 11. (submit the form along with the simulator scenarios). 12. Each applicant will be significantly involved in the minimum number of transients and events specified on Form ES-301-5 (submit the form along with the simulator scenarios). 13. The level of difficulty is appropriate to support licensing decisions for each crew position. TARGET QUANTITATIVE ATTRIBUTES (PER SCENARIO) **Actual Attributes** 6/6/8 **Total malfunctions (5-8)** 1. 1/2/3 2. Malfunctions after EOP entry (1-2) 4/3/4 з. Abnormal events (2-4) 2/2/2 4. Major transients (1-2) 1/2/3 5. EOPs entered/requiring substantive actions (1-2) 0/2/0 6. EOP contingencies requiring substantive actions (0-2) 4/2/2 7. Critical tasks (2-3)

ES-301

ES-301

Transient and Event Checklist

Applicant	Evolution	Minimum	1	Scenario	Number	
Type	Туре	Number	00-4	00-3	00-6	Spare
			1	2	3	4
	Reactivity	1	1/	1,4/	1/	1/
•	Normal	1	/1	/1	/1	/1
RQ	Instrument	2	3/4	3/2	3/4	2/3
	Component	2	2/5	6/6	2,5,9/8	4,7/8
	Major	1	6,7/6,7	5,6/5,6	6,7/6,7	5,6 / 5,6
						-
	Reactivity	1	1	1,4	1	1
	Normal	0				
As RO	Instrument	1	3	3	3	2
	Component	1	2	6	2,5,9	4,7
	Major	1	6,7	5,6	6,7	5,6
SRO-I						
	Reactivity	0				
	Normal	-1	1	1	1	1
As SRO	Instrument	1	3,4	2,3	3,4	2,3
	Component .	1.	2,5	5	2,5,8,9	4,7,8
	Major	1	6,7	5,6	6,7	5,6
	Reactivity	0	N/A	N/A	N/A	N/A
	Normal	1	N/A	N/A	N/A	N/A
SRO-U	Instrument	1	N/A	N/A	N/A	N/A
	Component	1	N/A	N/A	N/A	N/A
	Maior	1	N/A	N/A	N/A	N/A

OPERATING TEST NO.: 2

Instructions:

(1)

Enter the operating test number and Form ES-D-1 event numbers for each evolution type.

(2) Reactivity manipulations must be significant as defined in Appendix D.

NOTE: Scenario Number 4 is a "spare" scenario and is represented for comparison purposes only in Examination Outline submittal.

The "/" in the cells for the "RO" applicant type represents the position the applicant is expected to fill during the scenario. The events are listed for the identified position: RO / BOP.

Author: Chief Examiner:

NUREG-1021, Revision 8

Operating	Test:	2
-----------	-------	---

		Applicant #1 RO / SRO-I/ SRO-U				Applicant #2 RO/SRO-I/SRO-U				Applicant #3 RO(BOP)/ SRO-I/SRO-U			
Competencies		SCENARIO			SCENARIO				SCENARIO				
	04	03	06	S	04	03	06	S	04	03	06	S	
Understand and Interpret Annunciators and Alarms	2-7	2-6	2-9	2-8	2,3,6 ,7	3-6	2,3,5 ,6,7, 9	2,4,5 ,6,7	4-7	2,5,6	4,6,7 ,8	3,5,6 ,8	
Diagnose Events and Conditions	2-7	2-6	2-9	2-8	2,3,6 ,7	3-6	2,3,5 ,6,7, 9	2,4,5 ,6,7	4-7	2,5,6	4,6,7 ,8	3,5,6 ,8	
Understand Plant and System Response	1-7	1-6	1-9	1-8	1,2,3 ,6,7	1,3-6	1,2,3 ,5,6, 7,9	1,2,4 ,5,6, 7	1,4-7	1,2,5 ,6	1,4,6 ,7,8 -	1, 3,5,6 ,8	
Comply With and Use Procedures (1)	1-7	1-6	1-9	1-8	1,2,3 ,6,7	1,3-6	1,2,3 ,5,6, 7,9	1,2,4 ,5,6, 7	1,4-7	1,2,5 ,6	1,4,6 ,7,8	1, 3,5,6 ,8	
Operate Control Boards (2)	1-7	1-6	1-9	1-8	1,2,3 ,6,7	1,3-6	1,2,3 ,5,6, 7,9	1,2,4 ,5,6, 7	1,4-7	1,2,5 ,6	_1,4,6 ,7,8	1, 3,5,6 ,8	
Communicate and Interact With the Crew	1-7	1-6	1-9	1-8	1-7	1-6	1-9	1-8	1-7	1-6	1-9	1-8	
Demonstrate Supervisory Ability (3)	1-7	1-6	1-9	1-8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Comply With and Use Tech. Specs. (3)	1,4,5	3	3	2,4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Notes:					• .								
(1) Includes Technical Specification compliance for an RO.													

(2) Optional for an SRO-U.

(3) Only applicable to SROs.

Instructions:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

NOTE: **OPERATING TEST NO.: 2.** Scenario Number 4 is a "spare" scenario and is represented for comparison purposes only in Examination Outline submittal. The order of listing for candidates is SRO, RO and BOP by position.

Author: Chief Examiner:

ES-301

Applicant	Evolution	Minimum		Scenario	Number	
Туре	Туре	Number	00-1	00-2	00-5	Spare
			1	2	3	4
	Reactivity	1	1/	1/	1,3/	1/
	Normal	1	/1	/1	/1,3	/1
RO	Instrument	2	3/ 2	2/3	5/4	2/3
	Component	2	4/4	4,6,8/ 4,5	2,6/6	4,7/8
	Major	1	5,6 / 5,6	717	7,8/7,8	5,6 / 5,6
	Reactivity	1	1	1 ·	1,3	1
	Normal	0				
As RO	Instrument	1	3	2	5	2
	Component	1	4	4,6,8	2,6	4,7
	Major	1	5,6	7	7,8	5,6
SRO-I						
	Reactivity	0				
	Normal	1	1	1	1,3	1
As SRO	Instrument	1.	2,3 ,	2,3	4,5	2,3
	Component	1	4	4,5,6,8	2,6	4,7,8
	Major	1	5,6	7	7,8	5,6
	Reactivity	0	N/A	N/A	N/A	N/A
	Normal	1	N/A	N/A	N/A	N/A
SRO-U	Instrument	1	N/A	N/A	N/A	N/A
	Component	1	N/A	N/A	N/A	N/A
	Major	1	N/A	N/A	N/A	N/A

OPERATING TEST NO.: 1

Instructions:

(1)

Enter the operating test number and Form ES-D-1 event numbers for each evolution type.

(2) Reactivity manipulations must be significant as defined in Appendix D.

NOTE: Scenario Number 4 is a "spare" scenario and is represented for comparison purposes only in Examination Outline submittal.

The "/" in the cells for the "RO" applicant type represents the position the applicant is expected to fill during the scenario. The events are listed for the identified position: RO / BOP.

Author: Chief Examiner:

NUREG-1021, Revision 8

	R	Applicant #1 RO / SRO-I/ SRO-U				Applicant #2 RO/ SRO-I/SRO-U				Applicant #3 RO(BOP)/SRO-I/SRO-U			
Competencies		SCEN	IARIO			SCENARIO				SCENARIO			
	01	02	05	S	01	02	05	S	01	02	05	S	
Understand and Interpret Annunciators and Alarms	2-6	2-8	2-8	2-8	3-6	2,4,6 ,7,8	2,5,6 ,7,8	2,4,5 ,6,7	2,4,5 ,6	3,4,5 ,7,8	3,4,6 ,7,8	3,5,6 ,8	
Diagnose Events and Conditions	2-6	2-8	2-8	2-8	3-6	2,4,6 ,7,8	2,5,6 ,7,8	2,4,5 ,6,7	2,4,5 ,6	3,4,5 ,7,8	3,4,6 ,7,8	3,5,6 ,8	
Understand Plant and System Response	1-6	1-8	1-8	1-8	1,3-6	1,2,4 ,6,7, 8	1,2,3 ,5,6, 7,8	1,2,4 ,5,6, 7	1,2,4 ,5,6	1,3,4 ,5,7, 8	1,3,4 ,6-8	1, 3,5,6 ,8	
Comply With and Use Procedures (1)	1-6	1-8	1-8	1-8	1,3-6	1,2,4 ,6,7, 8	1,2,3 ,5,6, 7,8	1,2,4 ,5,6, 7	1,2,4 ,5,6	1,3,4 ,5,7, 8	1,3,4 ,6-8	1, 3,5,6 ,8	
Operate Control Boards (2)	1-6	1-8	1-8	1-8	1,3-6	1,2,4 ,6,7, 8	1,2,3 ,5,6, 7,8	1,2,4 ,5,6, 7	1,2,4 ,5,6	1,3,4 ,5,7, 8	1,3,4 ,6-8	1, 3,5,6 ,8	
Communicate and Interact With the Crew	1-6	1-8	1-8	1-8	1-6	1-8	1-8	1-8	1-6	1-8	1-8	1-8	
Demonstrate Supervisory Ability (3)	1-6	1-8	1-8	1-8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Comply With and Use Tech. Specs. (3)	2,3	4	4,5	2,4	-N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Notes:													
(1) Includes Technical Specification compliance for an RO.(2) Optional for an SRO-U.													

Operating Test: 1

(3) Only applicable to SROs.

Instructions:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

NOTE: **OPERATING TEST NO.: 1.** Scenario Number 4 is a "spare" scenario and is represented for comparison purposes only in Examination Outline submittal. The order of listing for candidates is SRO, RO and BOP by position.

Author: Chief Examiner:

Simulation	Facility <u>Braidwood</u>		Scenario <u>00-3</u> Operating Test No.: 2				
Examiners	•		Applicant: <u>SRO</u>				
	······		<u>RO</u>				
			ВОР				
Objectives:To evaluate the applicants ability to use Normal, Abnormal, Emergency and alarm response procedures to respond to a PT-508 high failure, a Power Range NI failure, an inadvertent dilution, a reactor trip due to a failed open RTB, and a Loss of All AC.Initial Conditions:IC-21; 100% power BOL, Equilibrium Xenon							
Turnover	Unit 1 is at 100%	6 power. Ur	nit 2 is in MODE 5. The 1A DG is OOS to replace a leaking fuel				
•	injection line on	the 2R cylin	nder. The 1A DG is expected back in 3 to 4 hours. Currently in				
	LCO 3.8.1 Cond	ition B with	1 12 hours into 72 hour LCO.				
Event	Malf. No.	Event	Event				
No.		Type*	Description				
Preload	MRF EG03 MAINT_0		Place the 1A DG & output breaker in PTL and tag OOS				
<u> </u>	NRE DUU (0.000		Prevents ESF Bus 142 cross tie to U-2				
Preload	MRF FW160 STOP	C BOP	Prevent the IB AFW pump from starting				
		RU SPO	(NOTE 3)				
Preload	CAELIBDGAUTO	C BOP	Failure of the 1B DG to Auto Start				
Ticidad	Link MRF EG09	SRO	Tailule of the TD DO to Auto Start				
	REMOTE to TRG 6						
1		N BOP	Ramp the unit down in power to 900 MW at 5Mw/min				
		SRO					
		R RO					
2	FW16, 1500	I BOP	PT-508 (Feedwater Header Pressure Transmitter) fails high				
2	NILORA 500	I PO	NII 41 Derver Benge Unner Detector Failure High				
5	N100A, 500		(NOTE 1)				
4	MRF CV13 100	R RO	Inadvertent Dilution Event				
		SRO					
5	MRF RP01 TRIP	M BOP	Reactor Trip				
		· RO	(NOTE 2)				
		SRO	· · ·				
6	ED04A	M BOP	Loss of All AC				
	EG09B	RO	DG 1B Seizure (insert after crew manually starts)				
		SKO					
			·				

*(N)ormal, (R)eactivity (I)nstrument, (C)omponent, (M)ajor Transient

NOTE 1:

- .

RP20 (Open/Close) RX013 (Trip) RX135 (Trip) If the crew trips the reactor due to the inadvertent dilution, this event does not need to be initiated. **NOTE 2:**

When directed as local operator to attempt to start the 1B AFW pump MRF FW160 START **NOTE 3:** ·

SCENARIO 00-3 OVERVIEW

Unit 1 is at 100% power, BOL. Unit 2 is in MODE 5. The 1A Diesel Generator is OOS to replace a leaking fuel injection line on the 2R cylinder. Currently in LCO 3.8.1 Condition B with 12 hours into 72 hour LCO.

After the crew takes the shift, the crew will reduce power to 900 MW at 5Mw/min.

Following clearly observable plant response from the reactivity changes, feedwater header pressure instrument, PT-508 will fail high. The operator is expected to recognize this condition, take manual control of the Master FW Pumps Speed Controller and restore FW discharge pressure to within its normal band.

After the actions for the failed PT-508 instrument are complete, N-41 Power Range Upper Detector will fail high. The crew will enter BwOA INST-1 Attachment A and take actions to stabilize the plant. After the crew has defeated the failed N-41, the crew will place rods back into Auto and trip bistables associated with the failed Power Range NI. Tech Specs will be referenced.

After the actions of BwOA INST-1 are complete, an inadvertent dilution will occur. The crew should enter BwOA PRI-12 to attempt to determine and correct the cause of the inadvertent dilution. The crew may enter BwOA PRI-2 to commence emergency boration. The crew may trip the reactor due to the inadvertent dilution. If the crew does not trip the reactor, an inadvertent reactor trip will occur due to the opening of the 1A reactor trip breaker.

Once the immediate actions of BwEP E-0 are complete a Loss of All AC will occur. The 1B DG will not auto-start. When the crew attempts to manually start the 1B DG, it will seize and trip. Re-powering the ESF Buses from U-2 will also be unsuccessful. The crew will transition from E-0 to BwCA-0.0 and then transition to BWCA-0.2. While in ECA-0.0 the 1A DG will become available to restore power to Bus 141.

NOTE: The crew may transition to BwCA-0.1 if SI is not required.

During the crews actions in BwCA-0.0 the crew will recognize the failure of the 1B AFW pump to auto start. The crew will have to manually start (locally) the 1B AFW pump to restore AFW to the steam generators.

Critical Tasks

1. ECA-0.0--B: Establish the minimum required AFW flow rate (500 gpm) to the SGs before dryout occurs.

2. ECA-0.0--H: Isolate RCP seal injection before a charging pump starts or is started.

·· ·			
Scenario No: 00-3	Event No. 1		
Event Description:	Perform Load Decrease to 900 MW at 5MW/min		
Time Position Applicant's Actions or Behavior			
US	Implement actions of 1BwGP 100-4, "Power Descension"		
US	Direct load reduction		
CREW	Review applicable Precautions, and Limitations and Actions.		
RO	Verify rod position and boron concentration.		
	 Initiate boration, if required to maintain △I within target band. (BwOP CV-6) Determine boric acid flow rate Set 1FK-110 BA Flow Cont to desired boration rate. Set 1FY-0110 BA Blender Preset Counter to desired volume. Place MU MODE CONT SWITCH to STOP position. Set MU MODE SELECT to BOR position. Place MAKE-UP CONTROL Switch to START Verify proper operation of valves & BA transfer pump (CV110B open, BA pump is running, CV110A throttles open) Verify BA flow on recorder 		
BOP	 Initiate turbine load reduction: Depress LOAD RATE MW/MIN Enter 5 MW/min Depress REF Enter power level When ready to begin load reduction, depress GO Verify load decreases. 		

÷

.

Scenario	No: 00-3	Event No. 1
Event De	scription:	Perform Load Decrease to 900 MW at 5MW/min
Time	Position	Applicant's Actions or Behavior
	RO	 Monitor power decrease: Monitor reactor power, Tave, ΔI Verify rods more in AUTO to maintain Tave within ± 1.0°F of Tref. If borating: Monitor VCT level Monitor BA Blender counter countdown. Verify boration auto stops at preset value. Return Reactor Makeup System to blended flow at current blended flow.
		Note: Following clearly observable plant response from the reactivity changes, Event 2 is entered.

4

Scenario I	No: 00-3	Event No. 2
Event Des	scription:	PT-508 (Feedwater Header Pressure Transmitter) fails high
Time	Position	Applicant's Actions or Behavior
	CUE	MFP decrease in speed
		Decreasing SG water level
		Low SG Level alarms
		FW-SF mismatch alarms
	BOP	Diagnose failure of PT-508 failure high
	US	Direct actions to stabilize plant
	BOP	Take manual control of the Master FW Pumps Speed Controller
		Restore FW discharge pressure to normal band
		Restore SGWL to normal operating band
	US	Notify SM/ Maintenance of failure
		NOTE: Call as Electric Generation and request the ramp secured. Ensure that the ramp is secured prior to initiating next event.
		NOTE: After the actions for the failure of PT-508 have been completed, Event 3 may be started.
		· .

2

.

	•	
Scenario	No: 00-3	Event No. 3
Event D	escription:	N-41 Power Range Upper Detector Failure High
Time	Position	Applicant's Actions or Behavior
	CUE:	Annunciators: 1-10-A3 "PWR RNG HIGH STPT RX TRIP ALERT" 1-10-A4 "PWR RNG UPPER DET FLUX DEV HIGH" 1-10-B5 "PWR RNG FLUX HIGH ROD STOP" 1-10-C3 "PWR RNG FLUX RATE RX TRIP ALERT 1-10-C4 "PWR RNG CHANNEL DEV"
	RO	Identify/report failed N-41
	US	Transition to 1BwOA INST-1 "Nuclear Instrumentation Malfunction" Attachment A "PR Channel Failure" Direct actions of 1BwOA INST-1
	RO	 Check Rod Control Status Place the ROD BANK SELECT switch in MANUAL Check for Rod Stop PWR RNG FLUX HIGH ROD STOP – NOT LIT (It is lit) Place the ROD STOP BYPASS switch for the affected channel on the 1PM07J in BYPASS. Check Tave-Tref Deviation Restore Tave-Tref to within 1°F by using Control Rods Turbine Load RCS boron concentration
	BOP	Check SG Levels – Normal and Stable
	RO/BOP	 Bypass/Defeat PR Channel Functions at 1PM07J Select affected channel for following functions on 1PM07J Detector Current Comparator Upper Section Lower Section Miscellaneous Control and Indication section Power Mismatch Bypass Rod Stop Bypass Comparator and Rate panel Comparator Channel Defeat

3

•

Scenario	-No: 00-3	Event No. 3
Event De	escription:	N-41 Power Range Upper Detector Failure High
Time	Position	Applicant's Actions or Behavior
	US	Remove Control Power Fuses on 1PM07J for affected channel to trip bistables:
		Lo DY Trip NC41D
		Hi RY Trin NC41R
		Positive/Negative Rate Trip NC41U/K
		Locally trip Bistables for Affected Channel by Placing Indicated switches to TEST
		• OTAT Runback TB411D
	RO	Select Operable Channel – Loop ΔT recorder
		Check if Rod Control System can be Placed in Automatic
		 TORBINE LOW FOWER INTER C5 - Not Elit Tave-Tref deviation - Stable and within 1°F
		Place ROD BANK SELECT switch in – AUTO
	US	Reference Tech Specs
		3.3.1
		3.2.4
		NOTE: Initiate Event 4 after the Unit Supervisor has completed Tech. Spec. review.
		· · · · · · · · · · · · · · · · · · ·

Comments: _____

.

î

٠

١

Scenario	No: 00-3	Event No. 4
Event De	scription:	Inadvertent Dilution Event
Time	Position	Applicant's Actions or Behavior
	CUE:	RCS Temperature increase Power increase VCT Divert Valve to HUT Emergency Boration flow >100 gpm VCT Level increase
	RO/US	Determine inadvertent dilution is occurring
		NOTE: The crew may trip the reactor if they can not determine/control the inadvertent dilution.
	US	Transition to 1BwOA PRI-12 "Uncontrolled Dilution" Direct actions of 1BwOA PRI-12
	RO	Check all dilution paths isolated Place Makeup Control switch in OFF Check valves closed
	US	 Dispatch operator to verify dilution paths isolated 1CV8441 Locked Closed- Report valve is found open. When directed to close MRF CV13, 0. 1CV8435 Locked Closed 1CV8453 Locked Closed 1AB8629A Closed

.

÷

.

8

•

Scenario No: 0	0-3	Event No. 4			
Event Description:		Inadvertent Dilution Event			
Time Position		Applicant's Actions or Behavior			
RO		Check Letdown Temperature greater than 80°F			
		 Check Seal Water HX Tubes Intact VCT level – no unexpected increase CC Surge Tank Level – no unexpected decrease Check status of CV Demins Check CV Demin recently placed in service (Has not recently been placed in service) Check if dilution has been terminated Check Unit in MODE 1 or 2 			
		- Check dilution terminated (Local operator reports 1CV8441 was found open)			
- Check officient in MODE 1 of 2 - Check dilution terminated (Local operator reports 1CV8441 was found open) RO Check CV Pump Suction Aligned to the VCT • BDPS ACTUATED CHG SUCT SWITCH OVER – Not Lit • RWST to CENT CHG pumps isolation valves Closed - 1CV112D • 1CV112E Verify Reactor Makeup Control System Aligned for Auto Operation • Boric acid flow controller set for current RCS boron concentration • MODE SELECT switch in AUTO • Control Valve switches in AUTO • 1CV110A • 1CV111B • Makeup Control switch in START Check Shutdown Margin adequate		Check CV Pump Suction Aligned to the VCT BDPS ACTUATED CHG SUCT SWITCH OVER – Not Lit RWST to CENT CHG pumps isolation valves Closed 1CV112D 1CV112E Verify Reactor Makeup Control System Aligned for Auto Operation Boric acid flow controller set for current RCS boron concentration Boric acid flow controller in Auto MODE SELECT switch in AUTO Control Valve switches in AUTO 1CV110A 1CV110B 1CV111B Makeup Control switch in START Check Shutdown Margin adequate			

Comments: _____

,

. •

÷

,

Scenario	No: 00-3	Event No. 4
Event De	scription:	Inadvertent Dilution Event
Time	Position	Applicant's Actions or Behavior
	US	Refer to Tech Specs • 3.1.1 • 3.1.6 • 3.9.1 • 3.9.2 • TRM 3.1.i
		NOTE: If the crew does not trip the reactor during the dilution event, initiate the reactor trip after the crew references Tech Specs.

Comments: _____

Scenario	No: 00-3	Event No. 5		
Event Description:		Reactor Trip		
Time	Position	Applicant's Actions or Behavior		
	CUE	RX Trip breakers open		
		Turbine Trip		
		Numerous alarms		
		All Rod Bottom Lights Lit		
	US	Implement 1BwEP-0 "Reactor Trip or Safety Injection"		
		Direct actions of 1BwEP-0		
	RO	Perform immediate operator actions of 1BwEP-0		
		Verify reactor trip		
		Rod bottom lights LIT		
		• Reactor trip & bypass breakers open		
		• Neutron flux decreasing		
	BOP	Verify Turbine Trip		
		• Turbine throttle values closed		
		Turbine governor valves closed		
		Verify power to 4KV busses		
		Bus 141 alive light lit		
		 Bus 142 alive light lit 		
		~		
	CREW	Determine SI needed/actuated		
		• If needed		
		• Pzr pressure <1829 psig		
		• Steamline pressure <640 psig		
		• Cnmt pressure >3.4 psig		
		• Pzr level can not be maintained >4%		
		NOTE: Initiate Loss of All AC Event as the crew transitions to 1BwEP ES-0.1		

.

.

š				
Scenario 1	No: 00-3	Event No. 6		
Event Des	scription:	Loss of All AC Power		
Time	Position	Applicant's Actions or Behavior		
	CUE	No Bus energized lights lit Bus 141 & 142 de-energize		
	US	Transition to 1BwCA-0.0 "Loss of All AC Power" Direct actions of 1BwCA-0.0		
	RO	 Verify Reactor Trip Reactor trip and bypass breakers open Neutron flux decreasing 		
	BOP	 Isolate Steamlines Actuate Main Steamline Isolation Verify all MSIVs and MSIV bypass valves are Closed 		
	CREW	Actuate SI		
	ВОР [CT] ЕСА- 0.0В	 Verify AF Flow Total AF flow greater than 500 GPM (determine that no AF pumps are running) Dispatch local operator to attempt to start the 1A/1B AF Pump MRF FW160 START		

.

Scenario No: 00-3 Event No. 6		Event No. 6				
Event Description:		Loss of All AC Power				
Time	Position	Applicant's Actions or Behavior				
	RO	Verify RCS Isolated				
		PZR PORVs closed				
		- 1RY455A				
		- 1RY456				
ľ		Letdown orifice isolation valves closed				
		- 1CV8149A				
		- 1CV8149B				
		- 1CV8149C				
		• Letdown line isolation valves alosed				
		- 1CV459				
		- 1CV460				
		Excess letdown isolation valves closed				
		- 1CV8153A				
		- 1CV8153B				
	DOD	The Association Descent Associated at 14237 DOD Durane				
	BOb	Try to restore Power to Any/Both Unit 1 4K v ESF Buses				
		Check Dos bour furning Reset SI				
		- Manually start any non-running DG (none will start)				
		Multiduity built any non running D C (none with surry				
		Prepare for ESF Bus Crosstie				
		• Dispatch local operator to depress emergency stop pushbutton on both DGs MRF EG20 TRIP Do not do this to the 1A DG.				
		Reset CNMT Isolation Phase A				
		Reset SI if necessary				
	US	Check Status of Unit 2 ESF Buses				
	~~	• Any Unit 2 4KV ESF Bus energized				
		• Notify Unit 2 to enter 2BwCA-0.3 Inform crew that Bkr 2414 will not stay closed.				
		Both Unit 2 4KV ESF busses energized				
	CREW	Crosstie Bus 141 to Unit 2				

Comments: _____

.

4

.

Scenario	No: 00-3	Event No. 6		
Event Description:		Loss of All AC Power		
Time	Position	Applicant's Actions or Behavior		
	ВОР	Crosstie Bus 142 to Unit 2 Notify Unit 2 that Bus 142 will be used for crosstie Check Bus 142 not faulted Place breakers in Pull Out ACB 1421 ACB 1422 ACB 1424 Verify following Train B loads available Bus 132X CENT CHG pump 1B CC Pump 1B or 0 SX pump 1B MCR chiller 0B Place loads in Pull Out Cent Chg pumps RH pumps AF pump 1A RCFCs (Hi and Low) CS pumps CC pumps (1A, 1B, 0) SX pumps MCR chillers Check Unit 2 reserve feed breaker closed ACB 2424 NOTE: MRF ED007 CLOSE when directed to close ACB 2424. Synch and close Bus 242/142 reserve feed breaker ACB 1424 (breaker will not close) Check Bus 142 energized -Open ACB 1424		
	US	Transition to Attachment B		
	CREW	Inhibit Automatic Loading on 4KV ESF Busses Place loads in Pull Out Verify loads available for DG support 		

•

÷

Scenario	No: 00-3	Event No. 6
Event Des	scription:	Loss of All AC Power
Time	Time Position Applicant's Actions or Behavior	
	US	 Attempt to Restore Power Dispatch local operators to start DG Notify Electric Operations to implement an emergency AC restoration program Notify IMs to obtain individual CETC readings from heated junction thermocouple cabinets in the AEER
	US [CT] ECA- 0.0H	Locally isolate RCP Seals (dispatch local operators to close the following valves): • 1CV8384A MRF CV41 0 • 1CV8384B MRF CV42 0 • 1CC685 • 1CV8100
		NOTE: Return the 1A DG to the crew at this time. Inform the crew that you are ready to clear the tags off of the 1A DG. Once tags are cleared, you will take the Control Mode Selector switch to Remote. MRF EG03 REMOTE
	US	Transition to step 20 of Attachment B when Bus 141 becomes energized per the Operator Action Summary Page.
	BOP	 Verify SX System Operation SX pump 1A running Verify SX pump crosstie valves open – 1SX033/034 Verify Following Equipment Loaded on Energized 4KV ESF Bus Check 480V ESF Busses energized Check associated battery charger energized Check associated instrument inverters energized Check VC fans- one train running Supply Fan Return Fan M/U Fan Consult TSC for restoration of DC and AC instrument loads on Energized Trains if previously shed.
	BOP	Stabilize SG Pressures

•

Scenario No:	: 00-3	Event No. 6
Event Descri	iption:	Loss of All AC Power
Time H	Position	Applicant's Actions or Behavior
U	JS	 Select Proper Recovery Procedure Check RCS subcooling acceptable Check PZR level greater than 12% (28%) Check if any SI equipment has automatically actuated upon AC power restoration Transition to 1BwCA-0.2 "Loss of All AC Power Recovery With SI Required"
U	JS	Direct actions of 1BwCA-0.2
R	10	Check RWST Level greater than 46%
В	SOP/RO	 Manually Establish ECCS Injection Alignment On Energized Train(s) Verify RH pump miniflow valves open. Verify RH HX bypass flow control valve in manual with zero demand. Open Chg pump to cold leg injection isol valves. Open RWST to Chg pumps suction valves. Close VCT outlet isol valve. Close chg line Cnmt isol valves. Check CC Pumps all stopped Check CC from RCPs thermal barrier isol valves closed 1CC9438 or 1CC685 Load Safeguards Equipment as Necessary on Energized ESF Bus CC pump RH pump SI pump RCFCs Lo speed SX pump Place chiller in operation for operating VC Train.

.

4

Scenario	No: 00-3	Event No. 6
Event Description:		Loss of All AC Power
Time	Position	Applicant's Actions or Behavior
	CREW [CT] ECA- 0.0H	 Check if Charging Pumps should be started Check Chg pumps all stopped Check RCP seal injection isolation valves energized ICV8355A ICV8355B ICV8355D Dispatch operator to close RCP Seal Injection filter inlet isol vlvs. May have previously completed. ICV8384A ICV8384B Start Charging Pump(s)
		NOTE: Scenario may be terminated at this point

Comments: _____

a,

2

06/14/00 12:20 PM

Simulation Facility	Braidwood	Scenario No.: 00-4	Operating Test No.:	2
Examiners:		Operato	rs:	<u>SRO</u>
	······································		·····	RO
				BOP

Objectives: To evaluate the applicants ability to use Normal, Abnormal, Emergency and alarm response procedures to respond to pre-loaded SGTL, a power decrease, an auto rod speed controller failure, a VCT level transmitter failure, a SG level transmitter failure, actuation of deluge to the in service Control Room Vent Charcoal Filter, a SGTR.

Initial Conditions: IC-16, 49% power. Steady State Equilibrium Xenon.

Turnover: Circuit breaker 1423 (DG-1B feeder to bus 142) was declared OOS late last shift and is being replaced. DG-1B has been declared Out of Service. Breaker 1423 is expected to return to service in 3 to 4 hours. Currently in LCO 3.8.1 Condition B with 12 hours left on the completion time. Chemistry has just confirmed the 1B SG has a tube leak of 15 gpm.

Event	Malf.	Event	Event
No.	No.	Type*	Description
Preload	TH03B, 2	RO	SG B Tube leak – 2 gpm small enough to give alarms. Large enough to
		SRO	cause a power reduction
Preload	1B DG in PTL		1B DG OOS
	1423 in PTL		
	MRF EG09 MAINT_0		
Preload			Setup with the A Train MCR VC running and the OB Train secured.
			Secure the 1C MFP (first step of shutdown).
1		N BOP	Ramp down turbine power at directed MW/min
		B BO	
		K KU	Lower reactor power using rods and/or boration
2	RD09, 72	C RO	Auto Rod Speed controller failure – 72 steps/min when rod motion is
		SRO	initiated
3	CV17, 100	I RO	VCT level transmitter LT-185 fails high on a 180 sec ramp.
		SRO	
4	RX06G, 0	I BOP	SG B level transmitter (controlling) fails low on a 180 sec ramp (LT-
		SRO	529)
			(NOTE 1)
5	FP01C TRG 1	C BOP	Inadvertent deluge of MCR VC Charcoal filter (trips running supply &
	FP02G TRG 1	SRO	exhaust fans)
			(NOTE 2)
6	TC02	M BOP	Turbine trip on sensed low load
		RO SPO	
7	TU02D 400	M BOP	SC P tube munture (200 coo nome)
7	11105D, 400	RO	SO B tube rupture – (Soo sec ramp)
		SRO	
*(N)orma	l, (R)eactivity	(I)nstrument	, (C)omponent, (M)ajor Transient

NOTE 1 RP20 (OPEN/CLOSE) NOTE 2

RX057 (TRIP) When directed to reset deluge

RX058 (TRIP) DMF FP01C

MRF FP09 STOP

DMF FP02G

IOR SE:PN0750 OFF

When directed to secure OA Fire Pump

SCENARIO 00-4 OVERVIEW

Unit 1 is at 50% power. It will be discussed in the turnover that the SGTL has been discovered. Power decrease should be directed following turnover.

Following clearly observable plant response from the reactivity changes, an auto rod speed failure will cause rods to insert at 72 steps/min when demanded. It is expected that the RO will recognize improper rod motion for this condition and place rod control in manual. BwOA ROD-1 may be entered, but is NOT required, in response to the rod control problem. I&C will not be able to repair the rod speed problem and manual rod control will be the only way to move control rods at proper speed.

After actions for the rod failure are complete, a VCT level transmitter LT-185 will fail high. VCT level will have to be controlled manually to allow letdown flow to the VCT or divert as necessary. LT-112 indication will be available.

After control of VCT level is regained, a SG level channel will fail low. SG level control will be placed in manual and normal level restored. Entry is made into BwOA INST-2 (Attachment E); the level control is transferred to an operable channel and the FRV control returned to auto. The SRO will address Tech Specs for applicability and actions for the failed SG level instrument.

After the SG level channel bistables have been tripped, the deluge valve to the Control Room Vent Charcoal Filter opens when inadvertently kicked by a painter. The actuation of the deluge results in trip of the running "A" Train Control Room Ventilation Supply and Return fans and the "A" Train Chiller. The operator will be required to start the "B" Train equipment and direct local actions to isolate the deluge.

After Control Room Ventilation is restored, the main turbine will trip 60 seconds following failure of the load sensor. Coincident with the turbine trip the SGTR will occur on SG B. 1BwEP-0 will be entered and the crew will transition to E-3. The scenario terminates after depressurization is complete in E-3.

Critical Tasks

- E-3--A: Isolate feedwater flow into and steam flow from the ruptured SG before a transition to ECA-3.1 occurs.
- E-3--B: Establish/maintain RCS temperature so that transition from E-3 does not occur because the RCS temperature is in either of the following conditions:
 - Too high to maintain minimum required subcooling (per ICONICS or Att. A)

OR

- Below the RCS temperature that causes an extreme or severe challenge to the subcriticality and/or the integrity CSF (240°F).
- E-3--C: Depressurize RCS to meet SI termination criteria before water release from the ruptured SG PORV or Safety valve occurs.
- E-3--D: Terminate SI before ruptured SG overfill occurs and control RCS pressure and makeup flow so that primary and secondary inventory are stable before the end of the scenario.

Scenario No:	00-4	Event No. 1
Event Descrip	ption:	SG tube leak resulting in a power decrease.
Time Po	osition	Applicant's Actions or Behavior
		NOTE: Per turnover, the crew continues with 1BwOA SEC-8 "Steam Generator Tube Leakage" at step 10.b.
US	S	 Implement OA SEC-8 "STEAM GENERATOR TUBE LEAK" and direct operator action. Refer to Tech Specs 3.4.13 – MODE 3 in 6 hours, MODE 5 in 36 hours Suspend leak rate trending
US	5	 Initiate Power reduction/Unit shutdown Implement actions of 1BwGP 100-4. Direct load reduction
CR	REW	Review applicable Precautions, and Limitations and Actions.
RC	D	 Verify rod position and boron concentration. Initiate boration, if required to maintain ∆I within target band. (BwOP CV-6) Determine boric acid flow rate Set 1FK-110 BA Flow Cont to desired boration rate. Set 1FY-0110 BA Blender Preset Counter to desired volume. Place MU MODE CONT SWITCH to STOP position. Set MU MODE SELECT to BOR position. Place MAKE-UP CONTROL Switch to START
		 Verify proper operation of valves & BA transfer pump (CV110B open, BA pump is running, CV110A throttles open) Verify BA flow on recorder
BC)P	 Initiate turbine load reduction: Depress LOAD RATE MW/MIN Enter _ MW/min (determined to adequately meet Tech Spec times) Depress REF Enter power level When ready to begin load reduction, depress GO Verify load decreases.

Scenario	No: 00-4	Event No. 1
Event Description:		SG tube leak resulting in a power decrease.
Time	Position	Applicant's Actions or Behavior
	RO	 Monitor power decrease: Monitor reactor power, Tave, ΔI Verify rods move in AUTO to maintain Tave within ± 1.0°F of Tref. If borating: Monitor VCT level Monitor BA Blender counter countdown. Verify boration auto stops at preset value. Return Reactor Makeup System to blended flow at current blended flow.
		Note: Following clearly observable plant response from the reactivity changes, Event 2 is entered.

Scenario	No: 00-4	Event No. 2
Event De	escription:	Auto Rod speed controller failure – 72 steps/min.
Time	Position	Applicant's Actions or Behavior
	CUE	When rod motion is called for, rods step at 72 steps/min.
	RO/SRO	Identify/report rod motion too fast for conditions.
	RO	Place rod control in manual and stabilize reactor power.
	BOP/US	May stop turbine down power evolution until rod control problem is evaluated.
		NOTE: 1BwOA ROD-1 "UNCONTROLLED ROD MOTION, may be entered for reference but is not required.
	US	Notify SM/MAINT of rod speed controller malfunction
		NOTE: I&C will be unable to repair the rod speed controller.
	CREW	Determine actions needed to coordinate Unit S/D with rods in manual
		NOTE: After actions for rod speed problem have been completed, Event 3 may be started.

Comments:	
-----------	--

Scenario	No: 00-4	Event No. 3
Event De	scription:	VCT level transmitter LT-185 fails high
Time	Position	Applicant's Actions or Behavior
	CUE:	Annunciators: 1-9-A2 "VCT LEVEL HIGH LOW" 1-9-D2 "LTDWN FLOW DIVERTED TO HUT"
		1CV112A in full divert LT-112 indicates normal VCT level
	RO	 Identify/report failed transmitter Evaluation of operable VCT level indications LT-112 remains available.
	RO	Control VCT level manually to allow letdown flow to the VCT.
	US	Inform SM/Maint of VCT level transmitter LT-185 failure.
		NOTE: Initiate Event 4 after VCT level is regained and under manual control.

.

Comments: _____

.

Scenario	No: 00-4	Event No. 4
Event De	escription:	Steam Generator B level transmitter (controlling) fails low
Time	Position	Applicant's Actions or Behavior
	CUE:	 Annunciators 1-15-B3 "S/G 1B FLOW MISMATCH STM FLOW LOW" 1-15-B5 "SG 1B LVL LO-2 RX TRIP ALERT" 1-15-B9 "SG 1B LEVEL DEVIATION HIGH LOW" FT-529 indication reading low Feed reg. valve throttling open FW flow increasing SG level increasing above program
	BOP/US	 Identify/report Steam Generator Level channel LT-529 failure Take MANUAL control of Feed reg. valve and balance Feed flow with Steam flow to stabilize SG level, as necessary.
<u> </u>	US	Direct that the turbine ramp be slowed or stopped during troubleshooting.
	US	Implement BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment E "NARROW RANGE SG LEVEL CHANNEL FAILURE" and direct operator action.
	BOP/US	 Check affected SG levels normal If NOT, Place feed reg. valve in manual Restore SG level to a stable condition Select operable SG level channel Establish AUTO level control
	US	 Locally trip bistables for failed channel SG 1B - 1LT-529 - P14 LB529A Lo-2 Rx Trip/AF Pump Start LB529B
	BOP	Check status of AMS Not failed

- ----

Comments:

Scenario	No: 00-4	Event No. 4
Event De	scription:	Steam Generator B level transmitter (controlling) fails low
Time	Position	Applicant's Actions or Behavior
	US	Refer to Tech Spec • 3.3.1 • 3.3.2 • 3.3.3
	US	Inform SM/Maint of failure of SG 1B Level Transmitter LT-529
		NOTE: After Tech Specs are referenced, proceed to event 5.

+		
Scenario	No: 00-4	Event No. 5
Event Description:		Inadvertent deluge of MCR VC Charcoal filter
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciators: 0-33-A8 "MCR SUP FAN 0A TRIP DELTA P HIGH LOW 0-33-A9 "MCR RTRN FAN 0A TRIP DELTA P HIGH LOW 0-38-B7 "FIRE PUMP OA RUNNING" 0-33-C6 "MCR CHLR UNIT TROUBLE" Trip of running A Train Control Room Ventilation Supply and Return fans Trip of A Train Chiller. OA Fire Pump Running Unit 1 Fire Alarm
	RO	Identify/report trip of supply and return fans Diagnose inadvertent deluge of filter Start A train equipment as necessary Note: If asked, Fire Suppression Alarm is in Zone 1S-4.
	US	Direct isolation of deluge. Check SER printout to determine cause of alarm Direct securing of OA Fire Pump
	US	Report to SM/Maint status of control room fire suppression system
		NOTE: After the Control room Ventilation has been restored, Proceed to event 6 and 7.

÷x

•

O',

Scenario	No: 00-4	Event No. 6, 7
Event Description:		Automatic turbine trip (6) SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Behavior
	CUE	Turbine trip Reactor trip Power decreasing
	BOP/US	Identify/report turbine trip/reactor trip
	US	Implement EP-0 "Reactor Trip or Safety Injection"
	RO	Perform immediate operator actions of EP-0 Verify reactor trip • Rod bottom lights LIT • Reactor trip & bypass breakers open • Neutron flux decreasing
	BOP	 Verify Turbine Trip Turbine throttle valves closed Turbine governor valves closed Verify power to 4KV busses Bus 141 alive light lit Bus 142 alive light lit
	CREW	 Determine SI needed/actuated If actuated SI First OUT annunciator lit SI ACTUATED lit SI Equipment

05/25/00 11:20 PM

Scenario No: 00-4		Event No. 6, 7
Event Description:		Automatic turbine trip (6) SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Behavior
	BOP	Verify FW isolated
		FW pumps tripped
		• Isolation monitor lights lit • FW numps disch valves closed (FW002A.C)
		• • • • • • • • • • • • • • • • • • •
	RO	Verify ECCS pumps running
		CENT Chg pumps BH pumps
		• SI pumps
	BOP	Verify RCFCs running in LOW SPEED
		Verify Phase A isolation – Group 3 Monitor lights lit
		Verify CNMT Ventilation isolation - Group 6 Monitor lights lit
		Verify AF system:
		• AF pumps running.
		• AF isolation valves open (AF13A-H)
		• AF flow control valves throttled (AF005A-H)
		Verify CC Pumps running
		Verify SX Pumps running
	BOP	Check Main Steamline Isolation
		• Check SG pressure > 640 psig
		• Check CNMT pressure <8.2

Scenario	No: 00-4	Event No. 6, 7
Event De	scription:	Automatic turbine trip (6) SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Behavior
	BOP	Check if CNMT Spray is required
		• CNMT pressure > 20 psig
		NOTE: Containment spray may not be actuated at this time. When it does, do the following:
		Stop all RCPs
		Group 6 CS monitor lights – LIT
		Group 6 Phase B Isolation monitor lights – LIT
		• Check CS eductor suction flow on running pumps – Greater than 15 GPM
		• Check CS eductor additive flow on running pumps –Greater than 5 GPM.
	BOP	Verify AF flows
		• AF flow > 500 gpm available
		 SG levels maintained between 10% (31%) and 50%
		• Close AF isolation valves on SG 1B (due to SGTR)
		1AF013B
		1AF013F
	KO/BOP	Verify ECCS valve alignment & flows
		Group 2 CL Ini monitor lights lit
		• High Head Injection flow >100 gpm
		 Safety Injection flow > 200gpm (if RCS pressure <1700 psig)
	RO	Check at least One PZR PORV Relief Path Available
		• PORV isol valves - ENERGIZED • PORV relief path - AVAII ARI F
	BOP	Verify Generator Trin
	201	• OCB 1-8 open
		• OCB 7-8 open
	BOP	Verify DG running
		• SX valves open (SX169A/B)
		 Dispatch operator locally to check operation

.

•

Scenario No: 00-4		Event No. 6, 7
Event De	scription:	Automatic turbine trip (6)
Time	Position	SG B Tube Rupture (7)
1 1110		Applicant's Actions of Benavior
	BUr	ventilation systems anglied for emergency
		Control Room
[Aux Bldg.
		• Fuel Handling Bldg.
	RO	Check PZR sprays & PORVs closed
		Maintain RCS temperature control
		 Throttle AFW. Maintain total AFW flow >500 GPM until Steam Generator narrow range level >10% (31%).
		Check RCP status
		High Head SI Flow
		RCS pressure
	BOP	Check SG secondary boundary
		Check Steam Generator Tubes Intact (1B SG Ruptured)
	US	Transition to BwEP-3 "STEAM GENERATOR TUBE RUPTURE"
	US	Direct actions of BwEP-3
	RO	Check status of RCPs
		If any running, apply trip criteria • High Head Injection flow >100 gpm • Safety Injection Pump Disch flow > 200 gpm • RCS pressure < 1425 psig • Controlled C/D not in progress or previously initiated.

.

۰,
Scenario-No: 00-4		Event No. 6, 7
Event Description:		Automatic turbine trip (6)
Time	Desition	SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Benavior
	CREW	Identify ruptured SG
		o Unexpected rise in level
		o High activity for any SG sample
		• Reset CNMT Isol Phase A
		• Notify Chem to locally sample
		Open SG blowdown sample valves at Chem request
	ODEW	
	CREW	Identify/report IB SG as ruptured
		• · ·
	BOP	Isolate flow from ruptured SG
		• SG PORV 1MS018B in AUTO
		Check SG PORV 1MS018B closed
	BOP	Verify SG blowdown valves closed unless open for sampling
	[CT]	• 1SD002E
	E-3A	• 1SD002F
		Close MSIV and MSIV bypass valves for 1B SG
	BOP	Check PORVs on 1A 1C & 1D SGs available for cooldown
	201	
	BOP	Check ruptured SG level
		• II $\leq 10\%$ (31%) Maintain feed flow to 1D S/G until $\geq 100\%$ (21%)
		• If > 10% (31%)
		Verify AF valves closed on SG 1B
		Check ruptured SG pressure >320 psig.

Comments: _____

.

. . .

Scenario-	No: 00-4	Event No. 6, 7
Event De	scription:	Automatic turbine trip (6) SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Behavior
	CREW	Initiate RCS cooldown
		• Determine target temperature based on 1B SG pressure (Normal CNMT)
	[CT] E-3B	 Check PZR pressure < 1930 psig If so, block Steamline SI
		 Dump steam from intact SGs at maximum rate Steam dumps in STEAM PRESSURE Mode If steam dumps NOT available, SG PORVs
		Check average CETC temperatures < value determined above
		 Stop RCS Cooldown Maintain CETC < value determined above.
	BOP	 Check intact SG levels NR level >10% (31%) Maintain level between 23% (31%) and 50% Narrow range levels not increasing in an uncontrolled manner
	RO	Check PZR PORVs and Isolation Valves
		PORVs energized PORVs closed • RY455A • RY456
		At least ONE PORV Block valve OPEN RY8000A RY8000B

.

Scenario*No: 00-4		Event No. 6, 7
Event Description:		Automatic turbine trip (6) SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Behavior
	RO	Reset SI
		Reset CNMT isolation • ϕA • ϕB • Containment Ventilation • Restore IA to containment
	BOP	Verify all AC buses energized
· · · · · · · · · · · · · · · · · · ·	RO	 Check if RH pumps should be stopped RH Suction aligned to RWST RCS pressure >325 psig Stop RH pumps and place in standby
	CREW	Check if RCS Cooldown Should be Stopped
	CREW	Check ruptured SG pressure – STABLE OR INCREASING
	CREW	Check RCS subcooling acceptable

~¥

Scenario	No: 00-4	Event No. 6,7
Event Description:		Automatic turbine trip (6) SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Behavior
	RO	Depressurize RCS using Pzr spray to minimize break flow and refill Pzr.
	[CT] E-3C	Use PZR sprays Spray at maximum rate until ONE of the following met
		o BOTH
		• RCS pressure < 1B SG pressure
		• $PZR evel > 12\% (28\%)$
		o $PZR evel > 69\% (62\%)$
		o RCS subcooling NOT acceptable
		Close spray valves
		If sprays are not adequate, use one PZR PORV may use both
		 Open one PZR PORV until ONE of the following met BOTH
		 RCS pressure < 1B SG pressure PZR level > 12% (28%)
		o $PZR level > 69\% (62\%)$
		o RCS subcooling NOT acceptable
		Close PORVs
		Close spray valves
		Check RCS pressure increasing
	CREW	Check if ECCS flow should be terminated
		Subcooling acceptable
		Secondary Heat Sink
		RCS pressure stable or increasing
		• P2r level greater that 12% (28%)
	CREW	Stop ECCS Pumps and Place in Standby
		SI pumps
		All but one Chg pump

· • _____

Scenario	No: 00-4	Event No. 6, 7
Event Description:		Automatic turbine trip (6) SG B Tube Rupture (7)
Time	Position	Applicant's Actions or Behavior
	CREW	Terminate High-Head ECCSCheck Chg pumps suction aligned to RWST
	[CT] E-3D	 Reset SI recirc sump isol valves if necessary ISI8811A/1CV8110 ISI8811B/1CV8111 Reset SI Cent Chg Pump miniflow isol vlvs 1CV8114 1CV8116 Verify Chg pump miniflow isol vlvs open 1CV8110 1CV8111 1CV8114 1CV8114 1CV8116 Close Chg pumps to cold legs injection isol vlvs 1SI8801A 1SI8801B Establish Charging Flow
		Control Charging Flow to Maintain Pzr Level
		NOTE: Scenario may be terminated at this point

. . . . Ş.

*

Scenario 2 -

Cimulati	on Facility Desidenced			· · · · · · · · · · · · · · · · · · ·
Sinulati	on Facility Braidwood	Scen	ario No.: 00-6 Operating Test No.:	2
Examine	rs:		Operators:	SRO
				<u>RO</u>
				BOP
Objective Initial Co	es: To evaluate the app respond to normal detector failure, a I with a failure of au 1A AF Pump, and onditions: IC-21; 100%	plicants abilit power reduct RCP thermal tomatic start failure of the power BOL.	y to use Normal, Abnormal, Emergency and alarm ra ion, a plugged boric acid filter, a Tcold RTD failing barrier leak, a steam break causing a reactor trip, a R of both Auxiliary Feedwater (AF) pump but manual High Head SI discharge valves to auto open. Equilibrium. Xenon	esponse procedures to high, a steam flow CS Small Break LOCA start available for the
Turnover	Unit is at 100% pow	ver. Circuit br	eaker 1423 (DG-1B feeder to bus 142) was declared	OOS late last shift and
	3 to 4 hours. Curren	G-1B has be tly in LCO 3	en declared Out of Service. Breaker 1423 is expected 8.1 Condition B with 12 hours left on the completion	I to return to service in
Event	Malf.	Event	Event	i unie.
No.	No.	Type*	Description	
Preload	FW44	C BOP	1B AF Pump fails to start	
(NOTE I)	MRF EG09 MAINT_O	SRO	1B DG OOS	
(NOTE 1)	IMF RP15B IMF FW43 MRF RP90 OPEN MRF RP91 TEST IORs SE:PN0470 OFF SE:PN0468 OFF	C BOP SRO	1A AF Pump fails to auto start	
Preload (NOTE 1)	MRF RP75 OUT IOR ZDI1SI8801A CLS	C RO SRO	SI8801A fails close and SI8801B fails to auto oper	1
1		N BOP SRO	Ramp down turbine power to 800MW at 5 MW/m	in
		R RO	Lower reactor power using rods and/or boration	
2	RF CV33, 0	C RO SRO	Boric Acid filter plugged. (Insert after boration ha (NOTE 2)	s started)
3	RX18D, 630	I RO SRO	Loop 4 Tcold fails high (NOTE 3)	
4	RX03E, 0	I BOP SRO	Steam Flow C (control) detector fails low. (360 sec	; ramp) FT-532A
5	CC07C, 25	C RO SRO	Loop C RCP thermal barrier leak. (25 gpm)	
6	MS08C, 4	M BOP RO SRO	Main Steam Line Break Outside Containment (Res	ults in reactor trip)
7	ТН06С, 200 -900	M BOP RO SRO	RCS leak on Loop C at 200 gpm (increase to 900 g	pm after 5 min.)
8	Preload	C BOP SRO	AF pumps fail to auto start with 1A manual start ca	pable
9	Preload	C RO SRO	High Head SI discharge valves to RCS fail to open 1SI8801A	automatically with
*(N)ormal NOTE 1: NOTE 2: NOTE 3:	, (R)eactivity (1 Run BATCH FILE MRF CV34, 100 w MRF RP23 (OPEN	I)nstrument, for all Preload hen directed to /CLOSE)	(C)omponent,(M)ajor Transient BAT ES1.2 bypass filter.MRF RX026 (TRIP)MRF RX142 (TRIP)MRF RX141 (TRIP)MRF RX028 (TRIP)	RF RX025 (TRIP) RF RX027 (TRIP)

:

SCENARIO 00-6 OVERVIEW

Unit 1 is at 100 % power BOL. Following turnover, the crew will reduce power to 800MW at 5MW/min.

Following clearly observable plant response from the reactivity changes, the boric acid filter will become plugged causing a complete loss of boric acid flow. The operators will troubleshoot the lack of boric acid flow and will eventually open the filter bypass valve. The crew may use 1BwOP AB-26 "Changing a Boric Acid Filter" or the P&ID to bypass around the clogged filter.

After the boric acid filter bypass is opened, Loop 4 Tcold RTD will fail high. BwOA INST-2 (Attachment A) will be entered to address the failed Tcold RTD. The SRO will address ITS for actions for the failed Tcold instrument.

When I&C has tripped the bistables, a steam flow detector will fail low. This will cause the BOP to go to manual on the FWRV and control the feed pump speed manually. Entry into BwOA INST-2 (Attachment H) is required. The failed channel will be selected out and after control of SG level is attained, control will be switched back to auto. The turbine ramp should be slowed or stopped during troubleshooting and plant stabilized.

Two minutes following return of the SG level control to auto, a RCP will develop a thermal barrier leak. Entry into BwOA PRI-1 may occur and entry into PRI-6 will occur. The operators must diagnose the leak and expected radiation alarms, and manually isolate the leak.

After the RCP thermal barrier leak is isolated, a main steam break outside of containment will occur. This will result in a reactor trip and main steam isolation. The crew will enter BwEP E-0 and transition to BwEP ES-1.1. While the crew is in ES-1.1, an RCS leak of 200 gpm occurs. This leak will increase to 900 gpm after approx. 5 min. Upon AFW actuation, the 1A motor driven AF pump and the 1B diesel driven AF pump will fail to start. The operator will manually start the 1A AF pump (the 1B AFW pump will not be able to be started). The high head SI discharge valve SI8801A & B will fail to open with the SI8801B capable of being manually open. The operator will manually open SI8801B for high head injection flow. Transition is made to E-1 based on RCS and containment conditions. Cooldown will be required and transition is made to ES-1.2. The scenario is terminated when at step 6 when determination of cooldown is required.

Critical Tasks

E-0--F: Establish the minimum required AFW flow rate to the SGs before transition out of E-0.

E-0--I: Establish flow from at least one high-head ECCS pump before transition out of E-0.

Conorio	No: 00 6	
Scenario	NO: UU-U	
Event De	scription:	Power decrease at 5 MW/min.
Time	Position	Applicant's Actions or Behavior
	US	Implement actions of 1BwGP 100-4, "Power Descension"
	<u> </u> '	
	US	Direct load reduction to 800Mw.
	CREW	Review applicable Precautions, and Limitations and Actions.
	RO	Verify rod position and boron concentration.
		 Initiate boration, if required to maintain ∆I within target band. (BwOP CV-6) Determine boric acid flow rate Set 1FK-110 BA Flow Cont to desired boration rate. Set 1FY-0110 BA Blender Preset Counter to desired volume. Place MU MODE CONT SWITCH to STOP position. Set MU MODE SELECT to BOR position. Place MAKE-UP CONTROL Switch to START Verify proper operation of valves & BA transfer pump (CV110B open, BA pump is running, CV110A throttles open) Verify BA flow on recorder
	BOP	 Initiate turbine load reduction: Depress LOAD RATE MW/MIN Enter 5 MW/min Depress REF Enter power level When ready to begin load reduction, depress GO Verify load decreases.

...

-

Scenario	No: 00-6	Event No. 1
Event De	escription:	Power decrease at 5 MW/min
Time	Desition	
1 mile	FOSICION	Applicant's Actions or Behavior
	RO	 Monitor power decrease: Monitor reactor power, Tave, ΔI Verify rods more in AUTO to maintain Tave within ± 1.0°F of Tref. If borating:
		 Monitor VCT level Monitor BA Blender counter countdown. Verify boration auto stops at preset value. Return Reactor Makeup System to blended flow at current blended flow.
		Note: Following clearly observable plant response from the reactivity changes, Event 2 is entered.

Comments: _____

.

Scenario	No: 00-6	Event No. 2
Event Description:		Boric Acid filter plugged
Time	Position	Applicant's Actions or Behavior
	CUE	No Boric Acid flow is indicated. Boric Acid flow counter slowly stops
	RO/SRO	Identify /Report lack of boric acid flow
	RO	Check other indications in an attempt to identify why there is no boric acid flow.
	RO	Report that there are no abnormal valve lineups.
	RO/SRO	Determine that the boric acid filter is plugged. Recommend opening the filter bypass valve (1AB8458).
	US	Direct opening of boric acid filter bypass valve (1AB8458).
		NOTE: After boric acid filter bypass valve is opened, Event 3 may be started.

Comments: _____

-

••

..

.

Scenario No: 00-6		Event No. 3
Event Description:		Loop D Tcold fails high
Time	Position	Applicant's Actions or Behavior
	CUE:	Annunciators: 1-14-A3 "LOOP 1A TAVE DEV LOW" 1-14-B1 "OTΔT HIGH RX TRIP ALERT" 1-14-B3 "LOOP 1B TAVE DEV LOW" 1-14-C3 "LOOP 1C TAVE DEV LOW"
		Loop 4 ΔT Tcold fails high Tave Loop D increase ΔT Loop D decrease
	RO	 Identify/Report failed Tave & ΔT Determine Tcold failed high on Loop D Place Rod Bank Select switch in MANUAL
	US	Implement 1BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment A "RCS NARROW RANGE RTD CHANNEL FAILURE" and direct operator action.
	RO	 Manually defeat failed RTD channel Select failed Tave channel with Tave DEFEAT switch Select failed ΔT channel with ΔT DEFEAT switch Select operable channel for ΔT recorder
	RO	Check if rod control can be returned to AUTO • TURB LOW POWER INTLK C5 not lit Check Tave-Tref stable and within 1°F • Restore to within 1°F • Adjust rods • Adjust turbine load • Adjust turbine load • Adjust RCS boron concentration Place ROD BANK SELECT switch in AUTO Check PZR Level normal & stable

Comments:

.

C.		
Scenario No: 00-6		Event No. 3
Event De	scription:	Loop D Tcold fails high
Time	Position	Applicant's Actions or Behavior
	RO	 Locally trip bistables for Loop D by placing in TEST OP ΔT Trip TB441G OPΔT Runback TB441H OTΔT Trip TB441C OTΔT Runback TB441D Low Tave TB442G Lo-Lo Tave TB442D
	RO	Check P12 interlock LO-2 TAVE STM DUMP INTLK P12 not lit
	US	Check Technical Specifications: • 3.3.1 • 3.3.2
	US	Inform SM/Maint of Loop 1D Tcold RTD failure.
		NOTE: Initiate Event 4 after the Unit Supervisor references Tech Specs.

Scenario	No: 00-6	Event No. 4
Event Description:		Steam Flow C (controlling) detector fails low
Time	Position	Applicant's Actions or Behavior
	CUE:	 Annunciator 1-15-C3 "S/G 1C FLOW MISMATCH STM FLOW LOW" FT-532 indication reading low Feedwater Regulating Valve throttling closed FW flow decreasing SG level decreasing below program
	BOP/US	Identify/Report steam flow channel FT-532 failure Take MANUAL control of Feed reg. valve and balance Feed flow with Steam flow to stabilize SG level, as necessary.
	US	Direct that the turbine ramp be slowed or stopped during troubleshooting.
	US	Implement 1BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment H "STEAM FLOW CHANNEL FAILURE" and direct operator action.
	BOP/US	 Check affected SG levels normal Place feed reg. valve in manual Verify adequate feedwater ΔP Restore SG level to a stable condition
		Select operable steam flow channel Establish AUTO level control
		Verify steam pressure channels PT-534 and PT-535 normal
	US	Inform SM/Maint of failure of SG 1C steam flow channel FT-532
		NOTE: Two minutes following return of SG level control to auto, Proceed to Event 5

Comments: _____

۰.

3

٠

--

,

Scenario	No: 00-6	Event No. 5
Event De	scription:	Loop C RCP Thermal Barrier leak.
Time	Position	Applicant's Actions or Behavior
	CUE	CCW Surge Tank Level increase
		CCW activity levels increase (Radiation monitor alarm)
		CCW surge tank vent valve will close on high activity.
		Pressurizer level decreasing
		Charging flow increasing
		NOTE: 1BwOA PRI-1 may be entered. BwOA Pri-6 will be entered.
	US	Implement 1BwOA PRI-6, "Component Cooling Malfunction" and direct operator action.
	BOP	Check CC Surge Tank Level
		• Level is increasing
	US	Direct operations to 1BwOA PRI-6, ATT. A "Abnormal CC Surge Tank Level"
	BOP	Check CC Surge Tank Level
		Level is increasing
		Note: Utilize RF CC15/CC16 100 to drain surge tank when asked
	RO	Check for Leakage from RCP Thermal Barrier
		• RCP THERM BARR CC WTR FLOW HIGH/LOW (1-7-E4) – LIT
		• Seal Injection flow – any indicating abnormally high
•		• Manually throttle ICV121 and ICV182 to maintain seal injection flow between 8-13 GPM per pump.
		Manually close 1CC685
	US	Restore CC to unaffected RCPs at Shift Manager discretion
		Direct local operator to locally close RCP thermal harrier CC outlet value to isolate affected nump
		• 1CC9496C MRF CC46 0
	US	Refer to Tech Specs:
		• 3.7.7
		NOTE: After the RCP thermal barrier is isolated, Proceed to Event 6.
		· ·

_____.

	NI 00 C	
Scenario No: 00-6		Event No. 6
Event Description:		Main Steam Break Outside Containment (isolated by MSIV closure).
Time	Position	Applicant's Actions or Behavior
	CUE	MSIV closure
		Reactor Trip
		NOTE: Main Steam break will be isolated when MSIVs close.
	US	Implement 1BwEP-0 "Reactor Trip or Safety Injection"
	RO	Perform immediate operator actions of 1BwEP-0
		Verify reactor trip • Rod bottom lights LIT • Reactor trip & bypass breakers open • Neutron flux decreasing
	BOP	Verify Turbine Trip
		 Turbine throttle valves closed Turbine governor valves closed
		Verify power to 4KV busses
		 Bus 141 alive light lit Bus 142 alive light lit
	CREW	Determine SI needed/actuated
		 If needed Pzr pressure <1829 psig Steamline pressure <640 psig Cnmt pressure >3.4 psig Pzr level can not be maintained >4%
	BOP	Verify FW isolated
		 FW pumps tripped Isolation monitor lights lit FW pumps disch valves closed (FW002A-C)

٠.

•••

Scenario No: 00-6		Event No. 6
Event De	scription:	Main Steam Break Outside Containment (isolated by MSIV closure).
Time	Position	Applicant's Actions or Behavior
	RO	Verify ECCS pumps running
		• CENT Cha nume
		RH pumps
		• SI pumps
	BOP	Verify RCFCs running in LOW SPEED
		Verify Phase A isolation – Group 3 Monitor lights lit
		Verify CNMT Ventilation isolation - Group 6 Monitor lights lit
	[CT]	
	Е-0К	Verity AF system:
		• AF isolation values open (AF13A-H)
		• AF flow control valves throttled (AF005A-H)
		verify CC Pumps running
		Verify SX Pumps running
	BOP	Check Main Steamline Isolation
	201	 Check SG pressure > 640 psig
		• Check CNMT pressure <8.2
	BOP	Check if CNMT Spray is required
		• CNMT pressure > 20 psig
		NOTE: Containment spray may not be actuated at this time. When it does, do the following:
		• Stop all RCPs
		Group 6 CS monitor lights – LIT
		Group 6 Phase B Isolation monitor lights – LIT
		 Cneck CS eductor suction flow on running pumps – Greater than 15 GPM Check CS eductor additive flow on running pumps – Greater than 5 GPM
		Check of cautor additive new on running pumps — Greater than 5 Or W.

.

Comments:

.

11

Ŋ

Scenario No: 00-6	Event No. 6
Event Description:	Main Steam Break Outside Containment (isolated by MSIV closure).
Time Position	Applicant's Actions or Behavior
BOP	 Verify AF flows AF flow > 500 gpm available SG levels maintained between 10% (31%) and 50%
RO	Verify ECCS valve alignment & flows
[CT] E-0I	 Group 2 CL Inj monitor lights lit High Head Injection flow >100 gpm Must manually open 1SI8801B Safety Injection flow > 200gpm (if RCS pressure <1700 psig)
RO	Check at least One PZR PORV Relief Path Available PORV isol valves - ENERGIZED PORV relief path - AVAILABLE
BOP	Verify Generator Trip • OCB 1-8 open • OCB 7-8 open
BOP	 Verify DG running SX valves open (SX169A/B) Dispatch operator locally to check operation
ВОР	 Ventilation systems aligned for emergency Control Room Aux Bldg. Fuel Handling Bldg.
RO	Check PZR sprays & PORVs closed Maintain RCS temperature control • Throttle AFW. Maintain total AFW flow >500 GPM until Steam Generator narrow range level >10% (31%). Check RCP status

÷

•	
Scenario No: 00-6	Event No. 6
Event Description:	Main Steam Break Outside Containment (isolated by MSIV closure).
Time Position	Applicant's Actions or Behavior
ВОР	 Check SG secondary boundary Check Steam Generator Tubes Intact
RO	Check if RCS is Intact CNMT area radiation monitors CNMT pressure CNMT floor water level
	 Check if ECCS Flow Should be Terminated RCS subcooling Secondary Heat Sink RCS pressure stable or increasing Pzr level greater than 12%
SRO	Transition to 1BwEP ES-1.1 "SI Termination"
CREW	 Reset SI if Necessary Depress both SI reset pushbuttons Reset Containment Isolation Reset Phase A Reset Phase B Check SACs running Open instrument air Cnmt isolation valves 1IA065 1IA066

Comments: _____

13

.

Scenario No: 00-6		Event No. 6
Event Description:		Main Steam Break Outside Containment (isolated by MSIV closure).
Time	Position	Applicant's Actions or Behavior
	RO	 Realign Cent Chg Pumps Stop all but 1 Chg pump
		Check RCS pressure stable or increasing
		Check Chg Pump suction aligned to RWST
		Reset SI recirc sump isol valves if necessary
		 Reset Chg pump miniflow isol valves Verify Chg pump miniflow isolation valves open
		 Close Chg pumps to Cold Leg injection isol valves
	RO	 Establish Charging Flow Place 1CV182 controller at 0% demand Open charging line Cnmt isol valves 1CV8105 1CV8106 Throttle 1CV182 to maintain RCP seal injection flow between 8 and 13 gpm per pump. Control Charging Flow to Maintain Pzr Level Throttle 1CV121 to maintain Pzr level greater than 12% (28%) Check if SI Pumps Should be Stopped Check If RH Pumps Can Be Stopped Check RH pumps suction aligned to RWST Stop RH pumps and place in standby
		NOTE: After step 9 of 1BwEP ES-1.1 is complete, initiate Event 7

Scenario	No: 00-6	Event No. 7	
Event De	escription:	RCS Leak on C Loop	
Time	Position	Applicant's Actions or Behavior	
	CUE	Pzr level decreasing Pzr pressure decreasing Radiation monitor alarms Containment sump level increasing	
	US	Transition to BwEP-1 "LOSS OF REACTOR OR SECONDARY COOLANT"	
	_ *	Direct actions of BwEP-1	
	CREW	 Check Status of RCPs If any RCP is running check if RCPs should be stopped: High head SI flow greater than 100 GPM SI pump discharge flow greater than 200 GPM RCS temperature less than 1425 psig Controlled RCS cooldown not in progress or previously initiated 	
	BOP/US	 Check SG secondary pressure boundaries intact Check pressure in all SGs No SG pressure decreasing in uncontrolled manner No SG completely depressurized Check intact SG levels Narrow range levels >10% (31%). If not flow is maintain > 500 gpm Control feed flow to maintain intact SG levels between 10% (31%) and 50% Check narrow range levels NOT increasing in an uncontrolled manner. 	
	BOP	Check secondary radiation normal	
	RO/US	 Check PZR PORVs and Isolation Valves PORV Isol valves energized 1RY8000A/B PORVs closed RY455A & RY456 PORV isolation valves at least one open 	

ς.

x.

.

.

Scenario No: 00-6		Event No. 7
Event Description:		RCS Leak on C Loop
Time	Position	Applicant's Actions or Behavior
	CREW	Check if ECCS flow should be reduced
		RCS Subcooling acceptable
		 Secondary heat sink Total feed flow to SGs > 500 gpm available
		NR level in at least ONE intact SG > 10% (31%)
		• RCS Pressure stable or increasing
		• PZR level >12% (28%)
		Determine ECCS reduction criteria NOT met (subcooling likely)
	CREW	Check if CNMT Spray should be stopped
		CS Pumps running
		• Reset CS signal
		 When Spray Additive tank LO-2 level lights LIT, close eductor spray additive valves 1CS019A/B
		When CNMT pressure is < 15 psig AND CS has operated for at least 2 hours, continue with steps to secure CS

,

.

05/25/00 6:46 PM

.

Scenario No: 00-6 Event No 7		
Event De	scription	RCS Leak on C Loon
Time		
Time	Position	Applicant's Actions or Behavior
	RO/US	Check if RH Pumps should be stopped
		• Reset SI
		• Depress BOTH SI RESET pushbuttons
		• Verify SI ACTUATED permissive light NOT lit
		• Verify AUTO SI BLOCK permissive light LIT
		Check RH pumps suction aligned to RWST
		Check RCS pressure > 325 psig
		• If NOT, DO NOT stop RH pumps
		• If > 325 psig AND pressure stable or increasing
		Stop RH pumps and place in standby
	CREW	Check RCS and SG pressures
		Check pressure in ALL SGs stable or increasing
		Check RCS pressure stable or decreasing
	BOP/US	Check if DG should be stopped
		Bus 141 & 142 energized
		Bus 143 & 144 energized
		Stop 1A & 1B DG per 1BwOP DG-12 "Diesel Generator Shutdown"

Comments: _____

.

· •

Scenario No: 00-6		Event No. 7
Event De	scription:	RCS Leak on C Loop
Time	Position CREW	Applicant's Actions or Behavior Evaluate plant status
		• Verify Cold Leg Recirc capability
		Check Aux Building Radiation monitors
		• Reset Containment Isolation Phase A if necessary
		• Place H2 monitors in service per 1BwOP PS-9
		• Obtain samples RCS activity and boron concentration Containment sump and atmosphere
		• Evaluate plant equipment
		• Trip all Heater Drain Pumps
		 Shutdown Feedwater pumps, Condensate pumps and Circulating Water Pumps
		• Shutdown chiller on non-operating VC train
	RO/US	Check if RCS cooldown and depressurization is required
		• RCS pressure > 325 psig
		• Transition to 1BwEP ES-1.2, "Post LOCA Cooldown and Depressurization".
	US	Transition to 1BwEP ES-1.2 "POST LOCA COOLDOWN AND DEPRESSUIZATION"
	US	Direct actions of 1BwEP ES-1.2

Comments: _____

•

Scenario No: 00.6 Excent No. 7			
Event D	140. 00-0	Event No. /	
Event Description:		RCS Leak on C Loop	
Time	Position	Applicant's Actions or Behavior	
	RO	Reset SI if necessary	
		• Depress both SI reset pushbuttons	
		 Verify ALTO SLPLOCKED permissive light – NOT LIT Verify ALTO SLPLOCKED permissive light – LTT 	
		Venty A010 SI BLOCKED permissive light – L11	
	RO/BOP	Reset Containment Isolation	
	ļ	Reset CNMT Isol Phase A	
		Reset CNMT Isol Phase B	
		Reset CNMT Vent Isol	
		Check SACs – ANY RUNNING	
		• Open instrument air CNM1 isol valves.	
		114065	
	BOP	Verify ALL AC busses energized	
		• Bus 141 & 142	
		• Bus 143 & 144	
		• Bus 156, 157, 158, 159	
	RO	Check if RH numps should be stopped	
		onder in reit pumps should be stopped	
		Check RH pumps suction aligned to RWST	
		Check RCS pressure > 325 psig	
		 If NOT, DO NOT stop RH pumps 	
		• If > 325 psig AND pressure stable or increasing	
		Stop RH pumps and place in standby	
	BOP	Check Intact SG levels	
		• Narrow range levels >10% (31%)	
		• Control feed flow to maintain levels – BETWEEN 10% (31%) and 50%	
		Narrow range levels - NOT increasing in an uncontrolled manner	
	CREW	Initiate RCS cooldown to 200 F	
		NOTE: Scenario may be terminated at this point	
		A second to may be terminated at this point	

.

19

ES-301

Т

ŧ

. .

				-	
	QUALITATIVE ATTRIBUTES		L.	Initial	s
			a	b	c
		······································	ļ		_
1.	The initial conditions are realistic, in that some equipment and/or instrum of service, but it does not cue the operators into expected events.	entation may be out	1	to	MG
2.	The scenarios consist mostly of related events.		4	M	MCR
3.	Each event description consists of				1107
	the point in the scenario when it is to be initiated the malfunction(s) that are entered to initiate the event the symptoms/cues that will be visible to the crew the expected operator actions (by shift position) the event termination point (if applicable)		4	150	MEG
4.	No more than one non-mechanistic failure (e.g., pipe break) is incorporate without a credible preceding incident such as a seismic event.	ed into the scenario	4	7S	mçg
5.	The events are valid with regard to physics and thermodynamics.		1	nd	MAC
6.	Sequencing and timing of events is reasonable, and allows the examination complete evaluation results commensurate with the scenario objectives.	on team to obtain	51	15	MGS
7.	If time compression techniques are used, the scenario summary clearly so Operators have sufficient time to carry out expected activities without un constraints. Cues are given.	o indicates. ndue time	4	y s	MGS
8.	The simulator modeling is not altered.		A	xis	MGL
9.	The scenarios have been validated.		4	x	MOH
10.	Every operator will be evaluated using at least one new scenario. All oth been modified in accordance with Section D.4 of ES-301.	er scenarios have	A	AN	WGP
11.	All individual operator competencies can be evaluated, as verified using F (submit the form along with the simulator scenarios).	orm ES-301-6	A	ALS	MCL
12.	Each applicant will be significantly involved in the minimum number of tra specified on Form ES-301-5 (submit the form along with the simulator sc	ansients and events enarios).	4	M	met.
13.	The level of difficulty is appropriate to support licensing decisions for eac	h crew position.	51	No.	AKG6
	TARGET QUANTITATIVE ATTRIBUTES (PER SCENARIO)	Actual Attributes		J	γr/
1.	Total malfunctions (5-8)	7/7/7	51	κ	IN CA
2.	Malfunctions after EOP entry (1-2)	3/3/1	5	Le l	HICA
3.	Abnormal events (2-4)	4/3/4		Jel .	HP-C-J NICA
ŧ.	Major transients (1-2)	1/2/2	X	ker	NCL
5.	EOPs entered/requiring substantive actions (1-2)	2/3/2	X	res	MCB
6.	EOP contingencies requiring substantive actions (0-2)	0/2/0	A	rd	MSK
7.	Critical tacks (2.3)		-/-{		<u>r v v</u>

ES-301

Transient and Event Checklist

Applicant	Evolution	Minimum		Scenario	Number	
Туре	Туре	Number	00-7	00-8	00-9	Spare
·			1	2	3	4
	Reactivity	1	4/	1/	1/	1/
	Normal	1	/4	/1	/1	/1
RO	Instrument	2	1,2/1	3/4	4/2,3	2/3
	Component	2	3,5/5	2,6/6	5,7/5,7	4,7/8
	Major	1	6/6	6,7 / 6,7	6,8 / 6,8	5,6 / 5,6
	Reactivity	1	4	1	1	1
	Normal	0		,		
As RO	Instrument	1	1,2	3	4	2
	Component	1	3,5	2,6	5,7	4,7
	Major	1	6	6,7	6,8	5,6
SRO-I						
	Reactivity	0				
	Normal	1	4	1	1	1
As SRO	Instrument	1	1,2	3,4	2,3,4	2,3
	Component	1	3,5	2,6	5,7	4,7,8
	Major	1	6	6,7	6,8	5,6
	Reactivity	0	N/A	N/A	N/A	N/A
	Normal	1	N/A	N/A	N/A	N/A
SRO-U	Instrument	1	N/A	N/A	N/A	N/A
	Component	1	N/A	N/A	N/A	N/A
	Major	1	N/A	N/A	N/A	N/A

OPERATING TEST NO.: 3

Instructions: (1)

Enter the operating test number and Form ES-D-1 event numbers for each evolution type.

(2) Reactivity manipulations must be significant as defined in Appendix D.

NOTE: Scenario Number 4 is a "spare" scenario and is represented for comparison purposes only in Examination Outline submittal.

The "/" in the cells for the "RO" applicant type represents the position the applicant is expected to fill during the scenario. The events are listed for the identified position: RO / BOP.

Author: ------Chief Examiner: _

ES-301

		Applic O/ SRO	ant #1 -I/SRO	Ð	Applicant #2 Applicant #3 RO/ SRO-I / SRO-U RO(BOP)/ SRO-I / SRO-U					RO-U		
Competencies		SCENARIO			SCENARIO				SCENARIO			
	07	08	09	S	07	08	09	S	07	08	09	S
Understand and Interpret Annunciators and Alarms	1,2,3 ,5,6	2-7	2-8	2-8	1,2,3 ,5,6	2,3,5 ,6,7	4-8	2,4,5 ,6,7	1,5,6	4,5,6 ,7	2,3,5 ,6,7, 8	3,5,6 ,8
Diagnose Events and Conditions		2-7	2-8	2-8	1,2,3 ,5,6	2,3,5 ,6,7	4-8	2,4,5 ,6,7	1,5,6	4,5,6 ,7	2,3,5 ,6,7, 8	3,5,6 ,8
Understand Plant and System Response		1-7	1-8	1-8	1-6	1,2,3 ,5,6, 7	1,4-8	1,2,4 ,5,6, 7	1,4,5 ,6	1,4,5 ,6,7	1,2,3 ,5,6, 7,8	1, 3,5,6 ,8
Comply With and Use Procedures (1)		1-7	1-8	1-8	1-6	1,2,3 ,5,6, 7	1,4-8	1,2,4 ,5,6, 7	1,4,5 ,6	1,4,5 ,6,7	1,2,3 ,5,6, 7,8	1, 3,5,6 ,8
Operate Control Boards (2)	1-6	1-7	1-8	1-8	1-6	1,2,3 ,5,6, 7	1,4-8	1,2,4 ,5,6, 7	1,4,5 ,6	1,4,5 ,6,7	1,2,3 ,5,6, 7,8	1, 3,5,6 ,8
Communicate and Interact With the Crew	1-6	1-7	1-8	1-8	1-6	1-7	1-8	1-8	1-6	1-7	1-8	1-8
Demonstrate Supervisory Ability (3)	1-6	1-7	1-8	1-8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Comply With and Use Tech. Specs. (3)		2,3	3,4,5	2,4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Notes:				_			:					

Operating Test: 3

(1) Includes Technical Specification compliance for an RO.

(2) Optional for an SRO-U.

(3) Only applicable to SROs.

Instructions:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

NOTE: **OPERATING TEST NO.: 3.** Scenario Number 4 is a "spare" scenario and is represented for comparison purposes only in Examination Outline submittal. The order of listing for candidates is SRO, RO and BOP by position.

Author: Chief Examiner:

Simulation Fa	cility Braidwood	Scenario No.: 00-7	Operating Test No.: 3
Examiners:		Operato	rs: <u>SRO</u>
			<u>RO</u>
			<u></u> <u>BOP</u>
Objectives:	To evaluate the application respond to an impulse failing open requiring components failing to	ants ability to use Normal, Abno pressure transmitter failure, Pzr a unit S/D, loss of ESF Bus, RC	ormal, Emergency and alarm response procedu Master Controller failing low, 1C RCP #1 sea P shaft seizure resulting in a LOCA with vario

Initial Conditions: IC- 21, 100% power, Steady State operations. All equipment in automatic and operating properly.

100% power, Steady State operations. All equipment in automatic and operating properly. Turnover:

Event	Malf.	Event	Event
No.	No.	Type*	Description
Preload (NOTE 1)	RP01 IOR ZDIRT2 NORMAL	C BOP RO SRO	Automatic reactor trip failure. Failure of the reactor trip switch from the RO panel.
Preload (NOTE 1)	RP02A	C RO SRO	Failure of the "A" RTB to open.
Preload (NOTE 1)	RP15C MRF FW160 STOP FW43	C BOP RO SRO	Failure of the 1A SI Pump to Auto start. Failure of the 1B AFW Pump to Auto start. Failure of the 1A AFW Pump to Auto Start
1	RX10A, 0	I BOP RO SRO	PT-505 failure low (NOTE 2)
2	RX15, 2355	I RO SRO	Failure of the Pzr Master Pressure Controller
3	CV27C, 4	C RO SRO	Failure of the 1C RCP #1 seal
4		N BOP SRO	Ramp down turbine power at directed MW/min due to RCP seal failure
		R RO	Lower reactor power using rods and/or boration due to RCP seal failure
5	ED07B	C BOP RO SRO	Loss of ESF Bus 142 (overcurrent)
6	TH17C TH06C, 2000 IOR ZDI1HSAP041	M BOP RO SRO	1C RCP shaft seizure 1C RCS cold leg LOCA (1 minute delay) Trip Bkr 1412 in E-0 (after main generator trip) to manually start the 1A SI Pump; then delete override.

*(N)ormal,

(R)eactivity (I)nstrument, (C)omponent, (M)ajor Transient

NOTE 1: Run BATCH FILE for all Preload **BAT 1AFWPMP**

NOTE 2: RP20 (OPEN/CLOSE) RX143 (Trip)

SCENARIO 00-7 OVERVIEW

The scenario starts with the Unit 1 at 100% steady state power. There are no Out of Services and all equipment is operating properly.

After the crew has taken the shift, PT-505, Main Turbine First Stage Impulse Pressure Channel will fail low causing the crew to perform the actions of BwOA INST-2 Attachment D. These actions include manual rod control, going to the steam pressure mode on the steam dumps, defeating the failed channel, tripping bistables and referencing Tech Specs.

After the actions of BwOA INST-2 Attachment D are complete, the Pressurizer Master Pressure Controller will fail high. The crew should take manual control of the controller and restore RCS pressure to normal. The crew may reference BwOA INST-2 Attachment B for guidance. The crew should reference Tech Specs for DNB.

Once Pzr Pressure has been restored to normal, the 1C RCP #1 seal will fail open resulting in the Unit required to be shutdown and the 1C RCP secured within 8 hours. The crew should enter BwOA RCP-1 to address the seal failure. The crew will commence a unit shutdown per BwGP 100-4 ensuring that the 1C RCP will be secured in 8 hours.

Following clearly observable plant response from the reactivity changes resulting from the unit shutdown, an overcurrent condition will occur on Bus 142 resulting in the loss of Bus 142. The crew should enter BwOA ELEC-3 to take actions for the loss of Bus 142. The crew should also determine that Attachment D of BwOA ELEC-3 is not applicable. The crew will reference Tech Specs.

After the actions for the loss of Bus 142 are complete, the 1C RCP shaft will seize resulting in a RCS Cold Leg LOCA. The crew will have to manually trip the reactor from the safeguards panel due to both an automatic reactor trip failure and the failure of the manual reactor trip switch from the RO panel. The crew will perform the actions of BwEP E-0. During the Immediate Actions of E-0, the crew should recognize that the "A" reactor trip breaker failed to open and dispatch a local operator to open it. The crew will have to manually start the 1A SI pump due to an auto start failure. Auxiliary Feedwater will also have to be manually initiated due to the failure of the 1A AF pump to start and the failure of the 1B AFW pump to auto start.

From BwEP E-0 the crew will transition to BwEP E-1 and then to BwEP ES-1.2 to cooldown the primary plant.

Critical Tasks

- E-0--A: Manually trip the reactor from the control room to prevent a transition to BwFR-S.1.
- E-0--F: Establish the minimum required AFW flow rate to the SGs before transition out of E-0.
- E-0--J: Establish flow from at least one intermediate-head ECCS pump before transition out of E-0

•	•	
Scenario	No: 00-7	Event No. 1
Event De	escription:	PT-505 Failure Low
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciators: 1-14-D1 "TAVE CONT DEV HIGH" 1-14-E6 "TURB IMPULSE PRESS OOS" C-5 C-20 ΔP between PT-505 & PT-506
	US	Transition to 1BwOA INST-2 "Operation With A Failed Instrument Channel" Attachment D "Turbine Impulse Pressure Channel Failure" Direct actions of 1BwOA INST-2
	RO	Place Rod Bank Select Switch in Manual
	BOP	 Restore Steam Dumps Check LOSS OF TURB LOAD INTLK C7 – Not Lit Place MS header pressure controller in MANUAL and reduce demand signal to zero Place steam dump MODE SELECT switch in STM PRESS mode Place MS header pressure controller in AUTO
	RO	Manually Defeat Failed Channel • Select failed channel on TURBINE IMPULSE PRESSURE DEFEAT switch - PT-505
	US	Trip bistables Check Turbine power greater than 10% P13 input to P7 PB505A
	RO	 Check if Rod Control Can Be Placed in Auto TURBINE LOW POWER INTLK C5- Not Lit Tave-Tref deviation stable and within 1°F Place Rod Bank Select switch in Auto

•

5

•

Scenario	No: 00-7	Event No. 1
Event De	escription:	PT-505 Failure Low
Time	Position	Applicant's Actions or Behavior
	US/BOP	Check Status of AMS System
		Locally check OPERATING BYPASS switch at 1PA54J- OFF
	US	Locally Trip Bistable for Failed Channel
		AMS Arming C-20 PIS-FW447 Operating Bypass (SW12) to TIP1
		Operating Bypass Test Input (SW11) to Test Trip MRF RX149 TRIP
	US/RO	Check P13 Interlock
		 Turbine power greater than 10% Low Turbine Impulse Pressure Permissive P13 window- Not Lit
	US	Refer to Tech Specs
		3.3.1
		NOTE: Initiate Event 2 after Tech Specs have been referenced.

Scenario	No: 00-7	Event No. 2
Event De	scription:	Pressurizer Master Pressure Controller Failure (High)
Time Position		Applicant's Actions or Behavior
	CUES:	Annunciators 1-12-B2 "PZR PORV OR SAF VLV OPEN" 1-12-D2 "PZR PRESS CONT DEV HIGH" 1-12-C6 "PZR PORV DISCH TEMP HIGH" • Spray valves full open
	RO/US	Identify/Report failed PZR Master Pressure Controller
	US	Direct actions for failed PZR Master Pressure Controller
	RO/US	Check PZR Pressure: Verify pressure normal • Take manual control to restore PZR pressure • Ensure spray valves close
	RO	 Check proper operation of the following: Pzr Heaters PZR Spray Valves PZR PORVs
	US	Verify Tech Spec DNB has not been exceeded 3.4.1
	US	Inform SM/Maint of PZR Master Pressure Controller.
		NOTE: When Pzr Pressure has been returned to normal, initiate Event 3.

Comments: _____

· ·

Scenario	No: 00-7	Event No. 3
Event De	scription:	Failure of the 1C RCP #1 Seal.
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciator: (1-7-B3) – RCP SEAL LEAKOFF FLOW HIGH
		PCD Rearing temperature increase
	/	RCP Seal outlet temperature increasing
	RO/US	Identify /Report plant alarms.
	RO	Diagnose RCP seal failure from indications.
	US	Enter 1BwOA RCP-1 "Reactor Coolant Pump Seal Failure"
		Direct operator actions
	RO/US	Check #1 Seal ΔP
		• Seal $\Delta P > 200$ psid
		Check #1 Seal leakoff flow
	.	• #1 seal leakoff flow rate – HIGH
		Check for Eniled Instrument *
		Determine if affected RCP should be stopped
		Maintain at least 9 GPM Seal Injection
		• No. 1 seal leakoll flow <8 GPM • RCP temperatures
		• Seal leakoff flow <6 GPM.
		NOTE: If contacted as local operator: #2 Seal Leakoff flow is 0.3 gpm
	US	Determine need for Unit Shutdown
		Inform SM of status of BOD 10 Seal condition and the need for unit shutdown
		momi Sivi of status of RCF TC Sear condition and the need for unit shutdown.
		NOTE: 10 DOD Soul failure loads into Event A

.

Scenario	No: 00-7	Event No. 4
Event De	scription:	Unit Ramp Down
Time	Position	Applicant's Actions or Behavior
	US	Implement actions of 1BwGP 100-4, "Power Descension"
	US	Direct load reduction
	CREW	Review applicable Precautions, and Limitations and Actions.
	RO	Verify rod position and boron concentration.
		 Determine boric acid flow rate
		• Set IFK-110 BA Flow Cont to desired boration rate. • Set IFX-0110 BA Blender Preset Counter to desired volume.
		Place MU MODE CONT SWITCH to STOP position
		• Set MU MODE SELECT to BOR position
		• Place MAKE-UP CONTROL Switch to START
		• Verify proper operation of valves & BA transfer pump (CV110B open, BA pump is running, CV110A throttles open)
		• Verify BA flow on recorder
	BOP	Initiate turbine load reduction:
		Depress LOAD RATE MW/MIN
		• Enter 5 MW/min
		Depress REF
		Enter power level
		When ready to begin load reduction, depress GO
		• Verify load decreases.

Comments: _____

• • •

Scenario	No: 00-7	Event No. 4
Event De	scription:	Unit Ramp Down
Time	Position	Applicant's Actions or Behavior
	RO	 Monitor power decrease: Monitor reactor power, Tave, ΔI Verify rods more in AUTO to maintain Tave within ± 1.0°F of Tref. If borating: Monitor VCT level Monitor BA Blender counter countdown. Verify boration auto stops at preset value. Return Reactor Makeup System to blended flow at current blended flow.
		NOTE: Following clearly observable plant response from the reactivity changes, proceed with Event 5.
	•	
---------------------------------------	------------	--
Scenario	No: 00-7	Event No. 5
Event De	scription:	Loss of ESF Bus 142
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciators1-22-A7"BUS 142 FD BKR 1422 TRIP"1-22-C7"BUS 142 OVERLOAD OR LOW VOLTAGE"1-22-D9"DG 1B RUNNING UNLOADED"0 Volts and 0 Amps indicated on Bus 142
	US	Transition to BwOA ELEC-3 "Loss of 4KV ESF Bus"
		Direct actions of BwOA ELEC-3
	BOP	Determine Affected Bus
· · · · · · · · · · · · · · · · · · ·	US	Transition to Attachment C
	RO/BOP	 Verify Required ESF Loads Energized on Bus 141 Bus 131X 1A CV Pump 1A RH Pump 1A SI Pump 1A AF Pump 1A & 1C RCFC 1A CS Pump 1A or 0 CC Pump 1A SX Pump 0A VC Train
	BOP	Check Bus 142 Not Faulted • Place breaker control switches in Pull Out - ACB 1423 - ACB 1421 - ACB 1422 - ACB 1424 • Check Bus 142 lockout alarms Not Lit Check DC Crosstie Required
	BOL	 Check battery charger 112 energized Crosstie DC Bus 112 to 212

,

Scenario	No: 00-7	Event No. 5
Event D	escription:	Loss of ESF Bus 142
Time	Position	Applicant's Actions or Behavior
	US	 Refer to Tech Specs Perform the following Tech Spec surveillances within 1 hour 1BwOSR 3.8.1.1 2BwOSR 3.8.1.1 3.8.1 3.8.2 3.8.9 3.8.10
		NOTE: After Tech Specs have been referenced, initiate Event 6.

Scenario	No: 00-7	Event No. 6
Event De	scription:	RCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
<u></u>	CUE	Lowering PZR Level Lowering PZR Pressure Increasing Cnmt Pressure, Humidity and Sump Level
	RO	Manually trip the reactor
	[CT] E-0A	Will not work from the RO panel, must attempt at the Safeguards panel
	US	Implement 1BwEP-0 "Reactor Trip or Safety Injection"
		Direct actions of 1BwEP E-0
	RO	 Verify reactor trip Rod bottom lights LIT Reactor trip & Bypass breakers open (Notes 1A RTB closed and dispatches operator to open) Neutron flux lowering
	BOP	 Verify Turbine Trip Turbine throttle valves closed Turbine governor valves closed Verify power to 4KV busses Bus 141 alive light lit Bus 142 alive light lit
	CREW	 Determine SI needed/actuated If actuated SI First OUT annunciator lit (1-11-B1, 1-11-C1, 1-11-D1, 1-11-E1) SI ACTUATED lit (1-BP-4.1) SI Equipment actuated (SI pumps running, CV Cold leg injection SI8801A/B open) Manually actuate SI

.

Scenario	No: 00-7	Event No. 6	
Event De	scription:	RCS Large Break LOCA	
Time	Position	Applicant's Actions or Behavior	
	CREW	Recognize ADVERSE CNMT conditions when	
		•CNMT pressure > 5psig	
		• CNMT rad level > 10^5 R/hr (Grid 4 4AS120 or 4AS121)	
	RO	Trip RCPs per Operator Action Summary	
•		CC Water lost to RCP	
		CNMT Phase B actuated	
		• ALL of the following exist	
		Controlled RCS cooldown NOT in progress	
		 RCS pressure < 1425 psig HHSI flow > 100 gpm OR SI pump discharge flow > 200 gpm 	
	BOP	Verify FW isolated	
		• FW numps tripped	
		•Isolation monitor lights lit	
		•FW pumps disch valves closed (FW002A-C)	
	RO	Verify ECCS pumps running	
		• CENT Chg numps	
	[CT]	RH pumps	
	E-0J	• SI pumps (Will have to manually start the 1A SI pump)	
	ВОР	Verify Group 2 RCFC Accident Mode Lights Lit	
		• Verify Phase A isolation - Group 3 Monitor lights lit	
- ·		• Verify CNMT Ventilation isolation - Group 6 Monitor lights lit	

.

Scenario	No: 00-7	Event No. 6
Event De	scription:	RCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
	BOP [CT] E-0F	 Verify AF system: AF pumps running (Must dispatch local operator to start the 1B AF Pump) MRF FW160 START AF isolation valves open (1AF13A-H) AF flow control valves throttled (AF005A-H)
		Verify CC Pumps running
	· .	Verify SX Pumps running
		Check Main Steamline Isolation
		• Check SG pressure > 640 psig
		• Check CNM1 pressure on 1PK-937 OK 1P1-CS934 thru 937 is >8.2 psig
	BOP	Check if CNMT Spray is required
	POP	CNMT pressure > 20 psig Stop all RCPs Check Group 6 CS monitor lights lit Check Group 6 monitor Phase B Isolation lights lit Check CS eductor suction flow >15 gpm on 1FI-CS013 & 14 Check CS eductor additive flow > 5 gpm on 1FI-CS015 & 16
	BOP	Verify AF flows
1		•AF flow > 500 gpm
		•SG levels maintained between 10% (31%) and 50%
		•NR levels NOT increasing in an uncontrolled manner

7

•

Scenario	No: 00-7	Event No. 6
Event De	escription:	RCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
	RO	Verify ECCS valve alignment & flows
		• Group 2 Cold Leg Injection Monitor lights lit.
		• High Head SI flow >100 gpm
		• RCS pressure <1700 psig
		• SI Pump discharge flow > 200gpm
		Check RCS pressure < 325 psig
		 Check RH pump discharge flow > 1000 gpm
		Check at least ONE PZR PORV relief path available:
		• At least ONE PORV Isol valve energized.
		PORV in AUTO
		• Associated Isol valve open
·	BOP	Verify generator trip
		• OCB 1-8 and 7-8 open
		• PMG output breaker open
	BOP	Verify DG 1A running
		DG SX valves 1SX169A open
		• Dispatch operator to locarly check TA DO
		Ventilation systems aligned for amorganou
		Control Room
		• Aux Bldg.
		Fuel Handling Bldg.
		 Aux Bldg. Fuel Handling Bldg.

.

. .

Scenario	No: 00.7	Front No. 6
Eugent D		DOS Loren Drock LOCA
Event Do	escription:	KCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
	RO	Check PZR sprays & PORVs closed
		Check BCP status none running
		 Check RCS Cold Leg temps trending to or stable at 557°F
		• Throttle AF flow if required
		Report RCS cold leg temperatures low due to ECCS injection flow
	RO	Check RCP status:
		None running
	BOP	Check SG secondary boundary
	201	•All SG pressure stable
	· ·	Check SG tubes intact
		•All secondary rad monitors < ALERT setpoint
	CREW	Check if RCS is Intact
		Diagnose LOCA
		• CNMT are rad monitors levels increasing or in ALERT
		• $Grid 4 AS101, 4AS202, 4AS303 (IR1-AR014)$ • $Grid 4 AS111 (IPT-AP011)$
		$\mathbf{Grid} 4 \mathbf{A} \mathbf{S} 112 (\mathbf{1RT} \mathbf{A} \mathbf{R} 0 12)$
		• Grid 4 AS120 (1RT-AR020)
		• Grid 4 AS121 (1RT-AR021)
		• CNMT pressure > 3.4 psig
		$\sim CNMT$ floor water level > 5 inches
		• CIVINI HOOF WATER LEVEL > 5 HICHES
	US	Transition to 1BwEP-1 "Loss of Reactor or Secondary Coolant"
		Direct actions of 1BwFP-1
	.1	

~

Scenario	No: 00-7	Event No. 6
Event De	scription:	RCS Large Break LOCA
Time	Position CREW	Applicant's Actions or Behavior Check Status of RCPs None running
	BOP	 Check SG secondary boundaries intact Check pressure in all SGs No SG pressure decreasing in uncontrolled manner No SG completely depressurized Check intact SG levels Narrow range levels > 10% (31%). If not flow is maintain > 500 gpm Control feed flow to maintain intact SG levels between 10% (31%) and 50% Check narrow range levels NOT increasing in an uncontrolled manner.
	CREW	 Check secondary radiation trends normal SJAE GS exhaust 1PR27J Grid 1 1PS027 SG Blowdown 1PR08J Grid 1 1PS108 Main Steam: 1RT-AR022 & 1RRT-AR023 for each SG, Grid 1 4AA122/123, 4AB222/223, 4AC322/323, 4AD422/423 Main Steam Penetration 1A/1D 1RT-AR024 Grid 4 4AA124 Main Steam Penetration 1B/1C 1RT-AR024 Grid 4 4AB124
	RO	 Check PZR PORVs Power to PORV Isol valves 1RY8000A/B energized PORVs RY455A & RY456 CLOSED At least ONE PORV Block valve RY8000A OR RY8000B OPEN

Scenario	No: 00-7	Event No. 6
Event De	scription:	RCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
	CREW	Check if ECCS flow should be reduced
		RCS Subcooling acceptable
		Iconic Display
		OR
		ATTACHMENT A, FIGURE 1BwEP 1-1
		 Secondary heat sink Total feed flow to SGs > 500 gpm OR
		• NR level in at least ONE intact SG > 10% (31%)
		RCS Pressure stable or increasing
		PZR level >12% (28%)
		Determine ECCS reduction criteria NOT met (subcooling likely)
	CREW	Check if CNMT Spray should be stopped
		 CS Pumps running Reset CS signal
		• When Spray Additive tank LO-2 level lights L11, close eductor spray additive valves ICS019A/B
		 When CNMT pressure is < 15 psig AND CS has operated for at least 2 hours, continue with steps to secure CS
	RO	Check if RH Pumps should be stopped Reset SI Depress BOTH SI RESET pushbuttons
		 Verify SI ACTUATED permissive light NOT lit Verify AUTO SI BLOCK permissive light LIT
		Determine RH pumps should NOT be stopped with RCS pressure < 325 psig

~

.

17

•

Scenario	No: 00-7	Event No. 6
Event De	scription:	RCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
	CREW	Check RCS and SG Pressures for Faulted SG Indications
		• Verify pressure in all SGs stable or increasing
		• Pressure in RCS stable or decreasing
	BOP	Check if DG should be stopped
-		•ESF and Non-ESF Busses power by Offsite
		• Stop 1B DG per 1BwOP DG-12
		• • • • • • • • • • • • • • • • • • •
	CREW	Evaluate plant status
		• Verify Cold Leg Recirc capability
		• Check Aux Building Radiation monitors
		• Reset Containment Isolation Phase A if necessary
		• Place H2 monitors in service per 1BwOP PS-9
		Obtain samples RCS activity and boron concentration
		Containment sump and atmosphere
		• Evaluate plant equipment
		• Trip all Heater Drain Pumps
		• Shutdown Feedwater pumps, Condensate pumps and Circulating Water Pumps
		• Shutdown chiller on non-operating VC train
	RO	 Check if RCS cooldown and depressurization required RCS pressure > 325 psig If NOT check RHR flow > 1000 gpm When RWST level < 46% for transition to ES-1.3

~

Scenario No: 00-7 Event No. 6		
Event De	scription:	RCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
		Transition to 18wEP ES 1.2 "Post LOCA Cooldown and Depressurization"
	05	Transition to TBWER ES-T.2 Fost EOCA Cooldown and Depressunzation
		Direct actions of 1BwEP ES-1.2
	RO	Reset SI if necessary
		 Depress both SI reset pushbuttons Verify SI ACTUATED permissive light – NOT LIT Verify AUTO SI BLOCKED permissive light – LIT
	RO/BOP	Reset Containment Isolation
		 Reset CNMT Isol Phase A Reset CNMT Isol Phase B Reset CNMT Vent Isol Check SACs – ANY RUNNING Open instrument air CNMT isol valves. 11A065 11A066
	BOP	Verify ALL AC busses energized
		 Bus 141 & 142 (Bus 142 unavailable) Bus 143 & 144 Bus 156, 157, 158, 159
	RO	Check if RH pumps should be stopped
		Check RH pumps suction aligned to RWST
		 Check RCS pressure > 325 psig If NOT, DO NOT stop RH pumps
		 If > 325 psig AND pressure stable or increasing Stop RH pumps and place in standby
l	I	

Scenario 00-7

.

05/21/00 10:37 PM

.

. .

Ŧ.

-

••

Scenario	No: 00-7	Event No. 6
Event De	scription:	RCS Large Break LOCA
Time	Position	Applicant's Actions or Behavior
	BOP	 Check Intact SG levels Narrow range levels >10% (31%) Control feed flow to maintain levels – BETWEEN 10% (31%) and 50% Narrow range levels - NOT increasing in an uncontrolled manner
	CREW	Initiate RCS cooldown to 200 F
		NOTE: Once it is determined that a cooldown can be initiated the scenario can be terminated.

Simulatio	n Facility <u>Braidwood</u>	Scenario N	o.: 00-8	Operating Test No.:	3	
Examiners:			Operators:		<u>SRO</u>	
			•		PO RO	
					<u>KO</u>	
					BOP	
Objective	s: To evaluate	the applicants abi	lity to use Normal, A	bnormal, Emergency and a	larm response	
	procedures to	o respond to a				
Initial Co	nditions: IC-31, 90%	power, Steady St	ate, 1A Charging pur	np and 1B AFW pump OOS	S	
Turnover	Unit 1 is our	rently at 90% nov	ver 14 Charging pur	nn is OOS for numn bearing	replacement and is	
	expected bac	k next shift. Curr	ext shift. Currently in Tech Spec 3.5.2 Condition A. There are 5 days left on the			
	Completion	Time. The 1B AF	e. The 1B AFW Pump is OOS for a modification to the starting circuit and is			
	expected bac	k in 3 to 4 hours.	n 3 to 4 hours. Currently in Tech Spec 3.7.5 Condition A. There are 60 hours left			
	on the Comp	letion Time. Elec	trical Generation has	requested a load increase to	o full power as soon	
	as possible a	t 5Mw/min. Unit	2 is in a Refueling or	utage and they are making p	reps to lift the head.	
Event No	Mair.	Event Type*		Description		
Preload	RP01	M BOP	Failure of the react	tor to trip (Auto and Manual])	
(NOTE 1)	RP02A	RO		1 .	,	
	RP02B	SRO				
Preload	RD09, 18	C RO	Auto rod speed fai	lure at 18 steps/min.		
(NOTE I) Preload	MS03A 100 Trg 3	C BOP	SG Safety failure (ASGe		
(NOTE 1)	MS03B 100 Trg 3	RO	50 Salety failure (4 503)		
	MS03C 100 Trg 3	SRO				
Preload	1A CV Pump PTL & OOS		1A CV Pump OOS			
(NOTE 1)	1B AFW Pump PTL &		1B AFW Pump OC	DS		
Preload	Imbedded Batch File	С ВОР	1A AFW pump fai	l to Auto start		
(NOTE 1)		RO				
		SRO	D	1000/		
1		SRO	Ramp up turbine p	ower to 100% at 5 MW/min		
		R RO	Raise reactor powe	r using rods and/or dilution	·····	
2	CV01B	C RO	1B Charging Pump	o trip		
		SRO		1		
3	RX18E, 650	I RO	A Loop Hot Leg R	TD failure high		
4	DV02C 4.9mlbm/br		(NOTE 2)	<u>Character</u> (1)	1 1)	
4	KAUSU, 4.8midm/nr	SRO	IB SG Steam Flow	Channel Failure (controllin	ig channel)	
5	EG05A	M BOP	1E Main Power Tra	ansformer Failure		
		RO				
6	Droloadad	SRO M BOD				
0	Preloaded	RO	AIWS			
		SRO				
7	TRG! 3	M BOP	4 Faulted SGs			
		SRO				
*(N)ormal	(R)eactivity (1)	nstrument. (C)	omponent. (M)ajor	Transient		
NOTE 1:	Run BATCH FILE	for all Preload BA	TATWS			
NOTE 2: RP20 (OPEN/CLOSE) RX014 (Trip) RX136 (Trip) RX013 (Trip) RX135 (Trip) RX016 (Trip)						
		KXUI5 (Trip	<u>ן ר</u>			

SCENARIO 00-8 OVERVIEW

Unit 1 is at 90% power. Electric Generation has requested load increase to full power as soon as possible. The 1A Charging Pump is OOS for bearing replacement and the 1B AFW Pump is OOS for a modification installation. Unit 2 is in a refueling outage and they are making preps to lift the head.

Once the crew starts the power increase, a failed auto rod speed failure may become evident. If this is the case, the crew will put the Control Rods into manual.

Following clearly observable plant response from the reactivity changes due to the power increase, the 1B Charging pump will trip for no apparent reason. The crew should isolate letdown and reference the applicable Annunciator Response manuals and dispatch a local operator to investigate. The crew should also reference Tech Specs due to no charging pumps available. The local operator will report back that a maintenance worker hit the breaker trip with a bar that he was using to erect scaffolding. There is nothing wrong with the breaker or the pump. The crew should re-start the pump and re-establish letdown.

Once letdown is restored, the "A" Loop Hot Leg RTD will fail high. This will require the crew to enter BwOA INST-2 Attachment A and take the appropriate actions which include placing control rods in manual, defeating the failed channel, tripping bistables and referencing Tech Specs.

After the actions of BwOA INST-2 are complete, the controlling steam flow channel for the 1B SG will fail low. This will require the crew to take manual control of the 1B SG FRV and enter BwOA INST-2 Attachment H. The crew will select an operable channel for the 1B SG steam flow and return the FRV back to automatic control.

Shortly after the crew gains control of the 1B SG level, a catastrophic failure of the 1E Main Power Transformer will occur resulting in a trip of the Main Generator. The reactor will fail to trip resulting in the crew transitioning to BwFR-S.1. Compounding the problem, Auto rod speed will fail to 18 steps/min (rods may be in manual due to rod speed failure previously detected) requiring the crew to take manual control of rods. As steam generator pressure increases due to the ATWS, a safety valve on each of the SGs will fail open resulting in an uncontrolled depressurization of all SGs. The crew will transition from BwFR-S.1 to E-0. From E-0 the crew will transition to E-2 and then to BwCA-2.1

Critical Tasks

- -

FR-S.1--B: Start AFW pumps within 60 seconds of the ATWS condition.

FR-S.1--C: Insert negative reactivity into the core by at least one of the following methods before completing the immediate-action steps of FR-S.1:

- De-energize the control rod drive MG sets
- Insert RCCAs
- Establish emergency boration flow to the RCS

Scenario No: 00-	8 Event No. 1
Event Description:	Ramp up turbine and reactor power.
Time Position	Applicant's Actions or Behavior
CUE:	Request from System Operator to increase power to 100%
US	Implement actions of 1BwGP 100-3, "Power Ascension"
US	Direct increase to 100% power at desired rate.
CREW	Review applicable Precautions, and Limitations and Actions.
RO	Verify rod position and boron concentration.
	 Initiate dilution, if required. (BwOP CV-5) Determine desired PW flow rate. Set 1FK-111 PW/Total Flow Cont. to desired dilution rate. Set 1FY-0111 Primary Water Control Preset Counter to desired volume. Place MU MODE CONT SWITCH to STOP position. Set MU MODE SELECT to DIL or ALT DIL position. Place MAKE-UP CONTROL Switch to START Verify proper operation of valves & PW pump (CV111A & 111B open, PW pump is running, CV110B opens [if ALT DIL]) Verify PW flow on recorder
BOP	 Initiate turbine load increase: Depress LOAD RATE MW/MIN Enter desired load rate Depress REF Calculate desired power level Enter power level When ready to begin load increase, depress GO Verify load increases.
RO	Monitor power increase: • Monitor reactor power, Tave, ΔI

- •

.*

¥

Scenario	No: 00-8	Event No. 1
Event De	escription:	Ramp up turbine and reactor power.
Time	Position	Applicant's Actions or Behavior
		 Verify rods more in AUTO to maintain Tave within ± 1.0°F of Tref. If diluting: Monitor VCT level Monitor Primary Water Control counter countdown. Verify dilution auto stops at preset value. Return Reactor Makeup System to blended flow at current blended flow.
		NOTE: Following clearly observable plant response, Event 2 may be started.

Scenario	No: 00-8	Event No. 2
Event De	scription:	1B Charging Pump Trip
Time	Position	Applicant's Actions or Behavior
	CUES:	Annunciators 1-9-A3 "CHG PUMP TRIP" 1-9-D3 "CHG LINE FLOW HIGH LOW"
		Lowering PZR level Increasing Letdown temperatures
	RO	Identify/ Report loss of the 1B CHG Pump Recognize no available CHG pumps • Isolate letdown Reference Annunciator Response Guidelines • If no seal injection go to 1BwOA RCP-2 "Loss of Seal Injection"
	· · · · · · · · · · · · · · · · · · ·	NOTE: Report from local operator states maintenance worker hit the breaker while erecting scaffolding DMF CV01B
	RO	Verify suction source to 1B Charging Pump. Start 1B CHG Pump

Scenario No: 00-8		Event No. 2
Event Description:		1B Charging Pump Trip
Time	Position	Applicant's Actions or Behavior
		 Establish Normal CV Letdown per 1BwOP CV-17 Verify/Close 1CV8149A,B,C Letdown Orifice Isolation Valves Aign CC to the 1A Letdown HX Verify/Open 1CC9452A&B CC Inlet/Outlet Isolation valves Place the IPCV-CV131 Ltdn Line Press Cont VIv in manual and raise the demand to 40% Raise 1TCV-CC130A Ltdn HX Out Temp Cont VIv in manual and raise the demand to 60% Verify/Open 1LCV-CV460 Ltdn Line Isol VIv Verify/Open 1LCV-CV459 Ltdn Line Isol VIv Verify/Open for the 1A Regen HX 1CV8324A, Chg to Regen HX 1A Isol VIv Verify/Open 1CV8160 Ltdn Line Cnmt Isol VIv Verify/Open 1CV8160 Ltdn Line Cnmt Isol VIv Verify/Open 1CV8152 Ltdn Line Cnmt Isol VIv Verify/Open 1CV8152 Ltdn Line Cnmt Isol VIv Verify/Open 1CV381B Ltdn Reheat HX Bypass Flow Cont VIv Verify/Open 1CV8401A Ltdn to Ltdn HX 1A Isol VIv Verify/Open 1CV8401A Ltdn to Ltdn HX 1A Isol VIv Verify/Open 1CV8401A Ltdn to Ltdn HX 1A Isol VIv Verify/Open 1CV8401A Ltdn Kegen HX Verify/Open 1CV8401A Ltdn Kegen HX Verify/Open 1CV8401A Ltdn Kegen HX Verify/Open 1CV84015 Chg to RC Loop 1A/1B Verify/Open 1CV81678105 Chg Line Cnmt Isol VIv Adjust in Manual 1FK-121 Cent Chg Pp flow control VIv Controler to establish approximately 100 gpm charging flow. Adjust 1CV182 Chg Hdr Back Press Cont VIv to obtain 8-10 gpm seal injection flow. Open 1CV8149A/B/C Ltdn Orifice 1A/B/C Isol VIv as required to obtain desired Ltdn Flow Adjust 1TCV-CV131 Ltdn Line Press Cont VIv as required to control Ltdn Press as indicated on 1PI-131 Ltdn Line Press. Adjust 1TCV-CC130 as required to obtain desired temperature (90°F-115°F) Place 1FCV-121 in Auto Place 1FCV-121 in Auto
		NOTE: When Letdown has been established initiate Event 3.

. •

÷

,

Scenario	No: 00-8	Event No. 3
Event De	scription:	1A Loop Hot Leg RTD Failure (High).
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciator1-14-D1 "TAVE CONT DEV HIGH" 1-14-D3 "LOOP 1D TAVE LOW" 1-14-D5 "LOOP 1D △T DEV LOW" 1-14-E2 "AUCT TAVE HIGH"Automatic rod motion in
	RO	Determine failed channel Place rod control in manual
	US	Implement BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment A "RCS NARROW RANGE RTD CHANNEL FAILURE" and direct operator action.
	RO	 Place Rod Bank Select Switch in MANUAL Manually defeat failed RTD Select failed Tave channel with TAVE DEFEAT switch Select failed ΔT channel with ΔT DEFEAT switch Select an operable RTD channel to the ΔT recorder Check if rod control can be placed in AUTO TURBINE LOW POWER INTLK C5 – Not Lit Tave-Tref deviation – Stable and within 1°F Place Rod Bank Select switch in AUTO Check PZR Level PZR level – normal and stable
	US	 Locally trip bistables for the failed channel OPΔT Trip TB411G OPΔT Runback TB411H OTΔT Trip TB411C OTΔT Runback TB411D Low Tave TB412G Lo-Lo Tave TB412D

...

•

Scenario	No: 00-8	Event No. 3
Event De	escription:	1A Loop Hot Leg RTD Failure (High).
Time	Position	Applicant's Actions or Behavior
	RO	 Check P12 interlock Tave greater than 550°F LO-2 TAVE STM DUMP INTLK P12 – Not Lit
	US	Refer to Tech Specs
		NOTE: Once bistables have been tripped, initiate Event 4.

Scenari	o No: 00-8	Event No. 4
Event [Description:	1B SG Steam Flow Channel Failure (Controlling)
Time	Position	Applicant's Actions or Behavior
	CUE:	 Annunciator 1-15-B4 "S/G 1B FLOW MISMATCH FW FLOW LOW" FT-522 indication reading low Feedwater Regulating Valve throttling closed FW flow decreasing SG level decreasing below program
	BOP/US	Identify/Report steam flow channel FT-522 failure Take MANUAL control of Feed reg. valve and balance Feed flow with Steam flow to stabilize SG level, as necessary.
	US	Direct that the turbine ramp be slowed or stopped during troubleshooting.
	US	Implement 1BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment H "STEAM FLOW CHANNEL FAILURE" and direct operator action.
	BOP/US	 Check affected SG levels normal Place feed reg. valve in manual Verify adequate feedwater ΔP Restore SG level to a stable condition
		Establish AUTO level control Verify steam pressure channels PT-525 and PT-526 normal
	US	Inform SM/Maint of failure of SG 1B steam flow channel FT-522
		NOTE: Two minutes following return of SG level control to auto, Proceed to Event 5

...

۰.

.....

Scenario No: 00-8	Event No. 5, 6
Event Description:	1E Main Power Transformer Failure (5) ATWS (6)
Time Position	Applicant's Actions or Behavior
CUE	Annunciator 1-19-E2 "GENERATOR LOCKOUT RELAY TRIP" 1-19-A10 "MAIN XFMR 1E/1W FD BRKR TRIP" Main Generator Trip Main Turbine Trip
CREW	Determine requirement for a Reactor Trip Attempt to trip the reactor at both the reactor panel and the safeguards panel
US	Transition to 1BwFR-S.1 "Response to Nuclear Power Generation/ ATWS" Direct actions of 1BwFR-S.1 NOTE: When SG pressure increases to the lift setpoint of the SG Safeties, one on each SG will fail
	open
RO [CT] FR-S.1- C	 Verify Reactor Trip Rod bottom lights lit Reactor trip and bypass breakers open Neutron flux decreasing If the reactor will not trip, then allow control rods to insert automatically until rod speed is less than 48 steps/min, then manually insert control rods. NOTE: Rod speed is failed to 18 steps/min
BOP	 Verify Turbine Trip All turbine throttle valves closed All turbine governor valves closed
[CT] FR-S.1- B	 Determines that no AFW pumps are running Manually starts the 1A AF Pump

. •

Scenario	No: 00-8	Event No. 5, 6
Event Description:		1E Main Power Transformer Failure (5)
	·····	ATWS (6)
Time	Position	Applicant's Actions or Behavior
	RO	Initiate Emergency Boration of RCS
	[CT]	 Initiate emergency boration
	FR-S.1	• Open 1CV8104
	C	• Start boric acid transfer pump
		Check emergency boration flow greater than 30 gpm
		• Verify charging flow greater than 30 gpm
		• Check PZR pressure less than 2335 psig
	BOP	Verify Containment Ventilation Isolation
		• Group 6 CNMT Vent Isol monitor lights – LIT
	RO	Verify Reactor Subcritical
		• PR channels less than 5%
		• IR channels negative startup rate
	BOP	Isolate Steam Dumps
		Place steam dump BYPASS INTERLOCK switches to OFF RESET
······	RO	Check if the Following Trips Have Occurred
		Reactor Trip
	2 2	Dispatch local operator to open reactor trip breakers and secure rod drive MG sets.
		• Turbine Trip
	BOP	Check SG Levels
		 Narrow Range level in at least one SG Greater than 10% (31%) Control feed flow to maintain narrow range level between 10% (31%) and 50%
		NOTE: Open Rx Trip Breakers here.
	BOP	Check SG blowdown isolation valves closed (1SD002A-H)

Scenario	No: 00-8	Event No. 5, 6
Event Description:		1E Main Power Transformer Failure (5) ATWS (6)
Time	Position	Applicant's Actions or Behavior
	RO	Verify all Dilution Paths Isolated
		 Reactor makeup dilution valves closed 1CV111A 1CV111B Verify BTRS Mode Selector switch is OFF Dispatch operators to verify dilution paths isolated 1CV8441 1CV8435 1CV8453
		• 1AB8629A
	US	Implement 1BwEP-0 "Reactor Trip or Safety Injection" Direct actions of 1BwEP E-0
	RO	 Verify reactor trip Rod bottom lights LIT Reactor trip & Bypass breakers open Neutron flux lowering
	BOP	Verify Turbine Trip
		 Turbine throttle valves closed Turbine governor valves closed
		Verify power to 4KV busses
		 Bus 141 alive light lit Bus 142 alive light lit
	CREW	Determine SI needed/actuated

Scenario	No: 00-8	Event No. 5, 6
Event Description:		1E Main Power Transformer Failure (5) ATWS (6)
Time	Position	Applicant's Actions or Behavior
		 If actuated SI First OUT annunciator lit SI ACTUATED lit SI Equipment actuated Manually actuate SI
	CREW	Recognize ADVERSE CNMT conditions when •CNMT pressure > 5psig •CNMT rad level > 10 ⁵ R/hr (Grid 4 4AS120 or 4AS121)
	RO	Trip RCPs per Operator Action Summary CC Water lost to RCP CNMT Phase B actuated ALL of the following exist Controlled RCS cooldown NOT in progress RCS pressure < 1425 psig High Head SI flow > 100 gpm OR'SI pump discharge flow > 200 gpm
	BOP .	Verify FW isolated •FW pumps tripped •Isolation monitor lights lit •FW pumps disch valves closed (FW002A-C)
	RO	 Verify ECCS pumps running CENT Chg pumps RH pumps SI pumps
	JOI	• Verry Group 2 Refe Accluent Mode Lights Lit

. -

Scenario	No: 00-8	Event No. 5, 6					
Event Description:		1E Main Power Transformer Failure (5) ATWS (6)					
Time	Position	Applicant's Actions or Behavior					
		 Verify Phase A isolation - Group 3 Monitor lights lit Verify CNMT Ventilation isolation - Group 6 Monitor lights lit 					
	BOP	 Verify AF system: AF pumps running AF isolation valves open (1AF13A-H) AF flow control valves throttled (AF005A-H) Verify CC Pumps running Verify SX Pumps running Check Main Steamline Isolation Check SG pressure > 640 psig Check CNMT pressure on 1PR-937 OR 1PI-CS934 thru 937 is >8.2 psig Verify MSIV and MSIV Bypass valves closed 					
	ВОР	Check if CNMT Spray is required CNMT pressure > 20 psig Stop all RCPs Check Group 6 CS monitor lights lit Check Group 6 monitor Phase B Isolation lights lit Check CS eductor suction flow >15 gpm on 1FI-CS013 & 14 Check CS eductor additive flow > 5 gpm on 1FI-CS015 & 16					
	BOP	 Verify AF flows AF flow > 500 gpm SG levels maintained between 10% (31%) and 50% NR levels NOT increasing in an uncontrolled manner 					
	RO	Verify ECCS valve alignment & flows					

. . . .

Scenario	No: 00-8	Event No. 5, 6
Event Description:		1E Main Power Transformer Failure (5) ATWS (6)
Time	Position	Applicant's Actions or Behavior
		 Group 2 Cold Leg Injection Monitor lights lit. High Head SI flow >100 gpm RCS pressure <1700 psig SI Pump discharge flow > 200gpm Check RCS pressure < 325 psig
		 Check RH pump discharge flow > 1000 gpm Check at least ONE PZR PORV relief path available: At least ONE PORV Isol valve energized. PORV in AUTO Associated Isol valve open
	BOP	 Verify generator trip OCB 1-8 and 7-8 open PMG output breaker open
	BOP	 Verify DG 1A running DG SX valves 1SX169A open Dispatch operator to locally check 1A DG Ventilation systems aligned for emergency Control Room Aux Bldg. Fuel Handling Bldg.
	RO	Check PZR sprays & PORVs closed RCS temperature control

Scenario	No: 00-8	Event No. 5, 6
Event Description:		1E Main Power Transformer Failure (5) ATWS (6)
Time	Position	Applicant's Actions or Behavior
		 Check RCP status - none running Check RCS Cold Leg temps trending to or stable at 557°F Throttle AF flow if required Report RCS cold leg temperatures low due to ECCS injection flow
	RO	Check RCP status: None running
	BOP	 Check SG secondary boundary NO SG Pressure decreasing in an uncontrolled manner

Scenario	No: 00-8	Event No. 7
Event Description:		Four Faulted SGs ECA-2.1
Time	Position	Applicant's Actions or Behavior
	US	Transition to 1BwEP-2 "Faulted Steam Generator Isolation"
		Direct actions of 1BwEP-2
	ВОР	Check Main Steamline Isolation All MSIVs and MSIV bypass valves closed
		 Check if any SG Secondary Pressure Boundary is Intact Check pressure in all SGs – any SG pressure stable or increasing (NO)
	US	Transition to 1BwCA-2.1 "Uncontrolled Depressurization of All Steam Generators"
		Direct actions of 1BwCA-2.1
	BOP	 Check Secondary Pressure Boundary Check MSIVs closed IMS001A IMS001B IMS001C IMS001D Check MSIV bypass valves closed IMS101A IMS101B IMS101C IMS101C IMS101D Check SG PORVs closed IMS018A IMS018B IMS018C IMS018D Check FW to all SGs isolated Check SG blowdown isolation valves closed (ISD002A-H) Check SG blowdown sample isolation valves closed (ISD005A-D)
	RO/BOP	Control Feed Flow to Minimize RCS Cooldown
	KO/DOF	

: -•

Scenario	No: 00-8	Event No. 7
Event Description:		Four Faulted SGs ECA-2.1
Time	Position	Applicant's Actions or Behavior
		 Check cooldown rate in RCS cold legs less than 100°F in any 1 hour period If C/D >100°F/HR then decrease feed flow to 45 gpm for each SG. Check narrow range level in all SGs less than 50%
		• Check RCS hot leg temperatures stable or decreasing
	RO	Check status of RCPs
	BOP	Monitor AF Pump Suction Pressure • AF PUMP SX SUCT VLVS ARMED alarm - Not Lit
	RO	 Check PZR PORVs and Isolation Valves PORV isolation valves energized PORVs closed PORV isolation valves – at least one open
	BOP	 Check Secondary Radiation Reset CNMT Isolation Phase A Request Chemistry to sample SGs Check RM-11 for normal plant conditions
	BOP	Check if RH Pumps Should be Stopped RH pumps running RH pumps aligned to RWST RCS pressure >325 psig RCS pressure stable or increasing Reset SI Depress both SI reset pushbuttons Verify SI ACTUATED permissive light – Not Lit Verify Auto SI Blocked permissive light Lit Stop RH pumps and place in standby
	BOP	Check if CS Should be Stopped (none running)

-

Scenario No:	00-8	Event No. 7
Enert Description		Event No.
Event Descri	ption:	Four Faulted SGs ECA-2.1
Time P	Position	Applicant's Actions or Behavior
		Check RWST Level greater than 46%
		Check if SI Accumulators Should be Isolated (RCS pressure >125 psig)
CF	REW	Check if ECCS Flow Should be Reduced ICONICS Or Figure in procedure RCS Pressure stable or increasing PZR Level >12% (28%)
		NOTE: Once the crew has made a determination on ECCS flow reduction, the scenario can be terminated.

Simulation Fa	cility <u>Braidwood</u>	Scenario No.: 00-9	Operating Test No.:	3	
 Examiners:		Operat	ors:	SRO	
	<u></u>			<u> RO</u>	
	· · · · · · · · · · · · · · · · · · ·			BOP	
Objectives:	To evaluate the a respond to a require, a SG tube	pplicants ability to use Normal, Abr lest to raise power, radiation monitor e leak which degrades to a SGTR, ar	ormal, Emergency and alarm failure, SG Narrow range le d a main steam line break.	n response proc evel failure, Pzr	edures to level

Initial Conditions: IC-31; 90% Power, Equilibrium. Xenon, Steady State. 1A AFW pump OOS

Turnover: Unit 1 is at 90% power, Steady State. The 1A AFW pump is OOS for motor bearing replacement. Currently in Tech Spec 3.7.5 Condition A. The pump is expected back in 3 to 4 hours. There are 60 hours left on the Completion Time.

Event	Malf.	E	vent	Event
No.	No.	T	ype*	Description
Preload	1A AFW Pump in			1A AFW pump OOS
	PTL & OOS			
1		N	BOP	Raise turbine power to 100% at 5 MW/min
			SRO	
		R	RO	Raise reactor power using rods and/or boration
2	RM01AU 5	I	BOP	1D Main Steam Line radiation monitor failure
			SRO	
3	RX06C, 0	Ι	BOP	1A SG Narrow Range level channel failure (LT-519)
			SRO	(NOTE 1)
4	RX13A, 0	I	RO	Pressurizer Level Channel LT-459 fail low
			SRO	(NOTE 2)
5	TH03D, 20	C	BOP	1D SG Tube Leak
			RO	
			SRO	
6	TH03D, 450	M	BOP	1D SGTR (after crew determines shutdown required)
			RO	
			SRO	
7	MS04D, 100	С	BOP	1D SG atmospheric relief fail open
			RO	
			SRO	
8	MS07A, .5	м	BOL	IA Main Steam Line steam break (once C/D commenced in E-3)
			KU SPO	
			SKU	

*(N)ormal,

\$

(R)eactivity

vity (I)nstrument,

(C)omponent, (M)ajor Transient

NOTE 1: RP21 (OPEN/CLOSE) RX051 (Trip) RX052 (Trip)

NOTE 2: RP20 (OPEN/CLOSE) RX029 (Trip)

SCENARIO 00-9 OVERVIEW

Unit 1 is at 90% power, Steady State. The 1A AFW pump is OOS for motor bearing replacement. Currently in Tech Spec 3.7.5 Condition A. The pump is expected back in 3 to 4 hours. There are 60 hours left on the Completion Time. Electric Generation has requested an increase in power to 100% at 5MW/min.

Following clearly observable plant response from the reactivity changes, the 1D Main Steam Line radiation monitor will fail. The crew will enter the RM-11 annunciator responses and determine that the Rad Monitor has failed.

After the crew has taken the actions for the failed rad monitor, the 1A SG Narrow Range Level Channel (LT-519) will fail low. The crew will enter BwOA INST-2 Attachment E. The crew will take manual control of the 1A FRV, restore SG level, trip applicable bistables and reference Tech Specs. The crew will also switch controlling channels and return the 1A SG FRV to Auto.

Once the actions for the failed SG level channel are complete, Pzr level channel 459 will fail low. The crew will enter BwOA INST-2 Attachment C to select an operable channel, restore Pzr level to normal and restore letdown. The crew will also trip bistables and reference Tech Specs.

When the crew is determines that the tripping of the Pzr level bistables will not generate a reactor trip or SI, the 1D Steam Generator will develop a 20 gpm leak. The crew will enter BwOA SEC-8 and determine that a unit S/D is required. The crew will initiate a S/D to MODE 3 within 6 hours and reference Tech Specs.

After the crew determines that a Unit shutdown is required per SEC-8, the SGTL on the 1D SG will increase to 450 gpm. At the same time, the 1D SG atmospheric relief valve will fail open. The crew will trip the reactor, manually initiate a Safety Injection and transition to BwEP E-0.

From E-0 the crew will transition to BwEP E-3. After the crew has commenced a cooldown in E-3, the 1B main steam line will develop a large steam break. The crew will transition to BwEP E-2 per the foldout page. When the crew completes BwEP E-2 and transitions back to E-3 the scenario will be complete.

Critical Tasks

E-2--A: Isolate the faulted SG before transition out of E-2.

E-3--A: Isolate feedwater flow into and steam flow from the ruptured SG before a transition to ECA-3.1 occurs.

Scenario No	o: 00-9	Event No. 1
Event Desc	ription:	Ramp up turbine and reactor power.
Time	Position	Applicant's Actions or Behavior
	CUE:	Request from System Operator to increase power to 100%
ľ	US	Implement actions of 1BwGP 100-3, "Power Ascension"
t	JS	Direct increase to 100% power at desired rate.
(CREW	Review applicable Precautions, and Limitations and Actions.
F	१०	Verify rod position and boron concentration.
		 Initiate dilution, if required. (BwOP CV-5) Determine desired PW flow rate. Set 1FK-111 PW/Total Flow Cont. to desired dilution rate. Set 1FY-0111 Primary Water Control Preset Counter to desired volume. Place MU MODE CONT SWITCH to STOP position. Set MU MODE SELECT to DIL or ALT DIL position. Place MAKE-UP CONTROL Switch to START Verify proper operation of valves & PW pump (CV111A & 111B open, PW pump is running, CV110B opens [if ALT DIL]) Verify PW flow on recorder
E	BOP	 Initiate turbine load increase: Depress LOAD RATE MW/MIN Enter desired load rate Depress REF Calculate desired power level Enter power level When ready to begin load increase, depress GO Verify load increases.
Comments	S:	

÷

Scenario	No: 00-9	Event No. 1
Event De	scription:	Ramp up turbine and reactor power.
Time	Position	Applicant's Actions or Behavior
	RO	 Monitor power increase: Monitor reactor power, Tave, △I Verify rods more in AUTO to maintain Tave within ± 1.0°F of Tref. If diluting: Monitor VCT level Monitor Primary Water Control counter countdown. Verify dilution auto stops at preset value. Return Reactor Makeup System to blended flow at current blended flow.
		NOTE: Following clearly observable plant response, Event 2 may be started.

.

Scenario No: 00-9		Event No. 2
Event Description:		1D Main Steam Line Radiation Monitor Failure
Time	Position	Applicant's Actions or Behavior
	CUES:	RM-11 Alarm
	BOP	Acknowledge RM-11 and reference Annunciator Response Determine 1D Main Steam Line Radiation Monitor is in alarm
		Monitor 1D SG level, steam flow and feed flow
		NOTE: Should be able to determine that it is a Rad Monitor failure based on only 1 RM in the steam line and it is at max indication with no other alarms (SJAE, blowdown, etc).
	RO	Monitor Pzr Level and Pressure
		NOTE: Crew may enter 1BwOA SEC-8 "Steam Generator Tube Leak" while waiting for Rad Monitor failure confirmation.
	US	Notify Radiation Protection to verify alarm
		Reference Tech Spec 3.3.3
	US	Inform SM/System Engineering of Rad Monitor failure
		NOTE: After determination of a failed RAD Monitor initiate Event 3.

Comments: _
Scenario No: 00-9		Event No. 3
Event De	scription:	1A SG Narrow Range Level Channel Failure (LT-519)
Time	Position	Applicant's Actions or Behavior
	CUE	Annunciator 1-15-A5 "SG 1A LVL LO-2 RX TRIP ALERT" 1-15-A9 "SG 1A LEVEL DEVIATION HIGH LOW"
	BOP	Identify/report Steam Generator Level channel LT-519 failure
	US	Implement BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment E "NARROW RANGE SG LEVEL CHANNEL FAILURE" and direct operator action.
	BOP	 Check affected SG levels normal If NOT, Place feed reg. valve in manual Restore SG level to a stable condition
		 Select operable SG level channel Establish AUTO level control
	US	Locally trip bistables for failed channel P14 LB519A Lo-2 Rx Trip/AF Pump Start LB519B
	ВОР	Check status of AMS Not failed
	US	Refer to Tech Spec (ITS) 3.3.1 3.3.2 3.3.3
	US	Inform SM/Maint of failure of SG 1A Level Transmitter LT-519
		Note: Following Tech Spec determination, initiate Event 4.

Comments: _____

Scenario No: 00-9	Event No. 4
Event Description:	Pressurizer Level Channel failure low (LT-459)
Time Position	Applicant's Actions or Behavior
CUES:	 Annunciators (1-12-A4) PZR LVL LOW HTRS OFF LTDWN SECURED (1-12-B4) PZR LEVEL CONT DEV LOW PZR heaters tripped OFF with associated alarms Letdown Isolation Valve 1LCV-459 & Orifice Isolation valves 1CV8149A/B/C CLOSE Charging flow control 1CV-121 throttles open to increase flow
RO/US	Identify/Report failed PZR level channel - LT-459
US	Implement 1BwOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment C "PRESSURIZER LEVEL CHANNEL FAILURE" and direct operator action.
RO/US	Check PZR Level: Verify level normal • Take manual control to restore PZR level • Select an operable channel • Select operable channel for PZR level recorder
RO	Check letdown and PZR heaters PZR level >17% Establish letdown per 1BwOP CV-17 Verifies closed 1CV8149A,B,C Place letdown pressure controller 1PCV-CV131 in MAN and raise demand to 40% Place Letdown Hx Out Temp Cont Vlv 1TCV-CC130A to MAN and raise demand to 60%. Open Letdown Line Isolation valve 1LCV-CV459, verify open 1LCV-460 Verify open inservice regen Hx isolation valves 1CV8324A/B & 1CV8389A/B Verify open Letdown Line CNMT isolation valves 1CV8160 & 1CV8152 Verify open Ltdn to Ltdn HX in service 1CV8401A/B Verify Close Pzr Aux Spray Vlv 1CV8145 Verify Open 1CV8147/8105/8106 Charging Line Cnmt Isol Vlvs

.

÷

.

Scenari	o No: 00-9	Event No. 4
Event I	Description:	Pressurizer Level Channel failure low (LT-459)
Time	Position	Applicant's Actions or Behavior
	RO (cont.)	 Adjust in MAN Cent Chg Pump Flow controller 1FK-121 to establish ≈ 100 gpm charging flow with 8-10 gpm seal injection flow. Open the selected letdown orifice isolation valve(s) 1CV8149 A/B/C to establish desired letdown flow Adjust 1PCV-CV131 to obtain 360-380 psig on 1PI-131 and place in AUTO Adjust 1TCV-CC130A to obtain 90-115°F on 1TI-130 and place in AUTO When plant conditions stabilize, place FCV-121 in AUTO. Verify Radiation Monitor 1RE-PR006 in service
	RO/US	 Check PZR level control in Auto Master PZR Level Controller 1CV121 controller
	US/RO	Trip bistables for 1LT-459 by placing in TEST: • PZR HI WTR LVL RX TRIP LB459A
	US	Refer to Technical Specifications: • 3.3.1 • 3.3.3 • 3.3.4
	US	Inform SM/Maint of PZR level channel LT-459 status.
		A state and a succession of the sources can be the press mittate by the s

Comments: _____

Scenario No: 00-9	Event No. 5
Event Description:	1D Steam Generator Tube Leak
Time Position	Applicant's Actions or Behavior
CUE	Increasing Charging flow SG Blowdown Radiation Alarm Off Gas Radiation Alarm Pzr level and pressure decreasing
US	Transition to 1BwOA SEC-8 "Steam Generator Tube Leak" Direct actions of 1BwOA SEC-8
RO	 Maintain PZR Level Throttle charging header control valves 1CV121 1CV182 Check PZR Level – stable or increasing Monitor VCT Level Verify makeup adequate to maintain VCT level
BOP	 Minimize Secondary Contamination Perform BwOP MS-13 "Operation With Steam Generator Tube Leakage"
US	Notify Rad Protection for radiation surveys
CREW	 Identify Leaking SG Increasing trend on any Main Steamline Radiation monitor Decreasing feed flow wit stable SG level in any SG Unexpected rise in any narrow range level Chemistry report on activity
RO	 Determine SG Tube Leak Rate Estimate SG Tube Leak Rate Observe difference between charging flow and seal leakoff plus letdown flow Observe change in VCT level 1BwOS SG-1 Steam Generator Primary to Secondary Leakage Estimation Grab sample Check total RCS to Secondary leak rate less than 10 gpm
US	Transition to step 9.

.

Scenario No: 00-9		Event No. 5
Event Description:		1D Steam Generator Tube Leak
Time	Position	Applicant's Actions or Behavior
	CREW	 Confirm SG Leak Rate – At least 2 independent indications trend in the same direction MS Radiation Monitors SJAE/ Gland Steam Exhaust SG Blowdown N-16 Grab Sample
		NOTE: If leak is determined to be \geq 30 gpm, the following actions will be taken.
	CREW	 Initiate Unit Shutdown Check leak rate increasing less than 30 GPD/ HR Reduce Power to less than 50% in 1 hour per 1BwGP 100-4T3, Rapid Power Reduction Flowchart Shutdown Unit to MODE 3 in the following 3 hours
	US	Refer to Tech Spec 3.4.13
	· · · · · · · · · · · · · · · · · · ·	NOTE: If leak is determined to be <30 gpm, the following actions will be taken.
	CREW	 Initiate Unit Shutdown Check leak rate increasing less than 30 GPD/ HR While continuing with this procedure, shutdown Unit to MODE 3 within Six hours per 1BwGP 100-4/ 5
	US	Refer to Tech Spec 3.4.13
	· · ·	NOTE: After the crew determines that a Unit Shutdown is required, initiate Event 6,7

÷

Ścenario	00-9	Event 6.7
No:		
Event De	scription:	1D Steam Generator Tube Rupture (6) 1D SG atmospheric Relief Fail Open (7)
Time	Position	Applicant's Actions or Behavior
	CUE	Lowering Pzr level Lowering Pzr pressure Increasing charging flow Lowering Feed Flow to the 1D SG
	RO	Manually trip the reactor
	US	Implement 1BwEP-0 "Reactor Trip or Safety Injection"
		Direct actions of 1BwEP E-0
	RO	 Verify reactor trip Rod bottom lights LIT Reactor trip & Bypass breakers open Neutron flux lowering
	ВОР	 Verify Turbine Trip Turbine throttle valves closed Turbine governor valves closed Verify power to 4KV busses Bus 141 alive light lit Bus 142 alive light lit
	CREW	 Determine SI needed/actuated If actuated SI First OUT annunciator lit (1-11-B1, 1-11-C1, 1-11-D1, 1-11-E1) SI ACTUATED lit (1-BP-4.1) SI Equipment actuated (SI pumps running, CV Cold leg injection SI8801A/B open) Manually actuate SI

÷

Scenario No:	00-9	Event 6,7
Event Des	scription:	1D Steam Generator Tube Leak (6) 1D SG atmospheric Relief Fail Open (7)
Time	Position	Applicant's Actions or Behavior
	BOP	Verify FW isolated •FW pumps tripped •Isolation monitor lights lit •FW pumps disch valves closed (FW002A-C)
	RO	 Verify ECCS pumps running CENT Chg pumps RH pumps SI pumps
	BOP	 Verify Group 2 RCFC Accident Mode Lights Lit Verify Phase A isolation - Group 3 Monitor lights lit Verify CNMT Ventilation isolation - Group 6 Monitor lights lit
	BOP	 Verify AF system: AF pumps running AF isolation valves open (1AF13A-H) AF flow control valves throttled (AF005A-H) Verify CC Pumps running Verify SX Pumps running Check Main Steamline Isolation Check SG pressure > 640 psig Check CNMT pressure on 1PR-937 OR 1PI-CS934 thru 937 is >8.2 psi

.

.

;

Scenario	00-9	Event 6,7
Event De	scription:	1D Steam Generator Tube Leak (6) 1D SG atmospheric Relief Fail Open (7)
Time	Position	Applicant's Actions or Behavior
	ВОР	Check if CNMT Spray is required CNMT pressure > 20 psig Stop all RCPs Check Group 6 CS monitor lights lit Check Group 6 monitor Phase B Isolation lights lit Check CS eductor suction flow >15 gpm on 1FI-CS013 & 14 Check CS eductor additive flow > 5 gpm on 1FI-CS015 & 16
	BOP	 Verify AF flows AF flow > 500 gpm SG levels maintained between 10% (31%) and 50% NR levels NOT increasing in an uncontrolled manner If a ruptured SG is identified, then manually close its AF isolation valves 1AF013D 1AF013H

ĩ

06/14/00 12:37 PM

Scenario No:	00-9	Event 6,7
Event De	scription:	1D Steam Generator Tube Leak (6) 1D SG atmospheric Relief Fail Open (7)
Time	Position	Applicant's Actions or Behavior
	RO	Verify ECCS valve alignment & flows
		Group 2 Cold Leg Injection Monitor lights lit (except 1A AF pump).
		• High Head SI flow >100 gpm
		RCS pressure <1700 psig
		• SI Pump discharge flow > 200gpm
		 Check RCS pressure < 325 psig Check RH pump discharge flow > 1000 gpm
		Check at least ONE PZR PORV relief path available: • At least ONE PORV Isol valve energized. • PORV in AUTO
		 Associated Isol valve open
	BOP	Verify generator trip
		 OCB 1-8 and 7-8 open PMG output breaker open
	~	
	BOP	 Verify DG 1A running DG SX valves 1SX169A open Dispatch operator to locally check 1A DG
		 Ventilation systems aligned for emergency Control Room Aux Bldg. Evel Handling Bldg

î

Scenario No:	00-9	Event 6,7
Event Des	cription:	1D Steam Generator Tube Leak (6)
Time	Desition	ID SG aunospheric Relief Fail Open (7)
1 me	Position	Applicant's Actions or Benavior
	RO	Check PZR sprays & PORVs closed RCS temperature control • Check RCP statusCheck RCS Cold Leg temps trending to or stable at 557°F • Throttle AF flow if required Report RCS cold leg temperatures low due to ECCS injection flow
	RO	 Check RCP status (Check if RCPs should be stopped) ECCS flow – High head SI flow greater than 100 GPM OR SI pump discharge flow greater than 200 GPM RCS pressure less than 1425 psig Controlled RCS cooldown not in progress or previously initiated
	BOP	 Check SG secondary boundary All SG pressure not decreasing in an uncontrolled manner or completely depressurized Check SG tubes intact Determine 1D SG is ruptured
	US	Transition to 1BwEP-3 "Steam Generator Tube Rupture" Direct actions of 1BwEP-3
	RO	 Check Status of RCPs (Should RCPs be stopped) ECCS flow – High head SI flow greater than 100 GPM OR SI pump discharge flow greater than 200 GPM RCS pressure less than 1425 psig Controlled RCS cooldown not in progress or previously initiated
	CREW	Identify Ruptured SG (1D)

Comments: _

î

Scenario No:	00-9	Event 6,7
Event De	scription:	1D Steam Generator Tube Leak (6) 1D SG atmospheric Relief Fail Open (7)
Time	Position	Applicant's Actions or Behavior
	BOP [CT]	Isolate Flow From Ruptured SG • Verify ruptured SG PORV controller in Auto • Check ruptured SG PORV closed:
	E-3A	 1MS018D Verify ruptured SG blowdown isol valves closed: 1SD002C 1SD002D Close ruptured SG MSIV and bypass valve Close PORV(s) on intact SGs available for RCS cooldown 1MS018A 1MS018B 1MS018C
	BOP	Check Ruptured SG Level • Narrow range level greater than 10% (31%) Verify AF isolation valves on ruptured SG closed - 1AF013D - 1AF013H Check Ruptured SG Pressure – greater than 320 psig
	CREW	 Initiate RCS Cooldown Determine required core exit temperature from table Check PZR pressure less than 1930 psig PZR LOW PRESS SI BLOCK PERMISSIVE, P-11 Lit Block steamline isolation SI Place STM LINE SI RESET/BLOCK switches to BLOCK Dump steam to condenser from intact SG at maximum rate Check steam dumps available Place main steam header pressure controller in manual and reduce demand signal to zero Place steam dump mode selector switch in STM PRESS mode Adjust MS pressure controller in manual or auto to initiate cooldown
		TWEE, Initial Steam Dieak und the covidera has commenced

Comments:

.

î

06/14/00 12:37 PM

Scenario No:	00-9	Event 8
Event De	scription:	1A Main Steam Line Break
Time	Position	Applicant's Actions or Behavior
	CUE	Elevated steam flow on the 1A SG 1A SG pressure decreasing PZR level decreasing PZR pressure decreasing
	CREW	May stop cooldown of 1BwEP-3
	US	Transition to 1BwEP-2 "Faulted Steam Generator Isolation"
		Direct actions of 1BwEP-2
	BOP	Check Main Steamline Isolation All MSIVs and MSIV bypass valves closed
		 Check if any SG Secondary Pressure Boundary is Intact Check pressure in all SGs – any SG pressure stable or increasing
	BOP	 Identify faulted SG (1A) Any SG pressure decreasing in an uncontrolled manner OR Any SG completely depressurized
	BOP [CT] E-2A	Isolate Faulted SG (1A) Close AF isolation valves on faulted SG 1AF013A 1AF013E
		 Check FW to faulted SG isolated Associated row on FW ISOLATION MONITOR LIGHTS panel Lit for faulted SG Verify SG PORV on faulted SG closed IMS018A
		 Verify SG blowdown isolation and sample valves on faulted SG closed 1SD002A 1SD002B 1SD005A

:

·

06/14/00 12:37 PM

Scenario No:	00-9	Event 8
Event Description: 1A Main Steam Line Break		
Time	Position	Applicant's Actions or Behavior
	ВОР	 Monitor AF Pump Suction Pressure AF PUMP SX SUCT VLVS ARMED alarm Not Lit Check Secondary Radiation Secondary radiation trends –normal for plant conditions
	US	Transition to 1BwEP-3 "Steam Generator Tube Rupture"
		NOTE: The scenario may be terminated at this pont.

Comments: ____

Ţ