

June 26, 2001

Mr. John H. Mueller
Chief Nuclear Officer
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Operations Building, Second Floor
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 2 - REQUEST FOR
ADDITIONAL INFORMATION (RAI), PROPOSED AMENDMENT ON REACTOR
PROTECTION SYSTEM ELECTRICAL POWER MONITORING ASSEMBLIES
(TAC NO. MB1163)

Dear Mr. Mueller:

The NRC staff is reviewing the subject proposed amendment from Niagara Mohawk Power Corporation (NMPC) dated February 27, 2001. On May 17, 2001, the staff held a telephone discussion with Messrs. S. Leonard and C. Mackaman, et al. of NMPC on comments we previously e-mailed (publicly available in ADAMS Accession No. ML011160024). The NRC staff summarized the information verbally communicated by NMPC staff during the conference call (enclosure).

Please review the enclosure and confirm, clarify, or otherwise correct the information. We request your timely response to support NMPC's requested target date of February 28, 2002.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosure: RAI

cc w/encl.: See next page

Mr. John H. Mueller
Chief Nuclear Officer
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Operations Building, Second Floor
Lycoming, NY 13093

June 26, 2001

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 2 - REQUEST FOR
ADDITIONAL INFORMATION (RAI), PROPOSED AMENDMENT ON REACTOR
PROTECTION SYSTEM ELECTRICAL POWER MONITORING ASSEMBLIES
(TAC NO. MB1163)

Dear Mr. Mueller:

The NRC staff is reviewing the subject proposed amendment from Niagara Mohawk Power Corporation (NMPC) dated February 27, 2001. On May 17, 2001, the staff held a telephone discussion with Messrs. S. Leonard and C. Mackaman, et al. of NMPC on comments we previously e-mailed (publicly available in ADAMS Accession No. ML011160024). The NRC staff summarized the information verbally communicated by NMPC staff during the conference call (enclosure).

Please review the enclosure and confirm, clarify, or otherwise correct the information. We request your timely response to support NMPC's requested target date of February 28, 2002.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosure: RAI
cc w/encl.: See next page

Accession Number: **ML011620025**

OFFICE	PDI-1/PM	PDI-1/LA	EEIB	EEIB/SC	PDI-1/SC(A)
NAME	PTam	SLittle*	JKnox*	CHolden*	RCorreia
DATE	6/26/01	6/11/01	6/27/01	6/25/01	6/26/01

OFFICIAL RECORD COPY

*See previous concurrence

DISTRIBUTION:

PDI-1 R/F	PUBLIC
RCorreia	PTam
OGC	JKnox
ACRS	
BPlatchek	
SLittle	
LBerry	
CCarpenter	

Nine Mile Point Nuclear Station
Unit No. 2

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
Nine Mile Point Nuclear Station
P.O. Box 126
Lycoming, NY 13093

Mr. Jim Rettberg
NY State Electric & Gas Corporation
Corporate Drive
Kirkwood Industrial Park
P.O. Box 5224
Binghamton, NY 13902-5224

Mr. John V. Vinquist, MATS Inc.
P.O. Box 63
Lycoming, NY 13093

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. Paul D. Eddy
Electric Division
NYS Department of Public Service
Agency Building 3
Empire State Plaza
Albany, NY 12223

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Timothy S. Carey
Chair and Executive Director
State Consumer Protection Board
5 Empire State Plaza, Suite 2101
Albany, NY 12223

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW.
Washington, DC 20005-3502

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

Mr. William M. Flynn, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

NINE MILE POINT NUCLEAR STATION, UNIT NO. 2

REQUEST FOR ADDITIONAL INFORMATION

PROPOSED AMENDMENT ON REACTOR PROTECTION SYSTEM ELECTRICAL POWER

MONITORING ASSEMBLIES

On May 17, 2001, the NRC staff conducted a telephone conference with Niagara Mohawk Power Corporation personnel. The NRC staff received verbal information on the following items. Please confirm, clarify, or otherwise correct the accuracy of the these items:

1. The main steam isolation valve (MSIV) trip solenoids supplied by General Electric are designed for 40 years of operation if operated continuously at 125 volts (i.e., the solenoids' maximum design rating of 125 volts).
2. If operated at 128 volts (a voltage above the maximum design rating), the MSIV trip solenoids supplied by GE are designed for 2.2 years of operation (i.e., the solenoids have a qualified life of 2.2 years if operated continuously at 128 volts).
3. A voltage of 124 volts is the maximum normal voltage expected from the reactor protection system (RPS) power supplies.
4. MSIV trip solenoids supplied by GE are replaced before they reach 2.2 years of operation at normal voltages.
5. MSIV trip solenoids supplied by GE are in the process of being replaced with solenoids designed for 40 years of operation if operated continuously at 128 volts.
6. The proposed Technical Specifications (TSs) overvoltage Allowable Value change will reduce margin from 8 volts (132 volts, the current TS overvoltage Allowable Value, minus 124 volts, the maximum expected normal voltage from the RPS power supplies) to 4 volts (128 volts, the proposed TS overvoltage Allowable Value, minus 124 volts, the maximum expected normal voltage from the RPS power supplies).
7. The probability for tripping of an electric protective assembly (EPA) will not change due to a set point drift with a 4 versus 8 volt margin.
8. Bypassing one EPA for testing and calibration does not adversely affect the probability for EPA trip (and thus reactor trip).
9. The proposed calibration frequency of 184 days was selected to assure that there would be no change in the probability for EPA trip (and thus reactor trip) due to set point drift.