

February 7, 1978

Docket No. 50-271

Yankee Atomic Electric Company  
ATTN: Mr. Robert H. Groce  
Licensing Engineer  
20 Turnpike Road  
Westboro, Massachusetts 01581

Gentlemen:

The Commission has issued the enclosed Amendment No. 44 to Facility Operating License No. DPR-28 for the Vermont Yankee Nuclear Power Station. The amendment consists of changes to the Technical Specifications in response to your application for amendment dated August 5, 1977.

The amendment provides for an increase in the High Drywell Pressure setpoint.

Copies of the Safety Evaluation and the Notice of Issuance are enclosed.

Sincerely,

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors

Enclosures:

1. Amendment No. 44
2. Safety Evaluation
3. Notice

cc w/enclosures:  
See next page

*MBF*

OFFICE ➤	ORB#4:DOR	ORB#4:DOR	OELD	C-ORB#4:DOR	RSB LB	RSB RAB
SURNAME ➤	RIngram	MFairtile:dn		RWReid	WButler	R. Baer
DATE ➤	1/11/78	1/24/78	1/ /78	2/7/78	1/25/78	1/26/78

*See [unclear] 2/9/78*

*CP*

DISTRIBUTION

Docket

NRC PDR

L PDR

ORB#4 Reading

VStello

KRGoller/TCarter

RIngram

DRoss

MFairtile

TAbernathy

OELD

JBuchanan

OI&E(5)

file

BJones(4)

XTRA Cy 4

BScharf(10)

W. Butler

JMcGough

C. Grimes

BHarless

DEisenhut

ACRS(16)

OPA, Clare Miles

Yankee Atomic Electric Company

cc w/enclosure(s):

Mr. S. D. Karpyak  
Vermont Yankee Nuclear Power  
Corporation  
77 Grove Street  
Rutland, Vermont

Mr. Donald E. Vandenburg  
Vice President  
Vermont Yankee Nuclear Power  
Corporation  
Turnpike Road, Route 9  
Westboro, Massachusetts 01581

John A. Ritsher, Esquire  
Ropes & Gray  
225 Franklin Street  
Boston, Massachusetts 02110

Gregor I. McGregor, Esquire  
Assistant Attorney General  
Department of the Attorney General  
State House, Room 370  
Boston, Massachusetts 02133

Richard E. Ayres, Esquire  
Natural Resources Defense Council  
917 15th Street, N.W.  
Washington, D.C. 20005

Honorable M. Jerome Diamond  
Attorney General  
John A. Calhoun  
Assistant Attorney General  
State of Vermont  
109 State Street  
Pavilion Office Building  
Montpelier, Vermont 05602

Anthony Z. Roisman, Esquire  
Sheldon, Harmon & Roisman  
105 15th Street, N.W., 5th Floor  
Washington, D.C. 20005

Brooks Memorial Library  
224 Main Street  
Brattleboro, Vermont 05301

John R. Stanton, Director  
Radiation Control Agency  
Hazen Drive  
Concord, New Hampshire 03301

John W. Stevens  
Conservation Society of Southern  
Vermont  
P. O. Box 256  
Townshend, Vermont 05353

Mr. David M. Scott  
Radiation Health Engineer  
Agency of Human Services  
Division of Occupational Health  
P. O. Box 607  
Barre, Vermont 05641

New England Coalition on Nuclear  
Pollution  
Hill and Dale Farm  
West Hill - Faraway Road  
Putney, Vermont 05346

Mr. Raymond H. Puffer  
Chairman  
Board of Selectman  
Vernon, Vermont 05354

Chief, Energy Systems Analyses  
Branch (AW-459)  
Office of Radiation Programs  
U. S. Environmental Protection  
Agency  
Room 645, East Tower  
401 M Street, S.W.  
Washington, D.C. 20460

Yankee Atomic Electric Company

cc w/enclosure(s):  
U. S. Environmental Protection Agency  
Region I Office  
ATTN: EIS COORDINATOR  
JFK Federal Building  
Boston, Massachusetts 02203

cc w/enclosure(s) and cy of VY's  
filing dtd: 8/5/77  
Public Service Board  
State of Vermont  
120 State Street  
Montpelier, Vermont 05602



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

VERMONT YANKEE NUCLEAR POWER CORPORATION

DOCKET NO. 50-271

VERMONT YANKEE NUCLEAR POWER STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 44  
License No. DPR-28

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Vermont Yankee Nuclear Power Corporation (the licensee) dated August 5, 1977, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Facility Operating License No. DPR- 28 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 44, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: February 7, 1978

ATTACHMENT TO LICENSE AMENDMENT NO.44

FACILITY OPERATING LICENSE NO. DPR-28

DOCKET NO. 50-271

Revise Appendix A Technical Specifications as follows:

Remove Pages

19

35 & 36

39

Insert Pages

19

35 & 36

39

Changes on the revised pages are shown by marginal lines.

TABLE 3.1.1

REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENT REQUIREMENTS

Trip Function	Trip Settings	Modes in Which Functions Must be Operating			Minimum Number Operating Instrument Channels Per Trip System(2)	Required Conditions When Minimum Conditions For Operation Are Not Satisfied (3)
		Refuel(1)	Startup	Run		
1. Mode switch in shutdown		X	X	X	1	A
2. Manual scram		X	X	X	1	A
3. IRM						
High Flux	$\leq 120/125$	X	X	X(11)	2	A
Inop		X	X	X(11)	2	A
4. APRM						
High Flux (flow bias)	$\leq 0.66W+54\%(4)$			X	2	A or B
High Flux (reduced)	$\leq 15\%$	X	X	X	2 2(5)	A A or B
INOP				X	2	A or B
Boomscale	$\geq 2/125$			X	2	A
5. High Reactor Pressure	$\leq 1055$ psig	X	X	X	2	A
6. High Drywell Pressure	$\leq 2.5$ psig	X	X	X	2	A
7. Reactor Low Water Level	$\geq 1.0$ inch(6)	X	X	X	2	A
8. Scram Discharge Volume High Level	$\leq 24$ gallons	X	X	X	2	A

VYNPS

TABLE 3.2.1

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

<u>Core Spray - A &amp; B (Note 1)</u>			
<u>Minimum Number of Operable Instrument Channels per Trip System</u>	<u>Trip Function</u>	<u>Trip Level Setting</u>	<u>Required Action When Minimum Conditions for Operation are not Satisfied</u>
2	High Drywell Pressure	$\leq 2.5$ psig	Note 2
2	Low-Low Reactor Vessel Water Level	$\geq 6'$ 10.5" above top of active fuel	Note 2
1	Low Reactor Pressure #1	$\geq 300$ psig	Note 2
2	Low Reactor Pressure #2	$\geq 300$ psig	Note 2
1	Time Delay (14A-K16A&B)	$\leq 10$ seconds	Note 2
2	Pump 14-1A, Discharge Pressure	$\geq 100$ psig	Note 5
1	Auxiliary Power Monitor	--	Note 5
1	Pump Bus Power Monitor	--	Note 5
1	High Sparger Pressure	$\leq 5$ psid	Note 5
1	Trip System Logic	--	Note 5



VYNPS

TABLE 3.2.1 (CONT)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

<u>Low Pressure Coolant Injection System A &amp; B (Note 1)</u>			
<u>Minimum Number of Operable Instrument Channels per Trip System</u>	<u>Trip Function</u>	<u>Trip Level Setting</u>	<u>Required Action When Minimum Conditions for Operation are not Satisfied</u>
1	Low Reactor Pressure #1 (water level permissive)	$300 \leq p \leq 350$ psig	Note 2
2	High Drywell Pressure #1	$\leq 2.5$ psig	Note 2
2	Low-Low Reactor Vessel Water Level	$> 6'$ 10.5" above top of active fuel	Note 2
1	Time Delay (10A-K51A&B)	0 sec.	Note 5
1	Reactor Vessel Shroud Level	$\geq 2/3$ core height	Note 5
1	Time Delay (10A-K72A&B)	$\leq 60$ sec.	Note 5
1	Time Delay (10A-K50A&B)	$\leq 5$ sec.	Note 5
1	Low Reactor Pressure #2 (shutdown cooling permissive)	$100 \leq p \leq 150$ psig	Note 2
2 per pump	RMR Pump A & C Discharge Pressure	$\geq 100$ psig	Note 5
2	High Drywell Pressure #2	$\leq 2.5$ psig	Note 2

VYNPS

TABLE 3.2.1 (CONT)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

<u>Automatic Depressurization</u>			
<u>Minimum Number of Operable Instrument Channels per Trip System (Note 4)</u>	<u>Trip Function</u>	<u>Trip Level Setting</u>	<u>Required Action When Minimum Conditions for Operation are not Satisfied</u>
2	Low-Low Reactor Vessel Water Level	Same as Core Spray	Note 6
2	High Drywell Pressure	$\leq 2.5$ psig	Note 6
1	Time Delay (2E-K5A&B)	$\leq 120$ seconds	Note 6
1	Bus Power Monitor	--	Note 6
1	Trip System Logic	--	Note 6



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
SUPPORTING AMENDMENT NO. 44 TO FACILITY OPERATING LICENSE NO. DPR-28

VERMONT YANKEE NUCLEAR POWER CORPORATION

VERMONT YANKEE NUCLEAR POWER STATION

DOCKET NO. 50-271

Introduction

By an application for amendment to Operating License dated August 5, 1977, the Vermont Yankee Nuclear Power Corporation (the licensee), proposed changes to the Technical Specifications appended to Facility Operating License No. DPR-28, for the Vermont Yankee Nuclear Power Station. The proposed changes would provide an increase in the High Drywell Pressure setpoint from 2.0 to 2.5 psig.

Background

As part of our ongoing review of suppression chamber (torus) integrity, the Nuclear Regulatory Commission issued an Order for Modification of License, dated February 13, 1976, requiring that a differential pressure of 1.7 psi be maintained between the primary containment (drywell) and the torus. Previously, the maximum differential operating pressure was 1.5 psi. The high drywell pressure trip setpoint is 2.0 psig; thus, the margin between the trip point pressure setting and the drywell pressure has been reduced to 0.3 psi from 0.5 psi.

The proposed license amendment of August 5, 1977, requested a Technical Specification change increasing the high drywell pressure setpoint from 2.0 psig to 2.5 psig in order to permit the plant to maintain the pressure difference between the drywell and torus at 1.7 psi and in turn lessening the probability of an inadvertent trip of the setpoint which would cause reactor scram, containment isolation and attempt initiation of certain Emergency Core Cooling System (ECCS) components as the margin would become 0.8 psi.

Evaluation

The high drywell pressure trip signal is used to initiate primary containment isolation and serves as a backup or conjunctive signal to initiate the ECCS. While it is proposed to raise the trip setpoint value from 2.0 psig to 2.5 psig, the differential pressure between drywell ambient and the trip setting remains at 1.7 psi.

We have reviewed the proposed change with respect to the time to achieve containment isolation, the performance of the ECCS, and the containment response to a postulated loss-of-coolant accident (LOCA). The higher initial containment pressure will slightly improve ECCS pump performance due to the small increase in the net positive suction head accompanied by a lesser increase in pump discharge pressure. In addition, the change in the containment isolation time and the containment pressure response will be small since they are primarily a function of the differential pressure from drywell ambient and the trip setting. The margins between the containment design pressure and temperature and the calculated results for a spectrum of breaks is sufficiently large to accommodate the small changes associated with the higher setpoint. Fuel peak clad temperatures would be unaffected in the event of the design basis accident by the 0.5 psi increase in containment ambient pressure as the rate of discharge from a postulated double-ended pipe rupture would be at choked-flow conditions and independent of discharge pressure.

Based on our review, we find the licensee's proposal to increase the high drywell pressure setpoint from 2.0 psig to 2.5 psig acceptable.

#### Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

#### Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: February 7, 1978

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-271VERMONT YANKEE NUCLEAR POWER CORPORATIONNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE

The Nuclear Regulatory Commission (the Commission) has issued Amendment No. 44 to Facility Operating License No. DPR-28 issued to Vermont Yankee Nuclear Power Corporation (the licensee) which revised Technical Specifications for operation of the Vermont Yankee Nuclear Power Station (the facility), located near Vernon, Vermont. The amendment is effective as of the date of issuance.

The amendment provides for an increase in the High Drywell Pressure setpoint.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or


- 2 -

negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application dated August 5, 1977, (2) Amendment No. 44 to License No. DPR-28, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. and at the Brooks Memorial Library, 224 Main Street, Brattleboro, Vermont. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20540, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 7th day of February 1978.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors