# FINAL AS-ADMINISTERED ADMINISTRATIVE JPMS

# FOR THE BRAIDWOOD INITIAL EXAMINATION - OCTOBER 2000

ES-301

Administrative Topics Outline

Form ES-301-1

Facilit <u>y</u> Exami	y: <u>Braidwood</u> nation Level (circle	<u>d Unit 1 and 2</u> Date of Examination: <u>10/23/00</u> one): RO Operating Test Number: <u>1</u>
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions
A.1	Conduct of Operations / Plant Parameter Verification	JPM (Replacement/ New) KA 2.1.33 3.4/4.0
	Conduct of Operations / Respond to a Plant Fire Alarm	JPM (N-09) KA 2.1.18 2.9/3.0
A.2	Equipment Control / Perform a QPTR Surveillance	JPM (N-102 Modified) – KA 2.2.12 3.0/3.4
A.3	Radiation Control / RCA Exit with Contamination Alarm	JPM (N-151 New) KA 2.3.1 2.6/3.0
A.4	Emergency Plan / Emergency Plan Directions	<ul><li>2. a. K/A 2.4.39 3.3/3.1 Emergency Exposures</li><li>2. b. K/A 2.4.29 2.6/4.0 Emergency facilities</li></ul>

ł

E	S	-3	0	1

Administrative Topics Outline

Form ES-301-1

Facility Exami	/: <u>Braidwood</u> nation Level (circle	<u>d Unit 1 and 2</u> Date of Examination: <u>10/23/00</u> one): SRO Operating Test Number: <u>1</u>
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions
A.1	Conduct of Operations / Plant Parameter Verification	JPM (Replacement/ New) KA 2.1.33 3.4/4.0
	Conduct of Operations / Respond to a Plant Fire Alarm	JPM (N-09) KA 2.1.18 2.9/3.0
A.2	Equipment Control / Perform a QPTR Surveillance	JPM (N-102 Modified) – KA 2.2.12 3.0/3.4
A.3	Radiation Control / RCA Exit with Contamination Alarm	JPM (N-151 New) KA 2.3.1 2.6/3.0 Evaluated while performing JPM B.2.a
A.4	Emergency Plan / GSEP Classification	JPM (New) – KA 2.4.41 2.3/4.1

## ADMINISTRATIVE WALKTHROUGH JOB PERFORMANCE MEASURE

,

TASK TITLE: Area Temperature Monitoring Surveillance	2
JPM No.: NEW (RO/SRO)	REV: 0
Task Number: AM-018	K&A No.: 2.1.33
	K&A IMP: 3.4/4.0
CANDIDATE:	DATE:
EVALUATOR:	DATE:
The Candidate: PASSED this JPM.	TIME STARTED:
FAILED	TIME FINISHED:
CRITICAL ELEMENTS: (*) 5	JPM TIME:
CRITICAL TIME: NA	APPROX COMPLETION TIME 12 MINUTES
EVALUATION METHOD: PERFORM	LOCATION:
SIMULATE	SIMULATOR
GENERAL REFERENCES:	
<ol> <li>0BwOS TRM 3.7.d.1 U0, U1, U2 All Modes/ A Monitoring Shiftly Surveillance (Rev. 0)</li> </ol>	at All Times Area Temperature
MATERIALS:	
<ol> <li>0BwOS TRM 3.7.d.1 U0, U1, U2 All Modes/ A Monitoring Shiftly Surveillance</li> </ol>	at All Times Area Temperature
TASK STANDARDS:	
Perform Actions required to:	
<ol> <li>Review recorded temperatures on data shee</li> <li>Determine Tech Specs are not Satisfied.</li> </ol>	t.
TASK CONDITIONS:	
<ol> <li>You are the Unit 1 Admin NSO.</li> <li>Unit 1 is in MODE 1.</li> </ol>	
INITIATING CUES:	
<ol> <li>Surveillance OBwOS TRM 3.7.d.1 "UO, U1, U Temperature Monitoring Shiftly Surveillan</li> </ol>	2 All Modes/ At All Times Area ce" has been completed by the Rounds
NLO. 2. You have been directed to review surveill	ance OBwOS TRM 3.7.d.1.

5

PERFORMANCE CHECKLIST	STANDARDS	SAT	UN SAT	N/A
RECORD START TIME				
1. Review OBwOS TRM 3.7.d.1	Reviews OBwOS TRM 3.7.d.1		Q	D

NOTE

In order to verify the OPERABILITY of equipment or systems within specific areas the Shift Manager or designee may elect to perform a partial surveillance provided all applicable PREREQUISITES, PRECAUTIONS, and LIMITATIONS and ACTIONS are observed

2. Verify all applicable N/A PREREQUISITES, PRECAUTIONS, and LIMITATIONS and ACTIONS satisfactorily addressed. 3. Record the Start Time on Determines time is filled in each Data Sheet as it is on sheet D-2. performed. 4. Record the certified Determines ID number filled portable temperature in. monitoring instrument ID number on the Data Sheet before being performed.

NOTE

If an installed instrument is not available, the certified portable temperature monitoring instrument may be used to obtain the required readings. The reason for using the portable instrument in lieu of the installed instrument shall be recorded in the comments section of the data sheet.

NOTE

Per commitment 456-402-83-00701, anytime an EDG room ambient temperature exceeds 122F, the Control Cabinet internal temperature must be verified less than 132F. This temperature is read with the portable instrument by placing the probe into the air stream at the cabinet air exhaust grilles on BOTH sides of the cabinet.

PERFORMANCE CHECKLIST	STANDARDS	SAT	UN SAT	<u>N/A</u>
*5. Record the area	• Reviews area temperatures	D		
Data Sheets. The readings are obtained either from installed instrumentation	• Determines 1A DG Room temperature is greater than 122°F.			ū
portable temperature monitoring instrument as listed on the Data Sheet.	• Contact NLO for resolution of EDG Control Cabinet exhaust temperatures.			Q
CUE: When contacted as the NLO report Left side of cabinet is 129°F and the right side of the cabinet is 133°F When contacted as the SRO, state that you will	• Inform SRO of out of spec reading.			
reference Tech Specs.				
	• Determines Div 11 Misc Ele Equip Room temperature needs to be reported to System Engineering.			
CUE: SRO will contact System Engineering	• Circles reading per Limitations & Actions or contacts NLO for resolution.	ū		Q
CUE: This completes the JPM.				

RECORD STOP TIME

COMMENTS:

. .

PERFORMANCE CHECKLIST

.

SELF

CHECK

TASK CONDITIONS:

- 1. You are the Unit 1 Admin NSO.
- 2. Unit 1 is in MODE 1.

# INITIATING CUES:

- 1. Surveillance OBwOS TRM 3.7.d.1 "UO, U1, U2 All Modes/ At All Times Area Temperature Monitoring Shiftly Surveillance" has been completed by the Rounds NLO.
- 2.You have been directed to review surveillance OBwOS TRM 3.7.d.1.

## JOB PERFORMANCE MEASURE

TASK TITLE: Respond to a Fire Detection/Suppression	System Alarm
JPM No.: <b>N-09</b>	REV: <u>10</u>
TPO No.: IV.D.AM-01	K&A No.: 2.1.18
TASK No.: AM-040	K&A IMP: 2.9/3.0
TRAINEE:	DATE:
The Trainee: PASSED This JPM.	TIME STARTED:
CRITICAL ELEMENTS: (*)2,3,6	JPM TIME:MINUTES
CRITICAL TIME: N/A	APPROX COMPLETION TIME 10 MINUTES
EVALUATION METHOD: PERFORM SIMULATE	LOCATION: IN PLANT SIMULATOR
GENERAL REFERENCES:	
<pre>1. BwAR 0-37-A4, Rev. 8, "UNIT 1 AREA FIRE". 2. BwAP 1100-16, Rev. 11, "Fire/Hazardous Materia 3. BwOP FP-49, Rev. 1 "Interpretation of _PM09J F: MATERIALS:</pre>	ls Spill and/or Injury Response" ire Protection Alarms"
Copies of BwAR 0-37-A4, and BwAP 1100-16.	
TASK STANDARDS:	
1. Respond to a Fire Detection/Suppression Syst	cem Alarm.
TASK CONDITIONS:	
1. You are the Unit 1 Admin NSO. 2. All systems are in automatic, both Units at	100% Power.

INITIATING CUES:

......

¥ 1

. .

. .

1. The "Unit 1 Area Fire" annunciator (0-37-A4) has just alarmed.

PERFOR	RMANCE CHECKLIST	STANDARDS	SAT	UNSAT	N/A
RECORI	D START TIME				
1.	Obtain a copy of the annunciator response manual for "Unit 1 Area Fire Alarm"	Reference 0-37-A4			
*2.	Determine zone number of fire alarm on Fire Panel 1PM09J and locate fire area by referring to the applicable zone number in the Pre-Fire Plans.	Determine Zone number			
Cue:	1PM09J indicates that the fire is in the 1B DO Tank Room				
*3.[	Dispatch personnel to investigate fire.	Dispatch personnel to investigate fire.			
Cue:	Operator reports a small oil fire in the 1B DO Tank Room.				
<b>4</b> .	If a fire is found, dispatch personnel to extinguish fire per BwAP 1100-16.	Transition to BwAP 1100- 16			
5.	Locate BwAP 1100-16 Appendix A.	<ul> <li>Locate BwAP 1100-16, Fire and/or Injury Response,</li> <li>Per step F.1 of the main body transition to Appendix A (Fire/Haz-Mat Spill Response)</li> </ul>			

:

v PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	N/A
*6. Initiate Appendix D	• Record the date			
	• Record the time			
Cue: The name of the caller is Joe Martin.	<ul> <li>Record the name of the caller</li> </ul>			
	<ul> <li>Acquire the location of the incident</li> </ul>			
	• Determine type of fire			
Cue: Acknowledge as the Shift Manager when contacted.	<ul> <li>Notify the Shift Manager</li> </ul>			
	<ul> <li>Announce the fire location, type and size of the fire over the radio system.</li> </ul>			
Cue: Plant siren has sounded for 13 seconds.	<ul> <li>Sound the plant fire siren for 10-15 seconds</li> </ul>			
	<ul> <li>Announce the fire location, type and size of the fire over the plant PA system utilizing the "EMER PAGE" button.</li> </ul>			
Cue: Plant siren has sounded for 13 seconds.	<ul> <li>Sound the plant fire siren for 10-15 seconds</li> </ul>			
	• Announce the fire location, type and size of the fire over the plant PA system utilizing the "EMER PAGE" button.			

Cue: THIS COMPLETES THIS JPM.

\_

RECORD STOP TIME

\_\_\_\_\_

COMMENTS:

ĩ

TASK CONDITIONS:

1 . . . .

- 1. 2.
- You are the Unit 1 Admin NSO. All systems are in automatic, both Units at 100% Power.

INITIATING CUES:

1. The "Unit 1 Area Fire" annunciator (0-37-A4) has just alarmed.

#### JOB PERFORMANCE MEASURE

TASK TITLE: Perform a QPTR Calculation	
JPM No.: N-102	REV: 9
TPO No.:	K&A No.: 2.2.12
TASK No.: RK 003	K&A IMP: 3.0/3.4
TRAINEE:	DATE:
EVALUATOR:	DATE:
The Trainee: PASSED this JPM.	TIME STARTED:
FAILED	TIME FINISHED:
CRITICAL ELEMENTS: (*) 5,6,7	JPM TIME:
CRITICAL TIME: NA	APPROX COMPLETION TIME 15 MINUTES
EVALUATION METHOD: PERFORM SIMULATE	LOCATION: IN PLANT SIMULATOR

#### GENERAL REFERENCES:

1BwOSR 3.2.4.1 "U1 Quadrant Power Tilt Ratio (QPTR) Calculation, Rev. 1

#### MATERIALS:

÷ ------

1. Blank copy of 1BwOSR 3.2.4.1.

#### TASK STANDARDS:

Complete QPTR surveillance (1BwOSR 3.2.4.1) using Plant Computer.
 Notes and reports failure to meet acceptance criteria.

TASK CONDITIONS:

You are the Unit NSO. Unit 1 is at 100% power.

#### INITIATING CUES:

The Unit Supervisor directs you to perform the weekly QPTR calculation using 1BwOSR 3.2.4.1, using the computer points.

PERFOR	MANCE CHECKLIST	STANDARDS	SAT	UNSAT	N/A
RECORD	START TIME				
1.	Refer to 1BwOSR 3.2.4.1, "Quadrant Power Tilt Ratio (QPTR) Calculation".	Locate and Open 1BwOSR 3.2.4.1.			
CUE:	All Prerequisites and Precautions are met.				
2.	Indicate the applicability of this surveillance on the appropriate Data Sheet.	On 1BwOSR 3.2.4.1 Data Sheet for Computer Points, mark block for "7 Days".			
3.	Record date and time.	Records current date & time on Data Sheet.	ū	ū	

## NOTE

With one Power Range Channel Inoperable and Thermal Power is >50% but <75%, the QPTR may be calculated using the three operable channels. With one Power Range Channel input to QPTR Inoperable with Thermal Power >75%, the QPTR shall be calculated using the three operable channels taking data when directed by System Engineering during performance of BwVSR 3.2.4.2. Record N/A for the Inoperable Power Range Channel data.

4.	Record the OPERABILITY
	status and indicated
	Reactor Power from NIS
	drawer front panel Percent
	Full Power meters on the
	appropriate Data Sheet.

Completes applicable Docks of Data Sheet for N41, N42, N43 and N44:

 Channel operable - "Y" block checked

 Instrument reading -Actual values

#### NOTE

Step F.5 and F.6 are independent of each other. Perform the applicable step. Step F.5 will use the process computer to determine the QPTR. Step F.6 will use installed NIS meters or DVMs to determine QPTR.

÷ 🖌					
PERFORM	MANCE CHECKLIST	STANDARDS	SAT	UNSAT	<u>N/A</u>
* 5.	<ul> <li>Determine the QPTR using process computer points as follows:</li> <li>Record present computer point reading.</li> <li>Divide the sum of the computer points by the number of the operable channels to obtain the average computer point reading.</li> <li>Divide the Computer</li> </ul>	Obtain readings from Process Computer by locating appropriate points: • N0041 AND N0042 • N0043 AND N0044 • N0045 AND N0046 • N0047 AND N0048 AND			
	Point Reading by the Average Computer Point Reading to determine the Quadrant Power Tilt Ratio.	Records values in appropriate blanks on Data Sheet. AND			
		Divides sum of computer points for Upper Detectors (A) by the total number of operable channels (4)			
		AND			
		Divides sum of computer points for Upper Detectors (B) by the total number of operable channels (4)			
* 6.	Determine QPTR.	Divide each computer point value by the calculated average for BOTH the Upper and Lower detectors			
		AND			
		Records QPTR value in appropriate blanks on Data Sheet.			

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	<u>N/A</u>
* 7. Evaluate Acceptance Criteria.	Determines QPTR for N0048 does NOT meet Acceptance Criteria (> 1.02)		ū	
Note: See attachment for values	AND			
and the debugsiment for varies.	Notifies SM (to initiate LOCAR 1BwOL 3.2.4.			
CUE: Acknowledge report for QPTR.				
CUE: This completes this JPM.				
RECORD STOP TIME	_			

COMMENTS

•

4

÷

4 · · · · · · ·

TASK CONDITIONS:

You are the Unit NSO.

Unit 1 is at 100% power.

INITIATING CUES:

The Unit Supervisor directs you to perform the weekly QPTR calculation using 1BwOSR 3.2.4.1, using the computer points.

,

,

KĒ

\_\_\_\_\_

1BwOSR 3.2.4.1 Revision 1 Reference Use

# UNIT ONE QUADRANT POWER TILT RATIO CALCULATION COMPUTER POINTS

# NOTE

The process computer point calculation is the most accurate method of calculating QPTR and should normally be used. During the performance of AFD calibrations on the excore detectors the process computer point method will not be correct until ALL drawers are calibrated. During this calibration period QPTR MUST be calculated using the NIS meter method.

Being performed once per:

- .....

✓ 7 Days (normal interval)□ 12 Hours (with BwVSR 3.2.4.2)

□ Shiftly □ Other: \_\_\_\_

Date: Toolay	Time: Now			
Channel /	N41	N42	N43	N44
Is the channel operable?	ΣΣIY ⊡ N	159Y⊡N	HSY DN	125 Y D N
Instrument reading	101.5 %	100.5 %	100 %	(20 %
	Upper Detectors	s (A)	<b>.</b>	
Computer point	N0041	N0043	N0045	N0047
Present computer point reading	3.976	3.981	3.979	3.980
Average computer point reading		3.979		
Upper power tilt ratio (¢≤1.02)	\$ 9992	\$ 1.001	\$ 1.00	\$ 1.00
	Lower Detectors	s (B)		7
Computer point	N0042	N0044	N0046	N0048
Present computer point reading	4.536	4.541	4.541	4.817
Average computer point reading		4.609	· · · · · · · · · · · · · · · · · · ·	
Lower power tilt ratio (¢≤1.02)	¢ .9842	¢ .9853	\$ .9853	\$ 1.045)

Date:	Time:	<b></b>		
Channel	N41	N42	N43	N44
Is the channel operable?				
Instrument reading	%	%	%	%
	Upper Detector	s (A)	L <u></u>	
Computer point	N0041	N0043	N0045	N0047
Present computer point reading				
Average computer point reading		I	· · · · · · · · · · · · · · · · · · ·	I
Upper power tilt ratio (¢≤1.02)	¢	¢	¢	¢
	Lower Detector	s (B)	1./	
Computer point	N0042	N0044	N0046	N0048
Present computer point reading				
Average computer point reading		· <u>····</u>	I	L
Lower power tilt ratio (¢≤1.02)	¢	¢	¢	¢

ATTACH additional copies of this page as necessary.

KEY

2 - 4 <b>1</b>	JOB PERFORMAN	JCE MEASURE
TASK TITLE:	RCA Exit with Contamination Alarm	
JPM No.:	N-151	REV: 0
TPO No.:		K&A No.: 2.3.1
TASK No.:	AM-027	K&A IMP: 2.6/3.0
CANDIDATE:		DATE:
EVALUATOR:		DATE:
The Candida	te: PASSED this JPM.	TIME STARTED:
	FAILED	TIME FINISHED:
CRITICAL EL	EMENTS: (*) 1,2	JPM TIME:
CRITICAL TI	ME: NA	APPROX COMPLETION TIME 5 MINUTES
EVALUATION	METHOD:	LOCATION:
	SIMULATE	IN PLANT SIMULATOR
GENERAL REF	ERENCES:	
1.	BwRP 5000-7, Rev. 2, Unescorted Acc	cess to and Conduct in Radiologically Posted
2.	Areas NGET Study Guide	to and conduct in Addiologically fosted
MATERIALS:	2	
1.	Braidwood Access Control	
2.	IPM-8 Personal Monitors	
TASK STANDA	RDS:	
1.	Demonstrate proper method to exit t	he RCA (Auxiliary Building).
TASK CONDIT	IONS:	
1. 2.	Plant is at any power level. Exit into the Aux. Building is requ	ired for NRC License Exam JPM N-89.
INITIATING (	CUES:	
1.	Upon exiting the Auxiliary Building	·.
NOTE: No Tas when t candid	sk Conditions or Initiating Cues nee the candidate is about to enter the date entering the IPM-8.	d to be given. This JPM is to be initiated IPM-8. Initiate this JPM prior to the
Note: Evalua RWP #_	ator must obtain the candidates RWP Exposure Limi	number and exposure limit t

1

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	N/A
RECORD START TIME				
Cue: IPM-8 Contamination monitor indicates alarm and a continuous tone sounds. *1. Re-monitor	Re-monitor If monitor alarms again, contact RP.	D		
Cue: IPM-8 Contamination monitor does not alarm.				
*2 Enter Portal monitor.	Wait for green light		ū	D
Cue: Red light alarms during first monitoring.	When red light appears; re-monitor.			
Cue: Red light alarms during second monitoring.	Contact RP for assistance.			
Cue: When contacted as Rad Protection, ask the candidate which RWP they are under and what is his/her exposure limit.	Candidates answer should match the RWP that they signed in under.			

RECORD STOP TIME:

COMMENTS:

.

.

Questions

## Question No: 1

8 1

An Alert Emergency has been declared on Unit 1 due to a LOCA. Two operators were in containment at the time of the LOCA. Both operators are out of the direct path of the LOCA. One operator fell as he was running and hit his head. He is unconscious and bleeding profusely from the head and his left ear. The other operator states that the injured man will die if he does not get help immediately. The injured man is too heavy for the other operator to get out of containment by himself. When asked, you volunteered to perform the operation.

What are the radiation exposure limits that should apply to this action and what individual must approve this exposure? (List all limits TEDE, Lens to the Eye and Extremities)

## **Expected Answer:**

**Exposure Limits:** 

- 25 rem TEDE (Whole Body)
- 75 rem to lens of the eye
- 250 rem to extremities (and any organs and skin)

Note: May also state that Station Director can authorize >25 Rem TEDE but not required for answer

Approval: The Station Director (Person in Command & Control)

## **Actual Answer:**

Candidate's response matched expected answer.

Sat \_\_\_\_ Unsat \_\_\_.

REFERENCE USE: YES

**K/A:** 2.4.29 2.6/4.0

Reference(s):BwZP 2000-13 " Emergency Personnel Dose Limits and Radiological Controls for Rescue<br/>and Recovery Operations", Rev. 0E1BwZP 2000-13A1 "Emergency Exposure Approval Form Rev 0E1

# ADMINISTRATIVE TOPICS SECTION A.4 RO

## **REFERENCE USE: YES**

Sat \_\_\_\_ Unsat \_\_\_.

# Question No: 2

Ŧ

A Site Emergency has been declared and the Evacuation Alarm has been sounded. What are the areas of assembly for both Licensed and Non-Licensed Operators?

\_\_\_\_\_

#### **Expected Answer:**

Control Room, Operation Support Center (OSC).

#### **Actual Answer:**

Candidate's response matched expected answer.

K/A: 2.4.29 2.6/4.0

**Reference(s):** BwZP 2000-10 "Assembly and Accountability of Personnel Rev 5.

**QA.4** 

# ADMINISTRATIVE TOPICS SECTION A.4 RO CANDIDATE QUESTION SHEET

## Question No: 1

£

An Alert Emergency has been declared on Unit 1 due to a LOCA. Two operators were in containment at the time of the LOCA. Both operators are out of the direct path of the LOCA. One operator fell as he was running and hit his head. He is unconscious and bleeding profusely from the head and his left ear. The other operator states that the injured man will die if he does not get help immediately. The injured man is too heavy for the other operator to get out of containment by himself. When asked, you volunteered to perform the operation.

What are the radiation exposure limits that should apply to this action and what individual must approve this exposure? (List all limits TEDE, Lens to the Eye and Extremities)

## Question No: 2

A Site Emergency has been declared and the Evacuation Alarm has been sounded. What are the areas of assembly for both Licensed and Non-Licensed Operators?

#### ADMINISTRATIVE WALKTHROUGH JOB PERFORMANCE MEASURE

TASK TITLE:	GSEP Classification			
JPM No.:	JPM-A-4 (SRO)		REV: 0	
			K&A No.:	2.4.41
TASK No.:	ZP-006		K&A IMP:	2.3/4.1
CANDIDATE:			DATE:	
EVALUATOR			DATE:	
The Candidat	te: PASSED	this JPM.	TIME STARTED:	
	FAILED		TIME FINISHED:	
CRITICAL ELE	EMENTS: (*) 1		JPM TIME:	an - *
CRITICAL TIN	4e: <b>NA</b>		APPROX COMPLETION	TIME <b>3</b> MINUTES
EVALUATION N	METHOD: PERFORM SIMULATE		LOCATION: IN PLANT SIMULATOR	
GENERAL REFE	ERENCES:			
1.	BwZP 200-1, "Braidwood	d Emergency	Action Levels" Rev.8	
MATERIALS:				
1. 2.	BwZP 200-1, "Braidwood Control Room Simulator	d Emergency r following	Action Levels" Rev.8 Operational Exam	
TASK STANDAR	RDS:			

1. Classify events for appropriate GSEP conditions per BwZP 200-1.

TASK CONDITIONS:

- 1. You are the Unit Supervisor.
- 2. The Unit has sustained a major casualty.

INITIATING CUES:

1. The Shift Manager requests you classify the plant conditions for the appropriate GSEP condition per BwZP 200-1.

1

STANDARDS

*1.	Classify Dynamic Scenario to determine appropriate GSEP Conditions.	Obtain copy of BwZP 200- 1 and classify event to determine appropriate GSEP Conditions.			
Dy: Apj	namic Scenario's, Mark plicable Scenario				
$   \times $	00-1 - MG-3 General Emergency	00-1	MG-3	Q	
o	00-2 - HU-2 Unusual Event	00-2	HU-2		
⊁	00-3 - MS-1 Site Emergency	00-3	MS-1		
米	00-4 - FA-1 Alert	00-4	FA-1		
×	00-5 - MA3/FA1 Alert	00-5	MA3/FA1		
o	00-6 - FA-1 Alert	00-6	FA-1		
o	00-7 - MA3/FA1 Alert	00-7	MA3/FA1		
*	00-8 - MS-3 Site Emergency	00-8	MS-3		
0	00-9 - FA-1 Alert	00-9	FA-1		
0	Spare - FA-1 Alert	Spare	FA-1		

COMMENTS:

\* Applicants evaluated on these scenarios