



June 6, 2001

PG&E Letter DCL-01-066

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 2
Special Report 01-03: Steam Generator Tube Plugging
During Unit 2 Tenth Refueling Outage

Dear Commissioners and Staff:

In accordance with Diablo Canyon Power Plant Technical Specifications 5.6.10a, this special report provides the number of steam generator (SG) tubes plugged during the Unit 2 tenth refueling outage completed during May 2001.

A total of 64 SG tubes were plugged as detailed in the following table.

SG	Plugged Tubes	Notes
2-1	6	None
2-2	25	None
2-3	9	None
2-4	24	None
Total	64	

If there are any questions regarding this special report, contact L. R. Exner at (805) 545-4302.

Sincerely,

Lawrence F. Womack

cc: Ellis W. Merschoff
David L. Proulx
Girija S. Shukla
Diablo Distribution
INPO

A001