



June 6, 2001

US Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Submittal of Monticello Monthly Operating Report for May 2001

In accordance with Monticello Technical Specification 6.7.A.3, the report of operating statistics for the Monticello Nuclear Generating Plant for the month of May is provided.

Please contact Douglas A. Neve, Project Manager – Licensing (Interim), at (763) 295-1353 if you require further information.

Douglas A. Neve
Project Manager – Licensing (Interim)

- c: Regional Administrator – III, NRC
- NRR Project Manager, NRC
- Sr. Resident Inspector, NRC
- Minnesota Dept. of Commerce
- J E Silberg

IE24

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-263
 UNIT Monticello
 DATE 6-1-1
 COMPLETED BY H. H. Paustian
 TELEPHONE 763/295-5151

MONTH OF May

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	587.	17	582.
2	586.	18	580.
3	585.	19	580.
4	587.	20	586.
5	582.	21	587.
6	417.	22	588.
7	587.	23	591.
8	587.	24	590.
9	554.	25	591.
10	590.	26	591.
11	587.	27	591.
12	588.	28	590.
13	586.	29	589.
14	586.	30	589.
15	585.	31	587.
16	584.		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-263
DATE 6-1-1
COMPLETED BY H. H. Paustian
TELEPHONE 763/295-5151

MONTH MAY

05-01-01
to Power operation.
05-06-01

05-06-01 Turbine stop valve #4 did not close during testing.
Power reduced to <45% while repairs performed.

05-06-01
to Power operation.
05-09-01

05-09-01 Power reduction to approximately 45% required due to
valving error during condensate demineralizer processing.

05-09-01
to Power operation.
05-31-01

Note: Power operation defined as essentially 100% of
rated power except for weekend load drops for
specified surveillance testing.

