

April 3, 1995

Mr. Donald A. Reid, Vice President
Operations
Vermont Yankee Nuclear Power Corporation
Ferry Road
Brattleboro, VT 05301

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M87809)

Dear Mr. Reid:

The Commission has issued the enclosed Amendment No. 144 to Facility Operating License No. DPR-28 for the Vermont Yankee Nuclear Power Station (VYNPS). This amendment is in response to your application dated August 27, 1993.

The amendment revises the VYNPS Technical Specifications to extend the Radioactive Effluent Release Report submittal frequency from semiannual to annual, to be consistent with revisions to 10 CFR 50.36a. The remaining portions of your application that relate to revisions to 10 CFR Part 20 are being reviewed separately.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register Notice.

Sincerely,

Original signed by:

Daniel H. Dorman, Project Manager
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures: 1. Amendment No. 144 to DPR-28
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

Docket File CGrimes
PUBLIC ACRS (4)
PDI-3 Plant OPA
SVarga OC/LFDCB
JZwolinski JLinville, RGI
PMcKee SKlementowicz
DDorman
SNorris
OGC
GHill (2)

9504060038 950403
PDR ADOCK 05000271
P PDR

CP-1
DFD
11

DOCUMENT NAME: G:\DORMAN\M87809.AMD

OFFICE	LA:PDI-3	PM:PDI-3	D:PDI-3	OGC	
NAME	SNorris	DDorman	PMcKee	C Marco	
DATE	03/24/95	03/27/95	04/13/95	03/30/95	03/ /95

OFFICIAL RECORD COPY

050054

NRG FILE CENTER COPY

April 3, 1995

Mr. Donald A. Reid, Vice President
Operations
Vermont Yankee Nuclear Power Corporation
Ferry Road
Brattleboro, VT 05301

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M87809)

Dear Mr. Reid:

The Commission has issued the enclosed Amendment No. 144 to Facility Operating License No. DPR-28 for the Vermont Yankee Nuclear Power Station (VYNPS). This amendment is in response to your application dated August 27, 1993.

The amendment revises the VYNPS Technical Specifications to extend the Radioactive Effluent Release Report submittal frequency from semiannual to annual, to be consistent with revisions to 10 CFR 50.36a. The remaining portions of your application that relate to revisions to 10 CFR Part 20 are being reviewed separately.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register Notice.

Sincerely,

Original signed by:

Daniel H. Dorman, Project Manager
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures: 1. Amendment No. 144 to DPR-28
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

Docket File CGrimes
PUBLIC ACRS (4)
PDI-3 Plant OPA
SVarga OC/LFDCB
JZwolinski JLinville, RGI
PMcKee SKlementowicz
DDorman
SNorris
OGC
GHill (2)

DOCUMENT NAME: G:\DORMAN\M87809.AMD

OFFICE	LA:PDI-3	PM:PDI-3	D:PDI-3	OGC	
NAME	SNorris	DDorman	PMcKee	C Marco	
DATE	03/24/95	03/27/95	04/3/95	03/30/95	03/ /95

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 3, 1995

Mr. Donald A. Reid, Vice President
Operations
Vermont Yankee Nuclear Power Corporation
Ferry Road
Brattleboro, VT 05301

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M87809)

Dear Mr. Reid:

The Commission has issued the enclosed Amendment No. ¹⁴⁴ to Facility Operating License No. DPR-28 for the Vermont Yankee Nuclear Power Station (VYNPS). This amendment is in response to your application dated August 27, 1993.

The amendment revises the VYNPS Technical Specifications to extend the Radioactive Effluent Release Report submittal frequency from semiannual to annual, to be consistent with revisions to 10 CFR 50.36a. The remaining portions of your application that relate to revisions to 10 CFR Part 20 are being reviewed separately.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register Notice.

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Dorman".

Daniel H. Dorman, Project Manager
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures: 1. Amendment No. 144 to DPR-28
2. Safety Evaluation

cc w/encls: See next page

Donald A. Reid, Vice President
Operations

Vermont Yankee Nuclear Power Station

cc:

Mr. Jay Thayer, Vice President
Yankee Atomic Electric Company
580 Main Street
Bolton, MA 01740-1398

G. Dana Bisbee, Esq.
Office of the Attorney General
Environmental Protection Bureau
State House Annex
25 Capitol Street
Concord, NH 03301-6937

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
Vermont Yankee Nuclear Power Station
U.S. Nuclear Regulatory Commission
P. O. Box 176
Vernon, VT 05354

R. K. Gad, III
Ropes & Gray
One International Place
Boston, MA 02110-2624

Chief, Safety Unit
Office of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Mr. Richard P. Sedano, Commissioner
Vermont Department of Public Service
120 State Street, 3rd Floor
Montpelier, VT 05602

Mr. David Rodham, Director
Massachusetts Civil Defense Agency
400 Worcester Rd.
P.O. Box 1496
Framingham, MA 01701-0317
ATTN: James Muckerheide

Public Service Board
State of Vermont
120 State Street
Montpelier, VT 05602

Chairman, Board of Selectmen
Town of Vernon
Post Office Box 116
Vernon, VT 05354-0116

Mr. Raymond N. McCandless
Vermont Division of Occupational
and Radiological Health
Administration Building
Montpelier, VT 05602

Mr. J. P. Pelletier, Vice President
Vermont Yankee Nuclear Power
Corporation
Ferry Road
Brattleboro, VT 05301

Mr. L. A. Tremblay
Senior Licensing Engineer
Vermont Yankee Nuclear Power
Corporation
580 Main Street
Bolton, MA 01740-1398

Mr. Robert J. Wanczyk, Plant Manager
Vermont Yankee Nuclear Power Station
P.O. Box 157, Governor Hunt Road
Vernon, VT 05354



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

VERMONT YANKEE NUCLEAR POWER CORPORATION

DOCKET NO. 50-271

VERMONT YANKEE NUCLEAR POWER STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 144
License No. DPR-28

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Vermont Yankee Nuclear Power Corporation (the licensee), dated August 27, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-28 is hereby amended to read as follows:


9504060046 950403
PDR ADDCK 05000271
P PDR

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 144, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Phillip F. McKee, Director
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: April 3, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 144

FACILITY OPERATING LICENSE NO. DPR-28

DOCKET NO. 50-271

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove

182
184
201
270
271
272
277
278

Insert

182
184
201
270
271
272
277
278

TABLE 4.8.1 NOTATION: (Cont'd)

- c. A composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sampling employed results in a specimen which is representative of the liquids released. Prior to analyses, all samples taken for the composite shall be thoroughly mixed in order for the composite sample to be representative of the effluent release.
- d. The principal gamma emitters for which the LLD specification will apply are exclusively the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141, and Ce-144. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level, but as "not detected". When unusual circumstances result in LLDs higher than required, the reasons shall be documented in the Annual Radioactive Effluent Release Report.

TABLE 4.8.2 NOTATION:

- a. See footnote a. of Table 4.8.1.
- b. Samples shall be changed at least once per 7 days and analyses shall be completed within 48 hours after removal from samplers. Sampling shall also be performed at least once per 24 hours for at least 7 days following each shutdown, startup or thermal power change exceeding 25% of rated thermal power in one hour, and analyses shall be completed within 48 hours of changing the samples. When samples collected for 24 hours are analyzed, the corresponding LLDs may be increased by a factor of 10. This requirement to sample at least once per 24 hours for 7 days applies only if: (1) analysis shows that the dose equivalent I-131 concentration in the primary coolant has increased more than a factor of 3 and the resultant concentration is at least 1×10^{-1} $\mu\text{Ci/ml}$; and (2) the noble gas monitor shows that effluent activity has increased more than a factor of 3.
- c. Sampling and analyses shall also be performed following shutdown, startup, or a thermal power change exceeding 25% of rated thermal power per hour unless: (a) analysis shows that the dose equivalent I-131 concentration in the primary coolant has not increased more than a factor of 3 and the resultant concentration is at least 1×10^{-1} $\mu\text{Ci/ml}$; and (2) the noble gas monitor shows that effluent activity has not increased more than a factor of 3.
- d. The principal gamma emitters for which the LLD specification will apply are exclusively the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135 and Xe-138 for gaseous emissions, and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144 for particulate emissions. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below LLD for the analyses should not be reported as being present at the LLD level for that nuclide, but as "not detected". When unusual circumstances result in LLDs higher than required, the reasons shall be documented in the Annual Radioactive Effluent Release Report.
- e. The ratio of the sample flow rate to the sampled stream flow rate shall be known for the time period covered by each dose or dose rate calculation made in accordance with Specifications 3.8.E.1, 3.8.F.1 and 3.8.G.1.
- f. The gaseous waste sampling and analysis program does not explicitly require sampling and analysis at a specified LLD to determine the I-133 release. Estimates of I-133 releases shall be determined by counting the weekly charcoal sample for I-133 (as well as I-131) and assume a constant release rate for the release period.

TABLE 3.9.3 NOTATION

- a Specific parameters of distance and direction sector from the centerline of the reactor and additional descriptions where pertinent, shall be provided for each and every sample location in Table 3.9.3 in a table and figure(s) in the ODCM. Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability, malfunction of automatic sampling equipment and other legitimate reasons. If specimens are unobtainable due to sampling equipment malfunction, every reasonable effort shall be made to complete corrective action prior to the end of the next sampling period. All deviations from the sampling schedule shall be documented in the annual Radiological Environmental Surveillance Report pursuant to Specification 6.7.C.3. It is recognized that, at times, it may not be possible or practicable to continue to obtain samples of the media of choice at the most desired location or time. In these instances, suitable alternative media and locations may be chosen for the particular pathway in question and appropriate substitutions made within 30 days in the radiological environmental monitoring program. In lieu of a Licensee Event Report and pursuant to Specification 6.7.C.1, identify the cause of the unavailability of samples for that pathway and identify the new location(s) for obtaining replacement samples in the next Annual Radioactive Effluent Release Report and also include in the report a revised figure(s) and table for the ODCM reflecting the new location(s).
- b One or more instruments, such as a pressurized ion chamber, for measuring and recording dose rate continuously may be used in place of, or in addition to, integrating dosimeters. For the purposes of this table, a Thermoluminescent Dosimeter (TLD) is considered to be one phosphor; two or more phosphors in a packet are considered as two or more dosimeters. Film badges shall not be used as dosimeters for measuring direct radiation. The 40 stations is not an absolute number. The frequency of analysis or readout for TLD systems will depend upon the characteristics of the specific system used and should be selected to obtain optimum dose information with minimal fading.
- c Airborne particulate sample filters shall be analyzed for gross beta radioactivity 24 hours or more after sampling to allow for radon and thoron daughter decay. If gross beta activity in air particulate samples is greater than ten times the yearly mean of control samples, gamma isotopic analysis shall be performed on the individual samples.
- d Gamma isotopic analysis means the identification and quantification of gamma-emitting radionuclides that may be attributable to the effluents from the facility.
- e The "upstream sample" shall be taken at a distance beyond significant influence of the discharge. The "downstream" sample shall be taken in an area beyond but near the mixing zone.
- f Composite sample aliquots shall be collected at time intervals that are very short (e.g., hourly) relative to the compositing period (e.g., monthly) in order to assure obtaining a representative sample.
- g Each meteorological sector shall have an established "inner" and an "outer" monitoring location based on ease of recovery (i.e., response time) and year-round accessibility.
- h Sample collection will be performed weekly whenever the main plant stack effluent release rate of I-131, as determined by the sampling and analysis program of Table 4.8.2, is equal to or greater than 1×10^{-1} uCi/sec. Sample collection will revert back to semimonthly no sooner than at least two weeks after the plant stack effluent release rate of I-131 falls and remains below 1×10^{-1} uCi/sec.

VYNPS

Letter from L. A. Tremblay, Jr. (VYNPC) to USNRC, "Supplemental Information to VYNPC April 19, 1990 Response Regarding FROSSTEY-2 Fuel Performance Code," BVY 90-054, dated May 10, 1990 (Approved by NRC SER, dated September 24, 1992).

Letter from L. A. Tremblay, Jr. (VYNPC) to USNRC, "Responses to Request for Additional Information on FROSSTEY-2 Fuel Performance Code," BVY 91-024, dated March 6, 1991 (Approved by NRC SER, dated September 24, 1992).

Letter from L. A. Tremblay, Jr. (VYNPC) to USNRC, "LOCA-Related Responses to Open Issues on FROSSTEY-2 Fuel Performance Code," BVY 92-39, dated March 27, 1992 (Approved by NRC SER, dated September 24, 1992).

Letter from L. A. Tremblay, Jr. (VYNRC) to USNRC, "FROSSTEY-2 Fuel Performance Code - Vermont Yankee Response to Remaining Concerns," BVY 92-54, dated May 15, 1992 (Approved by NRC SER, dated September 24, 1992).

Report, "Loss-of-Coolant Accident Analysis for Vermont Yankee Nuclear Power Station," NEDO-21697, August 1977, as amended (Approved by NRC SER, dated November 30, 1977).

Report, "General Electric Standard Application for Reactor Fuel (GESTARII)," NEDE-24011-P-A, GE Company Proprietary (the latest NRC-approved version will be listed in the COLR).

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met. The COLR, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

B. Reportable Occurrences

This section deleted.

C. Unique Reporting Requirements

1. Annual Radioactive Effluent Release Report

- a. Within 90 days after January 1 of each year, a report shall be submitted covering the radioactive content of effluents released to unrestricted areas during the previous calendar year of operation.

- b. The Annual Radioactive Effluent Release Report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit as outlined in Regulatory Guide 1.21, Revision 1, June 1974, "Measuring, Evaluating and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants", with data summarized on a quarterly basis following the format of Appendix B thereof. For solid wastes the format for Table 3 in Appendix B of Regulatory Guide 1.21 shall be supplemented with three additional categories: class of solid wastes (as defined by 10CFR Part 61), type of container (e.g., LSA, Type A, Type B, Large Quantity), and solidification agent or absorbent, if any.

In addition, the Annual Radioactive Effluent Release Report shall include an annual summary of hourly meteorological data collected over the previous year. This annual summary may be either in the form of an hour-by-hour listing on magnetic tape of wind speed, wind direction, atmospheric stability, and precipitation (if measured), or in the form of joint frequency distributions of wind speed, wind direction, and atmospheric stability.* This same report (or a supplement to it to be submitted within 180 days of January 1 each year) shall include an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the unit during the previous calendar year. The Annual Radioactive Effluent Release Report (or supplemental dose report) shall also include an assessment of the radiation doses from radioactive effluents to member(s) of the public due to any allowed recreational activities inside the site boundary during the previous calendar year. All assumptions used in making these assessments (e.g., specific activity, exposure time and location) shall be included in these reports. For any batch or discrete gas volume releases, the meteorological conditions concurrent with the time of release of radioactive materials in gaseous effluents (as determined by sampling frequency and measurement) shall be used for determining the gaseous pathway doses. For radioactive materials released in continuous effluent streams, quarterly average meteorological conditions concurrent with the quarterly release period shall be used for determining the gaseous pathway doses. The assessment of radiation doses shall be performed in accordance with the Off-Site Dose Calculation Manual (ODCM).

* In lieu of submission with the Annual Radioactive Effluent Release Report, the licensee has the options of retaining this summary of required meteorological data in a file that shall be provided to the NRC upon request.

VYNPS

With the limits of Specification 3.8.M.1 being exceeded during the calendar year, the Annual Radioactive Effluent Release Report (or supplemental dose report) shall also include an assessment of radiation doses to the likely most exposed real member(s) of the public from reactor releases (including doses from primary effluent pathways and direct radiation) for the previous calendar year to show conformance with 40CFR190, Environmental Radiation Protection Standards for Nuclear Power Operation.

The Annual Radioactive Effluent Release Report shall include a list and description of unplanned releases from the site to site boundary of radioactive materials in gaseous and liquid effluents made during the reporting period.

With the quantity of radioactive material in any outside tank exceeding the limit of Specification 3.8.D.1, describe the events leading to this condition in the next Annual Radioactive Effluent Release Report.

If inoperable radioactive liquid effluent monitoring instrumentation is not returned to operable status prior to the next release pursuant to Note 4 of Table 3.9.1, explain in the next Annual Radioactive Effluent Release Report the reason(s) for delay in correcting the inoperability.

If inoperable gaseous effluent monitoring instrumentation is not returned to operable status within 30 days pursuant to Note 5 of Table 3.9.2, explain in the next Annual Radioactive Effluent Release Report the reason(s) for delay in correcting the inoperability.

With milk samples no longer available from one or more of the sample locations required by Table 3.9.3, identify the cause(s) of the sample(s) no longer being available, identify the new location(s) for obtaining available replacement samples, and include revised ODCM figure(s) and table(s) reflecting the new location(s) in the next Annual Radioactive Effluent Release Report.

With a land use census identifying one or more locations which yield at least a 20 percent greater dose or dose commitment than the values currently being calculated in Specification 4.8.G.1, identify the new location(s) in the next Annual Radioactive Effluent Release Report.

Changes made during the reporting period to the Process Control Program (PCP) and to the Off-Site Dose Calculation Manual (ODCM), shall be identified in the next Annual Radioactive Effluent Release Report.

6.10 INTEGRITY OF SYSTEMS OUTSIDE CONTAINMENT

A program to reduce leakage from systems outside containment that would or could contain highly radioactive fluids during a serious transient or accident to as low as practical levels will be implemented. This program shall include the following:

- A. Provisions establishing preventive maintenance and periodic visual inspection requirements.
- B. System leakage inspections, to the extent permitted by system design and radiological conditions, for each system at a frequency not to exceed refueling cycle intervals. The systems subject to this testing are: (1) Residual Heat Removal, (2) Core Spray, (3) Reactor Water Cleanup, (4) HPCI, (5) RCIC, and (6) Sampling Systems.

6.11 IODINE MONITORING

A program which will ensure the capability to accurately determine the airborne iodine concentration in vital areas* under accident conditions will be implemented. This program shall include the following:

- A. Training of personnel.
- B. Procedures for monitoring.
- C. Provisions for maintenance of sampling and analysis equipment.

6.12 PROCESS CONTROL PROGRAM (PCP)

A process control program shall contain the sampling, analysis, tests, and determinations by which wet radioactive waste from liquid systems is assured to be converted to a form suitable for off-site disposal.

- A. Licensee initiated changes to the PCP:
 - 1. Shall be submitted to the Commission in the Annual Radioactive Effluent Release Report for the period in which the change(s) was made. This submittal shall contain:
 - a. Sufficiently detailed information to support the rationale for the change without benefit of additional or supplemental information.
 - b. A determination that the change did not reduce the overall conformance of the dewatered spent resins/filter media waste product to existing criteria for solid waste shipments and disposal.
 - c. Documentation of the fact that the change has been reviewed by PORC and approved by the Manager of Operations (MOO).
 - 2. Shall become effective upon review by PORC and approval by the Manager of Operations (MOO).

* Areas requiring personnel access for establishing hot shutdown conditions.

6.13 OFF-SITE DOSE CALCULATION MANUAL (ODCM)

An Off-Site Dose Calculation Manual shall contain the current methodology and parameters used in the calculation of off-site doses due to radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring alarm/trip setpoints, and in the conduct of the environmental radiological monitoring program.

A. Licensee initiated changes to the ODCM:

1. Shall be submitted to the Commission in the Annual Radioactive Effluent Release Report for the period in which the change(s) was made effective. This submittal shall contain:
 - a. Sufficiently detailed information to support the rationale for the change without benefit of additional or supplemental information. Information submitted should consist of a package of those pages of the ODCM which were changed with each page numbered and provided with the revision number, together with appropriate analyses or evaluations justifying the change(s).
 - b. A determination that the change will not reduce the accuracy or reliability of dose calculations or setpoint determinations.
 - c. Documentation of the fact that the change has been reviewed by PORC and approved by the Manager of Operations (MOO).
2. Shall become effective upon review by PORC and approved by the Manager of Operations (MOO).

6.14 MAJOR CHANGES TO RADIOACTIVE LIQUID, GASEOUS, AND SOLID WASTE TREATMENT SYSTEMS*

Licensee-initiated major changes to the radioactive waste systems (liquid, gaseous, and solid):

- A. Shall be reported to the Commission in the Annual Radioactive Effluent Release Report for the period in which the evaluation was reviewed by the PORC. The discussion of each change shall contain:
 1. A summary of the evaluation that led to the determination that the change could be made in accordance with 10CFR Part 50.59;
 2. Sufficient detailed information to support the reason for the change without benefit of additional or supplemental information;
 3. A detailed description of the equipment, components, and processes involved and the interfaces with other plant systems;

* Licensee may choose to submit the information called for in this Specification as part of the annual FSAR update.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 144 TO FACILITY OPERATING LICENSE NO. DPR-28

VERMONT YANKEE NUCLEAR POWER CORPORATION

VERMONT YANKEE NUCLEAR POWER STATION

DOCKET NO. 50-271

1.0 INTRODUCTION

By letter dated August 27, 1993, the Vermont Yankee Nuclear Power Corporation (the licensee) requested amendments to the Technical Specifications (TS) for the Vermont Yankee Nuclear Power Station in support of its plan to implement the revised 10 CFR Part 20 and 10 CFR 50.36a. This safety evaluation addresses the licensee's proposed TS changes related to the revision to 10 CFR 50.36a. The proposed amendment would change the Vermont Yankee TS to extend the Radioactive Effluent Release Report submittal frequency from semiannual to annual. The requested changes are in accordance with the change in Title 10, Code of Federal Regulations, Section 50.36a, "Technical specifications on effluents from nuclear power reactors," effective October 1, 1992. The remaining portions of the request relating to revisions to 10 CFR Part 20 are being reviewed separately.

2.0 EVALUATION

As indicated above, 10 CFR 50.36a was changed to require that a report to the Commission specifying the quantity of each of the principal radionuclides released to unrestricted areas during the previous 12 months should be prepared and submitted. The new regulation also requires that the time interval between submissions of the reports must be no longer than 12 months. Previously, 10 CFR 50.36a required these reports to be submitted semiannually and within 60 days after January 1 and July 1 of each year.

The licensee has proposed TS changes that are administrative in nature and consistent with the revised reporting requirement in 10 CFR 50.36a. The proposed changes are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Vermont State official was notified of the proposed issuance of the amendment. The State official had no comments.

9504060049 950403
PDR ADDCK 05000271
P PDR

4.0 ENVIRONMENTAL CONSIDERATION

The amendment relates to changes in recordkeeping, reporting, or administrative procedures or requirements. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: S. Klementowicz

Date: April 3, 1995