

June 18, 2001

MEMORANDUM TO: File

FROM: Jack N. Donohew, Senior Project Manager, Section 2  
Project Directorate IV */RA/*  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

SUBJECT: IMPLEMENTATION OF GENERIC LETTER (GL) 96-06 FOR WOLF  
CREEK GENERATING STATION (TAC NO. M96887)

The attached e-mails from the Wolf Creek Nuclear Operating Corporation stated that (1) all necessary modifications for GL 96-06 were installed in Refueling Outage 10, and (2) the analyses for GL 96-06 were revised after the outage and submitted in a letter to NRC dated February 12, 2001 (ET 01-0006) for the Wolf Creek Generating Station. The revised analyses did require any further modifications to the plant.

Docket No. 50-482

Attachments: 1. E-mail dated June 12, 2001  
2. E-mail dated June 7, 2001

June 18, 2001

MEMORANDUM TO: File

FROM: Jack N. Donohew, Senior Project Manager, Section 2  
Project Directorate IV /RA/  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

SUBJECT: IMPLEMENTATION OF GENERIC LETTER (GL) 96-06 FOR WOLF  
CREEK GENERATING STATION (TAC NO. M96887)

The attached e-mails from the Wolf Creek Nuclear Operating Corporation stated that (1) all necessary modifications for GL 96-06 were installed in Refueling Outage 10, and (2) the analyses for GL 96-06 were revised after the outage and submitted in a letter to NRC dated February 12, 2001 (ET 01-0006) for the Wolf Creek Generating Station. The revised analyses did require any further modifications to the plant.

Docket No. 50-482

Attachments: 1. E-mail dated June 12, 2001  
2. E-mail dated June 7, 2001

DISTRIBUTION:  
PUBLIC  
PDIV-2 Reading  
RidsNrrPMJDonohew  
RidsNrrLAEPeyton

**Accession No: ML011650501**

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	JDonohew	EPeyton	SDembek
DATE	6/18/01	6/18/01	

OFFICIAL RECORD COPY

E-mail Dated June 12, 2001

**From:** Wideman Steven G <stwidem@WCNOC.com>  
**To:** "Donohew Jack" <JND@nrc.gov>  
**Date:** 6/12/01 11:15AM  
**Subject:** RE: Implementation of Generic Letter 96-06.

All analyses were completed prior to Refueling Outage 10 in the spring of 1999. All necessary modifications were installed during Refueling Outage 10. Therefore, by June 29, 1999, with the exception of later staff questions about the analysis, and the changes made to the analysis due to those questions, we were finished with the effort needed to satisfy ourselves that we had satisfactorily addressed the issues identified in Generic Letter 96-06.

As a result of NRC staff questions about the WCNOC analysis provided by letter dated June 29, 1999 (WM 99-0042), WCNOC revised the analysis for the water hammer issue. WCNOC letter dated February 12, 2001 (ET 01-0006) provided the results of the revised analysis. No further modifications to the plant were needed as a result of the revised analysis.

Let me know if you need anything further.

> -----  
> From: Jack Donohew[SMTP:JND@nrc.gov]  
> Sent: Thursday, June 07, 2001 3:11 PM  
> To: kehall@wcnoc.com; stwidem@wcnoc.com  
> Subject: Implementation of Generic Letter 96-06.  
>  
> The question I sent to you in my previous email [(dated 6/7/01 and shown below)]  
> on this issue means that  
> the letters of February 29, 2000 (ET 00-0010), and February 21, 2001 (ET  
> 01-0006), which were submitted on GL 96-06 after the June 29, 1999,  
> letter, did not identify any additional analyzes and modification needed  
> to be completed in response to GL 96-06? <JND>  
>

**CC:** Hall Kenneth W <kehall@WCNOC.com>, Selbe William L

E-mail Dated June 7, 2001

**From:** Jack Donohew  
**To:** Ken Hall (office); Steve Wideman  
**Date:** 6/7/01 4:03PM  
**Subject:** Implementation of GL 96-06 Analyses and Modifications

By the letter dated June 29, 1999 (WM 99-0042), it is stated that "The purpose of this letter is to inform you that WCNOG has completed the analyzes and modifications to address the concerns discussed in Reference 1 [NRC Generic Letter 96-06]."

By this statement, I conclude that WCNOG has implemented GL 96-06 by June 29, 1999. Am I interpreting the statement correctly.

<JND>