OCT 1 8 1982

Docket Nos. 50-272 50-311

٠

Mr. Richard A. Uderitz Vice President - Nuclear Public Service Electric and Gas Company Mail Code T15A - P. O. Box 570 Newark, New Jersey 07101

Distribution: Docket File DBrinkman ACRS (10) NRC PDR Local PDR **OPA** ORB #1 Rda RDiggs DEisenhut NSIC CParrish ASLAB R. Ballard WRoss LJHarmon, IE File (2) OFLD SECY ELJordan DEQA:IE TBarnhart LSchneider JMTaylor, DRP:IE

Dear Mr. Uderitz:

The Commission has issued the enclosed Amendment No. 48 to Facility Operating License No. DPR-70 and Amendment No. 13 to Facility Operating License No. DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Appendices A and B Technical Specifications in response to your application transmitted by letter dated August 10, 1981 and modified by letter dated June 22, 1982.

These amendments revise the Radiological Safety and Environmental Technical Specifications related to process and effluent monitors to agree with existing plant conditions.

Copies of the Safety Evaluation, the Environmental Impact Appraisal and the Notice of Issuance and Negative Declaration are also enclosed.

Sincerely.

ORIGINAL SIGNED

William J. Ross, Project Manager **Operating Reactors Branch #1** Division of Licensing

Enclosures:

- 1. Amendment No. 48 to DPR-70
- 2. Amendment No. 13 to DPR-75
- 3. Safety Evaluation
- 4. Environmental Impact Appraisal
- Notice of Issuance/Negative Declaration 5.

cc w/encls:

	See next p	a ge			FR N	LOTICIE	_
8210 PDR	270352 8210 ADOCK 05000	018 0272	~		1 JUE	NOMEN	Γ
P		PDR			THUL	\mathcal{N}^{*}	
	SP		_	<u> </u>		T	
	DL:ORB#1	DL:ORB#1	DL:089#1	₽ 5 ;/PR	OELD	[
	CParrish	WRoss	SAVarga	GCLainas	M.KARMA		****
SURNAME	10/18/82	10/4/82	DY AP2	0/6/82	Φ/ <u>¢</u> /82		
				220000			
C FORM 318	(10-80) NBCM 0240		OFFICIAL	RECORD C	UPT		USGPO: 1981335-960

Mr. R. A. Uderitz Public Service Electric and Gas Company

cc: Mark J. Wetterhahn, Esquire Conner and Wetterhahn Suite 1050 1747 Pennsylvania Avenue, NW Washington, D. C. 20006

> Richard Fryling, Jr., Esquire Assistant General Solicitor Public Service Electric and Gas Company 80 Park Place Newark, New Jersey 07101

المراجع المراجع المراجع والمحاجب والمتحدين والمتحدين والمتعاد المحاج

Gene Fisher, Bureau of Chief Bureau of Radiation Protection 380 Scotch Road Trenton, New Jersey 08628

Mr. Henry J. Midura, General Manager -Salem Operations
Public Service Electric and Gas Company
P. O. Box 168
Hancocks Bridge, New Jersey 08038

Salem Free Library 112 West Broadway Salem, New Jersey 08079

Leif J. Norrholm, Resident Inspector Salem Nuclear Generating Station U. S. Nuclear Regulatory Commission Drawer I Hancocks Bridge, New Jersey 08038

Richard F. Engel Deputy Attorney General Department of Law and Public Safety CN-112 State House Annex Trenton, New Jersey 08625

Samuel E. Donelson, Mayor Lower Alloways Creek Township Municipal Hall Hancocks Bridge, New Jersey 08038 Richard B. McGlynn, Commissioner Department of Public Utilities State of New Jersey 101 Commerce Street Newark, New Jersey 07102

Mr. Edwin A. Liden, Manager Nuclear Licensing and Regulation Public Service Electric and Gas Co. Mail Code T16D - P.O. Box 570 Newark, New Jersey 07101

Regional Radiation Representative EPA Region II 26 Federal Plaza New York, New York 10007

Mr. R. L. Mittl, General Manager -Corporate Quality Assurance Public Service Electric and Gas Company Mail Code T16D - P.O. Box 570 Newark, New Jersey 07101

Ronald C. Haynes Regional Administrator - Region⁴ U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancocks Bridge, New Jersey 08038

Mr. Alfred C. Coleman, Jr. Mrs. Eleanor G. Coleman 35 K Drive Pennsville, New Jersey 08070

Mr. Dale Bridenbaugh M.H.B. Technical Associates 1723 Hamilton Avenue San Jose, California 95125



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC AND GAS COMPANY PHILADELPHIA ELECTRIC COMPANY DELMARVA POWER AND LIGHT COMPANY ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 48 License No. DPR-70

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated August 10, 1981 and modified by letter dated June 22, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.



- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 48, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION even A. Operating Reactors Branch #1 Division of Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: October 18, 1982

ATTACHMENT TO LICENSE AMENDMENT NO.48 FACILITY OPERATING LICENSE NO. DPR-70 DOCKET NO. 50-272

Charles and the second s

Revise Appendix A as follows:

Remove Pages	Insert Pages
3/4 3-18	3/4 3-18
3/4 3-36	3/4 3-36

Revise Appendix B as follows:

Remove Pages	<u>Insert Pages</u>
2.3-21	2.3-21
2.3-23	2.3-23

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FI	UNCTION	<u>AL UNIT</u>	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	CHANNELS OPERABLE	APPLICABLE MODES	ACTION
	b.	Phase "B" Isolation					
		1) Manual	2 sets of 2	1 set of 2	? sets of 2	1, 2, 3, 4	18
		2) Automatic Actuation Logic	2	1	2	1, 2, 3, 4	13
		3) Containment PressureHigh-Hig	4 h	2	3	1, 2, 3	16
	c.	Purge and Exhaust Isolation		•			
		1) Manual	2	1	2	1, 2, 3, 4	17
		2) Containment Atmo- sphere Radioactivi High	3 ty-	1	2**	1, 2, 3, 4	17
4	. STE	AM LINE ISOLATION					
	ð.	Manuál	1/steam line	l/steam line	1/operating steam line	1, 2, 3	18
	b.	Automatic Actuation Logic	2	1	2	1, 2, 3	13
	с.	Containment Pressure High-High	4	2	3	1, 2, 3	16
		niyu-niyu		• •			

The unit vent sampling monitor may also function in this capacity, with lowered setpoints, when the purge/pressure-vacuum relief isolation valves are open.

SALEM - UNIT 1

3/4 3-18

Amendment No.

48

ŦŦ

TABLE 3.3-6

RADIATION MONITORING INSTRUMENTATION

INS	TRUME	NT	•	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ALARM/TRIP SETPOINT	MEASUREMENT RANGE	<u>ACT ION</u>
1.'	AREA	MON	ITORS	•				
	a.	Fue1	Storage Pool Area	1	*	< 15 mR/hr	10 ⁻¹ - 10 ⁴ mR/hr	19
2.	PROC	ESS	MONITORS		•			
	ā.	Cont 1)	ainment Gaseous Activity a) Purge & Pressur Vacuum Relief	1# e-	1 2 3 4 8 6	< 2 x background	$10^{1} - 10^{6}$ com	22
			b) RCS Leakage Detection		1, 2, 3 & 4	N/A	10 ¹ - 10 ⁶ cpm	20
		2)	Air Particulate Activity a) Purge & Pressur	1/ e-				·
			Vacuum Keller Isolation		1, 2, 3, 4 & 6	2 x background	10 ¹ - 10 ⁶ cpm	22
			D) RCS Leakage Detection		1, 2, 3 & 4	N/A	10 ¹ - 10 ⁶ cpm	20
		3)	Fixed Filter lod Purge & Pressur Vacuum Boliof	ine- e -			•	
			isolation .	1#	1, 2, 3, 4 & 6	2 x background	10 ¹ - 10 ⁶ cpm	22

* With fuel in the storage pool or building.

The unit vent sampling monitor may also function in this capacity, with lowered when the purge/pressure-vacuum relief isolation valves are open. setpoints.

3/4 3-36

SALEM -

UNIT

ं 🌶

Amendment No. 48

.

TABLE 2.3-2

Gateous Source	Sampling Frequency and Analysis	Type of Activity Analysis	Detectable Concentrations (arCi/mi) ⁴
A. Waste Gas Decay Tank Releases	Each Tank to	Principal Gamma Emitters	10-4*
•	DE KEIENZEG	H·3	10-6
B. Containment Purge Releases	Each Purge C	Principal Gamma Emitters	10-4*
•		H-3	10-4
C. Condenser Air Ejector	Monthly	Principal Gamma Emitters	10 ^{-4^{h, e}}
		H-3	10-4
D. Environmental Release Points	Monthly	Principal Gamma Emitters	10 ^{4^{b, c}}
• •	(Gas Samples)	н.з	10-*
	Weekly (Charcoal Sample)	1-131	10-12
	• Monthly (Charcoal Sample)	1-133, 1-135	10-10
• •	Weekly (Particulates) ^d	Principal Gamma Emitters (Ba-La-140, I-131 and others)	10.11
	Monthly Composite ^d	-	
	(Particulates)	Gross a	• 10-11
	Quarterly Composite ^d (Particulates)	Sr-89, Sr-90	10-11

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS

^a The above detectability limits for activity analysis are based on technical feasibility and on the potential significance In the environment of the quantities released. For some nuclides, lower detection limits may be readily achievable, and when nuclides are measured below the stated limits, they should also be reported.

^bFor certain mixtures of gamma emitters, it may not be possible to measure radionuclides at levels near their sensitivity limits when other nuclides are present in the sample at much higher levels. Under these circumstances, it will be more appropriate to calculate the levels of such radionuclides using observed ratios with those radionuclides which are measurable.

Analyses shall also be performed following each refueling, startup, or similar operational occurrence which could alter the mixture of radionuclides.

To be representative of the average quantities and concentrations of radioactive materials in particulate form released in gaseous effluents, samples should be collected in proportion to the rate of flow of the effluent stream.

C Not applicable to Pressure-Vacuum Relief sperations

SALEM UNIT 1

2.3-21

Amendment No. 48

TABLE 2.3-4

SALEN STATION GASEOUS WASTE SYSTEN LOCATION OF PROCESS AND EFFLUENT MONITORS AND SAMPLERS REQUIRED BY TECHNICAL SPECIFICATIONS

•	Radiation	Auto Control to	Continuous	Grab	Messurèment				
Process Stream or Release Point	Alarm	Isolation Valve	Hon1tor (Station	Noble Ges	1	Particulate	H-J	Alpha
Haste Gas Decay Tanks				x	X	x	×	x	x
Condenser Air Removal System	×		×	x	×	x	×	x	x
Plant Vent	×	Xe	x .	×	×	x	×	x	x
Containment Purge/Pressure - Vacuum Relief				×	×	x	×	x	x
Building Ventilation Systems									
Auxillary Building and Radveste Ares ⁶		•		хc	×	x	×	x	x
Fuel Handling & Storage Building [®]				X.e	X	x	X	x	X -
									,
Furbine Gland Seat Condenser				Хc	x	x	×	X	X
					•				

Since these process streams or building ventilation systems are routed to the plant vent, the need for a continuous meditor at the individual discharge point to the main enhant duct is eliminated. One continuous meditor at the final release point is sufficient.

Automatically isolates Waste Gas Discharge Line on HIGH RADIATION signal from Gaseous Monitor, RélC. This monitor (RélC) along with RélA and RélB will initiate isolation of Containment Purge/Pressure-Vacuum Relief System on HIGH RADIATION also.

Grab sample stations from which monthly gas samples (Table 2.3-2) are to be taken. Also, grab samples should be taken and measured to detexains the "
process stream or building ventilation system source whenever an unexplained increase is indicated by the plant vent sampler-monitors.

2.3-23



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC AND GAS COMPANY PHILADELPHIA ELECTRIC COMPANY DELMARVA POWER AND LIGHT COMPANY ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 13 License No. DPR-75

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated August 10, 1981 and modified by letter dated June 22, 1982 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:
 - (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 13, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION even A: Operating Reactors Brànch #1 Division of Licensing

Hand Hall Market and Ma

Attachment: Changes to the Technical Specifications

Date of Issuance: October 18, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 13

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages	Insert Pages
3/4 3-18	3/4 3-18
3/4 3-39	3/4 3-39

Revise Appendix B as follows:

Remove Pages	Insert Pages
2.3-21	2.3-21
2.3-23	2.3-23

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FU	NCTION	L UNIT		TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
	b.	Phase	"B" Isolation					
		1)	Manual	2 sets of 2	1 set of 2	2 sets of 2	1, 2, 3, 4	18
		2)	Automatic Actuation Logic	2	1	2	1, 2, 3, 4	13
	·	3)	Containment PressureHigh-High	4	2	3	1, 2, 3	16
	с.	Conta Isola	inment Ventilation					
		1)	Manua 1	2	1	2	1, 2, 3, 4	17
		2)	Automatic Actuation Logic	-2	1	2	1, 2, 3, 4	13
		3)	Containment Atmo- sphere Gaseous Radioactivity-High	6 **	1	1	1, 2, 3, 4	17
4.	STE	AM LIN	E ISOLATION					
	ð.	Manu	al	2/steam line	1/steam line	1/operating steam line	1, 2, 3	21
	b.	Auto Actu	matic ation Logic	. 2	1	2	1, 2, 3	20
	c.	Cont High	ainment Pressure -High	4	2	3	1, 2, 3	16

The unit vent sampling monitor may also function in this capacity, with lowered setpoints, when the purge/pressure-vacuum relief isolation valves are open.

\$

SALEM - UNIT

N

3/4 3-18

Amendment

No.

			•			
INS	STRUMENT	MINTMUM Channels Operable	APPLICABLE MODES	ALARM/TRIP SETPOINT	MEASUREMENT RANGE	ACTION
1.	AREA MONITORS					
	a. Fuel Storage Pool Area	1	*	≦ 15 mR/hr	$10^{-1} - 10^4 \text{ mR/hr}$	23
2.	PROCESS MONITORS	• ,				
	a. Containment 1) Gaseous Activity a) Purge & Pressu	re-]**			·	
	Vacuum Relief Isolation	· · · · ·	1, 2, 3, 4 & 6	≤ 4.5 x 10 ⁻² C1/Sec	10 ¹ - 10 ⁶ cpm	25
	b) RCS Leakage Detection	1	1, 2, 3 & 4	N/A	10 ¹ - 10 ⁶ cpm	24
	2) Particulate Activi RCS Leakage Detection	ty - 1	1, 2, 3 & 4	N/A	10 ¹ - 10 ⁶ ср м	24
	<u>IN</u> 1. 2.	INSTRUMENT 1. AREA MONITORS a. Fuel Storage Pool Area 2. PROCESS MONITORS a. Containment 1) Gaseous Activity a) Purge & Pressu Vacuum Relief Isolation b) RCS Leakage Detection 2) Particulate Activity RCS Leakage Detection	INSTRUMENTMINIMUM CHANNELS OPERABLE1. AREA MONITORSa. Fuel Storage Pool Area12. PROCESS MONITORSa. Containment 1) Gaseous Activity a) Purge & Pressure- Vacuum Relief Isolationb) RCS Leakage Detectionc) Particulate Activity - 1 RCS Leakage Detection	MINIMUH CHANNELS OPERABLEAPPLICABLE MODESINSTRUMENTOPERABLEMODES1. AREA MONITORS*a. Fuel Storage Pool Area12. PROCESS MONITORS*a. Containment 1) Gaseous Activity a) Purge & Pressure- Isolation1**b) RCS Leakage Detection11, 2, 3 & 42) Particulate Activity - 1 RCS Leakage Detection1, 2, 3 & 4	MINIMUM CHANNELS OPERABLEAPPLICABLE MODESALARM/TRIP SETPOINTINSTRUMENTOPERABLEAPPLICABLE MODESALARM/TRIP SETPOINT1. AREA MONITORSa. Fuel Storage Pool Area1*a. Fuel Storage Pool Area1* $\leq 15 \text{ mR/hr}$ 2. PROCESS MONITORSa. Containment 1) Gaseous Activity a) Purge & Pressure- Isolation1, 2, 3, 4 & 6 $\leq 4.5 \times 10^{-2}$ Ci/Secb) RCS Leakage Detection11, 2, 3 & 4N/A2) Particulate Activity - 1 RCS Leakage Detection1, 2, 3 & 4N/A	MINIMUM CHANNELS OPERABLEAPPLICABLE MODESALARM/TRIP SETPOINTMEASUREMENT RANGE1. AREA MONITORSa. Fuel Storage Pool Area1* $\leq 15 \text{ mR/hr}$ $10^{-1} - 10^4 \text{ mR/hr}$ 2. PROCESS MONITORSa. Containment 1) Gaseous Activity a) Punge & Pressure- Isolation1, 2, 3, 4 & 6 $\leq 4.5 \times 10^{-2}$ $10^1 - 10^6 \text{ cpm}$ b) RCS Leakage Detection11, 2, 3 & 4N/A $10^1 - 10^6 \text{ cpm}$ 2) Particulate Activity - 1 RCS Leakage Detection1, 2, 3 & 4N/A $10^1 - 10^6 \text{ cpm}$

TABLE 3.3-6

RADIATION MONITORING INSTRUMENTATION

* With fuel in the storage pool or building.

** The unit vent sampling monitor may also function in this capacity, with lowered setpoints, when the purge/pressure-vacuum relief isolation valves are open.

Amendment No. 13

3/4 3-39

SALEM - UNIT 2

TABLE 2.3-2

Gaseous Source	-Sampling Frequency and Analysis	Type of Activity Analysis	Detectable Concentrations (sci/mi)*
A. Waste Gas Decay Tank Releases	Each Tank to	Principal Gamma Emitters	10-4 *
•	DE KEIEESEG	H-3	10-6
B. Containment Purge Releases	Each Purge C .	Principal Gamma Emitters	10 ^{-4[€]}
•	•	H-3	10-+
C. Condenser Air Ejector	Monthly	Principal Gamma Emitters	10 ^{-44, 4}
		H-3	10-4
D. Environmental Release Points	Monthly	Principal Gamma Emitters	10 ^{-4⁹. ^c}
. • •	(Gas Samples)	H-3	• 10 ⁻⁴
	Weekly (Charcoal Sampic)	1-131	10-12
	· Monthiy (Charcoal Sample)	1-133, 1-135	10-10
•	Weekly (Particulates) ^d	Principal Gamma Emitters (Ba-La-140, I-131 and others)	10 ⁻¹¹
•	Monthly Composite ^d		
•••	(Particulates)	Gross a	• 10-11
	Quarterly Composite [®] (Particulates)	Sr-89, Sr-90	10-11

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS

^aThe above detectability limits for activity analysis are based on technical feasibility and on the potential significance in the environment of the quantities released. For some nuclides, lower detection limits may be readily achievable, and when nuclides are measured below the stated limits, they should also be reported.

^b For certain mixtures of gamma emitters, it may not be possible to measure radionuclides at levels near their sensitivity limits when other nuclides are present in the sample at much higher levels. Under these circumstances, it will be more appropriate to calculate the levels of such radionuclides using observed ratios with those radionuclides which are measurable.

^eAnalyses shall also be performed following each refueling, startup, or similar operational occurrence which could alter the mixture of radionuclides.

To be representative of the average quantities and concentrations of radioactive materials in particulate form released in geneous effluents, samples should be collected in proportion to the rate of flow of the effluent stream.

C Not applicable to Pressure-Vacuum Relief operations

SALEM UNIT 2

2.3-21

Amendment. No. 13

TABLE 2.3-4

SALEN STATION GASEOUS WASTE SYSTEM

LOCATION OF PROCESS AND EFFLUENT MONITORS AND SAMPLERS REQUIRED BY TECHNICAL SPECIFICATIONS

Process Stream or Release Point	Radiation Alarm :	Auto Control 18 Isolation Valve	Continuous Monitor	Greb Sample Station	Me sturement				
					Noble Gas	1	Particulate	H·J	Alpha
Waste Gas Decay Tanks				X	x	x	x	x	x
Condenser Air Removal System	x		×	X	×	x	x	x	x
Plant Vent	×	X	x .	x .	×	x	×	x	x
Containment Purge/Pressure - Vacuum Melief	, <u>,</u>			×	x	x	x	x	x
Building Ventilation Systems									
Auxillary Building and Radvaste Area ⁸				, Xc	x	x	×	x	x
Fuel Handling & Storage Building [®]	·			Xc	x	x	x	x	x
					r				
Furbine Gland Seal Condenser ⁸				ıc	×	x	x	x	X

Since these process streams or building ventilation systems are routed to the plant vent, the need for a continuous menitor at the individual discharge point to the main anhaust duct is eliminated. One continuous menitor at the final release point is sufficient.

Automatically isolates Waste Gas Discharge Line on HIGH RADIATION signal from Gaseous Monitor, R41C. This monitor (R41C) along with R41A and R41B Will initiate isolation of Containment Purge/Pressure-Vacuum Relief System on HIGH RADIATION also.

Grab sample stations from which monthly gas samples (Table 2.3-2) are to be taken. Also, grab samples should be taken and measured to determine the "process stress or building ventilation system source whenever an unexplained increase is indicated by the plant vent sempler-monitors.

2.3-23



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 48 TO FACILITY OPERATING LICENSE NO. DPR-70

AND AMENDMENT NO. 13 TO FACILITY OPERATING LICENSE NO. DPR-75

PUBLIC SERVICE ELECTRIC AND GAS COMPANY, PHILADELPHIA ELECTRIC COMPANY, DELMARVA POWER AND LIGHT COMPANY, AND ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATION STATION, UNIT NOS. 1 AND 2

DOCKET NOS. 50-272 AND 50-311

Introduction

3210270360 82101

2DR

PDR

In a letter dated August 10, 1981, Public Service Electric and Gas Company (the licensee) submitted a request to modify Table 2.3-4 of Salem, Unit Nos. 1 and 2, Environmental Technical Specifications. This table indicates the location of process and effluent monitors and samplers required by technical specifications.

In a subsequent letter dated June 22, 1982, the licensee revised its proposed revision to Table 2.3-4 and, in addition, proposed modifications to Tables 3.3-3 and 3.3-6 of the Safety Technical Specifications and Table 2.3-2 of the Environmental Technical Specifications. Table 3.3-3 presents the engineered safety feature actuation system instrumentation. Table 3.3-6 presents the radiation monitoring instrumentation. Table 2.3-2 contains the various gaseous waste sampling and analysis requirements for all effluent release points and processes such as waste gas decay tank releases and containment purges. The changes to these tables are proposed to reflect the as-built monitoring system of Salem, Unit No. 2, and the modifications which are proposed for Unit No. 1.

The licensee requested that Table 2.3-4 be amended to reflect the as-built process and effluent monitoring system of Unit No. 2 and for approval of the modification to the Unit No. 1 process and effluent monitoring system which will make it identical to the Unit No. 2 system. The present table reflects the Unit No. 1 as-built condition but does not reflect Unit No. 2 as-built condition for the plant vent, reactor containment building, and waste gas discharge line.

- 2 -

Presently the waste gas discharge line of Unit No. 1 is monitored by gaseous monitor 1-R14 while Unit No. 2 does not have such a monitor. A high radiation signal from this monitor will automatically close the gas release valve in the Waste Disposal System of Unit No. 1. For Unit No. 2, the same function is performed by the gaseous monitor 2-R41C which is at the plant vent. Unit No. 2 does not have a separate monitor in the gas discharge line.

Flow from the containment purge of Unit No. 1 is monitored at the plant vent by air particulate, noble gas and radioiodine monitors 1-R11A, 1-R12A, and 1-R12B, respectively. These monitors also have the capability of sampling the containment atmosphere. A high radiation signal from any one of these monitors will initiate closure of the vacuum-relief line and/or the containment purge. For Unit No. 2, this monitoring function is served by plant vent monitors 2-R41A, 2-R41B, and 2-R41C. Radiation monitors 2-R11A, 2-R12A, and 2-R12B monitor exclusively the containment atmosphere at Unit No. 2.

The licensee requested that Table 3.3-3 and 3.3-6 of the Unit No. 1 Safety Technical Specifications be modified to reflect the proposed monitoring design changes. These changes would result in existing monitors 1-R11A, 1-R12A, and 1-R12B being utilized to monitor the containment atmosphere exclusively while new monitors 1-R41A, 1-R41B and 1-R41C would be utilized to monitor plant vent releases. These new monitors would also function as containment purge isolation monitors when the purge/vacuum relief isolation valves were open. However, while in this mode of operation, the licensee proposed that the monitors setpoints would be lowered. The present footnote in Tables 3.3-3 and 3.3-6 indicates that monitors 1-R11A, 1-R12A and 1-R12B can be utilized to monitor the plant vent effluent rather than monitoring containment atmosphere for up to 8 hours per 24 hour interval while either purging the containment atmosphere or venting a gas decay tank. With the proposed monitoring changes at Unit No. 1 this footnote would no longer be applicable.

For Unit No. 2, Tables 3.3-3 and 3.3-6 were proposed to be modified to clarify the footnote that the set points for the unit vent monitors (2-R41 series) would be lowered when functioning in the containment atmosphere isolation mode during purge or vacuum relief operations with these valves open.

The licensee also proposed that Table 2.3-2 of the Environmental Technical Specifications be clarified so that sampling and analysis of the containment would not be required for pressure-vacuum relief operations.

Evaluation and Findings

The staff has conducted an independent review and analysis of the potential radiological impact associated with the amending of Tables 2.3-2 and 2.3-4 of the Environmental Technical Specifications and Tables 3.3-3 and 3.3-6 of the Safety Technical Specifications.

A. Radioactive Release Considerations

The amending of Table 2.3-4 to reflect the as-built process and effluent monitoring system of Unit No. 2 will result in no additional releases of airborne effluents from Unit No. 2 since the change would only acknowledge the present system at Unit No. 2. The proposed modification to Unit No. 1 to make it identical to Unit No. 2, does present the possibility that additional airborne effluents could occur as a result of the new process and effluent monitoring system. The proposed modification to the Unit No. 1 system would eliminate monitor 1-R14. This monitor, which monitors the discharge from the gas decay tanks, presently causes the gas release valve to close automatically on a high radiation signal. In the proposed modification to Unit No. 1, a monitor 1-R41C. located at the plant vent, would close the gas release valve on a high radiation signal. The additional releases associated with the proposed modifications would occur because the monitor 1-R14 can close the valve sooner than the monitor at the plant vent. If the monitor, 1-R14, exceeded its setpoint, then the plant vent monitor 1-R41C would relay the high radiation signal to the control room less than I second later than if the 1-R14 monitor was still in the gas discharge line. At a maximum flow rate of 150 cfm this would result in an additional 2.5 ft³ of discharge would be an extremely small fraction of the annual anticipated release. The doses associated with such activity would be a small fraction of the annual beta and gamma air doses resulting from normal operation. Thus, the impact of this monitoring change will be minimal and is therefore acceptable.

With the acceptance of the proposed monitoring change to Unit No. 1, the changes to the footnotes in Tables 3.3-3 and 3.3-6 are also acceptable as these changes would then reflect the actual monitoring conditions. The change to the footnote to Tables 3.3-3 and 3.3-6 is acceptable because this change recognizes the lowering of the setpoint when the containment atmosphere is monitored during purge/pressure vacuum relief operations and does not impact either plant releases or the health and safety of the public.

The change to Table 2.3-2 distinguishes between sampling and analysis requirements for containment purges and pressure-vacuum relief operations. There is no need to sample and analyze the containment prior to pressure-vacuum relief operations as the discharge will be short term in nature. Therefore, the change to Table 2.3-2 is acceptable. The change to Table 2.3-4 to reflect the as-built condition of Unit No. 2 is also acceptable as it involves no increase in effluents nor a decrease in the safety margin for the plant as it presently exists.

Based upon the above evaluation, we conclude that the health and safety of the public will not be endangered by (1) amending Tables 2.3-2 and 2.3-4 of the Environmental Technical Specifications, (2) modifying Unit No. 1 process and effluent monitoring system, and (3) changing Tables 3.3-3 and 3.3-6 to reflect the changes to Unit No. 1 process and

- 3 -

effluent monitoring system and the as-built monitoring system for Unit No. 2. In addition, the amending of these tables and the modification to the Unit No. 1 process and effluent monitoring system will not increase the probability or consequences of accidents and does not involve a decrease in safety margin nor involve a significant hazards consideration.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: October 18, 1982

SER prepared by J. Hayes (ETSB) W. Ross (ORB #1)

ENVIRONMENTAL IMPACT APPRAISAL BY THE OFFICE OF NUCLEAR REACTOR REGULATION REGARDING AMENDING TABLES 2.3-2 AND 2.3-4 OF THE ENVIRONMENTAL TECHNICAL SPECIFICATIONS AND TABLES 3.3-3 AND 3.3-6 OF THE SAFETY TECHNICAL SPECIFICATIONS

and the second second and the second seco

Salem Nuclear Generating Station, Unit Nos. 1 and 2 Public Service Electric and Gas Company Docket Nos. 50-272 and 50-311

Introduction

Public Service Electric and Gas Company is presently licensed to operate the Salem Nuclear Generating Station located on Artificial Island on the Delaware River in Lower Alloways Township, Salem County, New Jersey. There are two pressurized water reactors at the site, each reactor capable of generating 3250 MWt of power. The proposed amending of Tables 2.3-2 and 2.3-4 of the Station's Environmental Technical Specifications, Tables 3.3-3 and 3.3-6 of the Station's Safety Technical Specifications, and the modifications to the Unit No. 1 process and effluent monitoring system will not affect the reactor power level nor the fuel burnup and, therefore, not affect the benefits of the electrical power production considered in the Commission's Final Environmental Statement, Docket Nos. 50-272 and 50-311.

A. Radiological Impact

As evaluated in the associated Safety Evaluation, the proposed request does not affect the conclusions of the initial SER which were that the process and effluent monitoring system assures that releases during normal operation meet the limits of Table 2, Column 1 of Appendix B of 10 CFR Part 20. In addition, the amending of these tables and the Unit 1 process and effluent monitoring system does not negate the fact that releases will be acceptable during normal operation and low probability accidents and within the "as low as reasonably achievable" requirements of 10 CFR Part 50, Appendix I.

The change in monitoring location of waste gas discharges would result in no more than one second of additional flow from the waste gas decay tank. The activity released would be a very small fraction of the annual effluents from the plant and the associated doses would be a likewise small fraction of the annual beta and gamma air doses anticipated from the units.

B. Conclusion

On the basis of the foregoing evaluation, it is concluded that there would be no significant environmental impact attributable to the amending of Tables 2.3-2 and 2.3-4 of the Environmental Technical Specifications, Table 3.3-3 and 3.3-6 of the Safety Technical Specifications, and the proposed modification to the Unit No. 1 process and effluent monitoring system. As a result of this conclusion, the Commission has further concluded that no environmental impact statement for the proposed action need be prepared and that a negative declaration to this effect is appropriate.

EIA prepared by J. Hayes (ETSB) W. Ross (ORB #1) - 2 -

∽590-01

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NOS. 50-272 AND 50-311

PUBLIC SERVICE ELECTRIC AND GAS COMPANY, PHILADELPHIA ELECTRIC COMPANY, DELMARVA POWER AND LIGHT COMPANY, AND ATLANTIC CITY ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSES AND NEGATIVE DECLARATION

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 48 to Facility Operating License No. DPR-70 and Amendment No. 13 to Facility Operating License No. 75, issued to Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees), which revised Technical Specifications for operation of the Salem Nuclear Generating Station, Unit Nos. 1 and 2 (the facilities) located in Salem County, New Jersey. The amendments are effective as of the date of issuance.

The amendments revise the Radiological Safety and Environmental Technical Specifications related to process and effluent monitors to agree with existing plant conditions.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

8210270366 8210

*,*90-01

The Commission has prepared an environmental impact appraisal for the revised Technical Specifications and has concluded that an environmental impact statement for this particular action is not warranted because there will be no environmental impact attributable to the action other than that which has already been predicted and described in the Commission's Final Environmental Statement for the facility dated April 1973.

For further details with respect to this action, see (1) the application for amendments dated August 10, 1981, as modified by letter dated June 22, 1982, (2) Amendment Nos. 48 and 13 to License Nos. DPR-70 and DPR-75, (3) the Commission's related Safety Evaluation and (4) the Commission's Environmental Impact Appraisal. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, D. C. and at the Salem Free Public Library, 112 West Broadway, Salem, New Jersey. A copy of items (2), (3) and (4) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 18th day of October, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

Operating Reactors Branch #1

Division of Licensing