			Distribution	on	
\smile	October 15, 1984	\smile	NRC PDR	5	
			Local PDR		
			ORB#1 Rdg.		
Dockat Nos 50-272			Gray File	4	
and $50-272$			DEisenhut		
and 50-511			CParrish		
			DFischer		
Mr Richard A Uderitz Vice P	resident -		OELD		
Nuclear	es ruente ····		LHarmon		
Public Service Electric and Gas	: Company		EJordan		
Post Office Box 236	, oompany		JNGrace		
Hancocks Bridge, New Jersev 08	1038		TBarnhart ((8)	
nanebers bi rages new berbey be			WJones		JPartlow
Dear Mr. Uderitz:			DBrinkman		RDiggs
			ACRS (10)		CMiles

The Commission has issued the enclosed Amendment No. 57 to Facility Operating License No. DPR-70 and Amendment No. 26 to Facility Operating License No. DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated October 5, 1982 and supplemented September 2, 1983.

These amendments would add a clarifying note to existing Technical Specifications which delineates operating restrictions when one Main Steam Isolation Valve solenoid vent valve is isolated. Other portions of this amendment request are being completed by separate amendments.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular monthly Federal Register notice.

Sincerely,

/s/DFischer

Donald Fischer, Project Manager Operating Reactors Branch #1 Division of Licensing

Enclosures:

- 1. Amendment No. 57 to DPR-70 2. Amendment No. 26 to DPR-75
- 3. Safety Evaluation

cc: w/enclosures See next page





October 15, 1984

Docket Nos. 50-272 and 50-311

Mr. Richard A. Uderitz, Vice President -Nuclear Public Service Electric and Gas Company Post Office Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. Uderitz:

The Commission has issued the enclosed Amendment No. 57 to Facility Operating License No. DPR-70 and Amendment No. 26 to Facility Operating License No. DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated October 5, 1982 and supplemented September 2, 1983.

These amendments would add a clarifying note to existing Technical Specifications which delineates operating restrictions when one Main Steam Isolation Valve solenoid vent valve is isolated. Other portions of this amendment request are being completed by separate amendments.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular monthly Federal Register notice.

Sincerely,

Donald Fischer, Project Manager Operating Reactors Branch #1 Division of Licensing

Enclosures:

- 1. Amendment No. 57 to DPR-70 Amendment No. 26 to DPR-75
- 2.
- Safety Evaluation 3.

cc: w/enclosures See next page

Mr. R. A. Uderitz Public Service Electric & Gas Company

cc: Mark J. Wetterhahn, Esquire Conner and Wetterhahn Suite 1050 1747 Pennsylvania Avenue, NW Washington, DC 20006

> Richard Fryling, Jr., Esquire Assistant General Solicitor Public Service Electric & Gas Company P. O. Box 570 - Mail Code T5E Newark, New Jersey 07101

Gene Fisher, Bureau of Chief Bureau of Radiation Protection 380 Scotch Road Trenton, New Jersey 08628

Mr. John M. Zupko, Jr. General Manager - Salem Operations Public Service Electric & Gas Company Post Office Box E Hancock Bridge, New Jersey 08038

Mr. Dale Bridenbaugh M.H.B. Technical Associates 1723 Hamilton Avenue San Jose, California 95125

James Linville, Resident Inspector Salem Nuclear Generating Station U.S. Nuclear Regulatory Commission Drawer I Hancock Bridge, New Jersey 08038

Richard F. Engel Deputy Attorney General Department of Law and Public Safety CN-112 State House Annex Trenton, New Jersey 08625

Richard B. McGlynn, Commission Department of Public Utilities State of New Jersey 101 Commerce Street Newark, New Jersey 07102 Salem Nuclear Generating Station Units 1 and 2

> Regional Radiation Representative EPA Region II 26 Federal Plaza New York, New York 10007

> Mr. R. L. Mittl, General Manager Nuclear Assurance and Regulation Public Service Electric & Gas Co. Mail Code T16D - P. O. Box 570 Newark, New Jersey 07101

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancock Bridge, NJ 08038

Mr. Alfred C. Coleman, Jr. Mrs. Eleanor G. Coleman 35 K Drive Pennsville, New Jersey 08070

Carl Valore, Jr., Esquire Valore, McAllister, Aron and Westmoreland, P.A. 535 Tilton Road Northfield, NJ 08225

June D. MacArtor, Esquire Deputy Attorney General Tatnall Building Post Office Box 1401 Dover, Delaware 19901

Harry M. Coleman, Mayor Lower Alloways Creek Township Municipal Hall Hancock Bridge, New Jersey 08038

Salem Nuclear Generating Station Units 1 and 2

- 2 -

cc: Mr. Edwin A. Liden, Manager Nuclear Licensing & Regulation Public Service Electric & Gas Company Post Office Box 236 Hancock Bridge, New Jersey 08038

> Mr. Charles P. Johnson Assistant to Vice President, Nuclear Public Service Electric & Gas Company Post Office Box 570 80 Park Plaza - 15A Newark, New Jersey 07101

Mr. David Wersan Assistant Consumer Advocate Office of Consumer Advocate 1425 Strawberry Square Harrisburg, PA 17120

•



PUBLIC SERVICE ELECTRIC AND GAS COMPANY PHILADELPHIA ELECTRIC COMPANY DELMARVA POWER AND LIGHT COMPANY ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 57 License No. DPR-70

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated October 5, 1982 and supplemented September 2, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:

8411090010 841015 PDR ADUCK 05000272

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 57, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Steven A. Varga, Chief Operating Reactors Branch #1 Division of Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: October 15, 1984

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 57 FACILITY OPERATING LICENSE NO. DPR-70 DOCKET NO. 50-272

Revise Appendix A as follows:

Remove Pages	Insert Pages
3/4 3-18	3/4 3-18
3/4 3-19	3/4 3-19
3/4 3-20	3/4 3-20

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT		TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION	
b.	Pha	se "B" Isolation					
	1)	Manual	2 sets of 2	1 set of 2	2 sets of 2	1, 2, 3, 4	18
	2)	Automatic Actuation Logic	2	1 .	2	1, 2, 3, 4	13
	3)	Containment PressureHigh-High	4	2	3	1, 2, 3	16
с.	Pur Isc	ge and Exhaust lation					
	1)	Manual	2	1	2	1, 2, 3, 4	17
	2)	Containment Atmo- sphere Radioactivity- High	3	1	2**	1, 2, 3, 4	- 17

** The unit vent sampling monitor may also function in this capacity with lowered setpoints when the purge/pressurevacuum relief isolation valves are open.

.

3/4 3-18

Amendment No. 57

		EN	GINEERED SAFETY FEATURE	E ACTUATION SYSTEM INS	STRUMENTATION		
FUN	CTIO	NAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
4.	STE	AM LINE ISOLATION					
.,.	а.	Manual	l/steam line	l/steam line	l/operating	1, 2, 3	18
	Ъ.	Automatic Actuation Logic	2***	1	2	1, 2, 3	13
	c.	Containment Pressur High-High	e 4	2	3	1, 2, 3	16
	d.	Steam Flow in Two Steam LinesHigh					
		Four Loops Operating	2/steam line	l/steam line any 2 steam lines	l/steam line		14*
		Three Loops	2/operating steam line	l###/any operating steam line	l/operating steam line		15
	CO	INCIDENT WITH EITHER T _{avg} Low-Low				1, 2, 3##	
		Four Loops Operating	l T _{avg} /loop	l T _{avg} in any 2 loops	l T _{avg} in any 3 loops		14*

*** The automatic actuation logic includes two redundant solenoid operated vent valves for each Main Steam Isolation Valve. One vent valve on any one Main Steam Isolation Valve may be isolated without affecting the function of the automatic actuation logic provided the remaining seven solenoid vent valves remain operable. The isolated MSIV vent valve shall be returned to OPERABLE status upon the first entry into MODE 5 following determination that the vent valve is inoperable. For any condition where more than one of the eight solenoid vent valves are inoperable, entry into ACTION 13 is required.

щ

3/4 3-19

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

	FUNCTIONAL UNIT		TOTAL NO. UNCTIONAL UNIT OF CHANNELS		MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION	
		Three Loops	l T _{avg} /operating loop	l### T _{avg} in any operating loop	l T _{avg} in any two operating loops		15	
		OR, COINCIDENT WITH		- -				
		Steam Line Pressure- Low				l, 2, 3###	(
		Four Loops Operating	l pressure/ loop	l pressure • any 2 loops	l pressure any 3 loops		14*	
		Three Loops Operating	l pressure/ operating loop	l### pressure in any operating loop	l pressure in any 2 operating loops	5	15	
	5.	TURBINE TRIP & FEEDWATER ISOLATION			·			
		a. Steam Generator Water level High-High	3/100р	2/loop in any operating loop	2/loop in each operating loop	1, 2, 3	14*	
	6.	SAFEGUARDS EQUIPMENT CONTROL SYSTEM (SEC)	3	2	3	1, 2, 3, 4	. 13 (
	7.	UNDERVOLTAGE, VITAL BUS						
-		a. Loss of Voltage	3	2	3	1, 2, 3	14*	
) F 22		b. Sustained Degraded Voltage	3	2	3	1, 2, 3	14*	
,								

3/43-20

Amendment No.



PUBLIC SERVICE ELECTRIC AND GAS COMPANY PHILADELPHIA ELECTRIC COMPANY DELMARVA POWER AND LIGHT COMPANY ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. ²⁶ License No. DPR-75

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated October 5, 1982 and supplemented September 2, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 26, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Yarga, ChileA ven

Operating Reactors Branch #1 Division of Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: October 15, 1984

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 26

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages	Insert Pages
3/4 3-18	3/4 3-18
3/4 3-19	3/4 3-19
3/4 3-20	3/4 3-20

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIO	NAL (UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
b.	Pha	se "B" Isolation					
	1)	Manual	2 sets of 2	1 set of 2	2 sets of 2	1, 2, 3, 4	18
	2)	Automatic Actuation Logic	2	1 .	2	1, 2, 3, 4	13
	3)	Containment PressureHigh-High	4	2	3	1, 2, 3	16
с.	Cor Isc	ntainment Ventilation Diation					
	1)	Manual	2	1	2	1, 2, 3, 4	17
	2)	Automatic Actuation Logic	2	1	2	1, 2, 3, 4	- 13
	3)	Containment Atmo- sphere Gaseous Radioactivity-High	1**	1	1	1, 2, 3, 4	17
				•			

** The unit vent sampling monitor may also function in this capacity with lowered setpoints when the purge/pressurevacuum relief isolation valves are open.

i

SALEM - UNIT

Ν

3/4

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

	FUN	CTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
		Three Loops	l T _{avg} /operating loop	l### T _{avg} in any operating loop	l T _{avg} in any two operating loops		15
		OR, COINCIDENT WITH					
		Steam Line Pressure- Low				1, 2, 3##	
		Four Loops	l pressure/ . loop	l pressure in any 2 loops	l pressure in any 3 loops		14*
		Three Loops Operating	l pressure/ operating loop	l### pressure in any operating loop	l pressure in any 2 operating loops	5	15
	5.	TURBINE TRIP & FEEDWATER ISOLATION	,				
		a. Steam Generator Water level High-High	3/100p	2/loop in any operating loop	2/loop in each operating loop	1, 2, 3	14*
	6.	SAFEGUARDS EQUIPMENT CONTROL SYSTEM (SEC)	3	2	3	1, 2, 3, 4	13
Amond	7.	UNDERVOLTAGE, VITAL BUS					
		a. Loss of Voltage	3	2	3	1, 2, 3	14*
Z		b. Sustained Degraded Voltage	3	2	3	1, 2, 3	14*
						•	

SALEM -UNIT N

3/4 3-19

Allenditen ē No.

i.

26

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT		NAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
4.	STE	AM LINE ISOLATION					
	a.	Manual	2/steam line	l/steam line	l/operating steam line	1, 2, 3	21
	b.	Automatic Actuation Logic	2***	1	2	1, 2, 3	20
	с.	Containment Pressure High-High	4	2	3	1, 2, 3	16
	d.	Steam Flow in Two Steam LinesHigh	· • • •	i			
		Four Loops Operating	2/steam line	l/steam line any 2 steam lines	l/steam line		14*
	CO]	INCIDENT WITH EITHER T _{avg} Low-Low				1, 2, 3##	
		Four Loops Operating	l T _{avg} /loop	l T _{avg} in any 2 loops	l T _{avg} in any 3 loops		14*

*** The automatic actuation logic includes two redundant solenoid operated vent valves for each Main Steam Isolation Valve. One vent valve on any one Main Steam Isolation Valve may be isolated without affecting the function of the automatic actuation logic provided the remaining seven solenoid vent valves remain operable. The isolated MSIV vent valve shall be returned to OPERABLE status upon the first entry into MODE 5 following determination that the vent valve is inoperable. For any condition where more than one of the eight solenoid vent valves are inoperable, entry into ACTION 20 is required.

1

3/4 3-20



SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION RELATED TO AMENDMENT NO. 57 TO FACILITY OPERATING LICENSE NO. DPR-70

AND AMENDMENT NO. 26 TO FACILITY OPERATING LICENSE NO. DPR-75

PUBLIC SERVICE ELECTRIC AND GAS COMPANY PHILADELPHIA ELECTRIC COMPANY DELMARVA POWER AND LIGHT COMPANY, AND ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATION STATION, UNIT NOS. 1 AND 2

DOCKET NOS. 50-272 AND 50-311

INTRODUCTION

By letter dated October 5, 1982 the licensee requested that the Technical Specifications for Salem Units 1 and 2 be changed to include the following note to Technical Specification Table 3.3.3:

"The automatic actuation logic includes the redundant solenoid operated vent valves for each Main Steam Isolation Valve. One vent valve on any one Main Steam Isolation Valve may be isolated without affecting the function of the automatic actuation logic provided the remaining seven solenoid vent valves remain operable. For this condition entry into the Action Statement (No. 13 on Unit 1, No. 20 on Unit 2) is not required."

The staff, during their review, noted that indefinite operation with an inoperable solenoid vent valve should not be permitted. In a letter dated September 2, 1983, the licensee responded to this concern by removing the last sentence of the note and replacing it with two corrective action statements. The note would then read:

"The automatic actuation logic includes two redundant solenoid operated vent valves for each Main Steam Isolation Valve. One vent valve on any one Main Steam Isolation Valve may be isolated without affecting the function of the automatic actuation logic provided the remaining seven solenoid vent valves remain operable. The isolated MSIV vent valve shall be returned to OPERABLE status upon the first entry into MODE 5 following determination that the vent valve is inoperable. For any condition where more than one of the eight solenoid vent valves are inoperable, entry into ACTION Statement (No. 13 on Unit 1, No. 20 on Unit 2) is required."

EVALUATION AND SUMMARY

The NRC staff reviewed the proposed change and concludes that operation with one solenoid valve out of service will not increase the severity of any design basis event beyond the consequences discussed in the FSAR. Each

8411090047 841015 ĀDOCK 05000272 PDR

main steam line isolation valve is equipped with two solenoid operated vent valves, either of which is capable of producing MSIV closure. The evlauation of design basis events in the FSAR assumes complete failure of one MSIV. The single failure of an additional solenoid operated vent valve would therefore produce consequences within the scope of the FSAR analyses. With the inclusion of the two corrective action statements in the Technical Specification note, we conclude that the licensee's proposal is acceptable.

Environmental Consideration

These amendments involve a change in the installation or use of the facilities components located within the restricted areas as defined in 10 CFR 20. The staff has determined that these amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meets the eligibility criteria for categorical exclusion set forth in 10 CFR Sec 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: October 15, 1984

Principal Contributor:

W. Jensen