

February 6, 1986

Docket No. 50-272

DISTRIBUTION

Docket File

Mr. C. A. McNeill, Jr.
Vice President - Nuclear
Public Service Electric and Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

LPDR
PAD-3 Rdg
OELD
D. Fischer
E. Jordan
J. Partlow
W. Jones
ACRS 10
LFMB

NRC PDR
Gray File 4
H. Thompson
C. Vogan
L. Harmon
B. Grimes
T. Barnhart 4
V. Benaroya
OPA
W. Jensen

Dear Mr. McNeill:

The Commission has issued the enclosed Amendment No. 71 to Facility Operating License No. DPR-70 for the Salem Nuclear Generating Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your request dated August 6, 1985.

The amendment permits Unit No. 1 to operate at the 2% higher power level of 3411 Mwt permitted for Unit No. 2.

A copy of the Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,
/s/DFischer

Donald C. Fischer, Senior Project Manager
PWR Project Directorate #3
Division of PWR Licensing-A

Enclosures:

- 1. Amendment No. 71 to DPR-70
- 2. Safety Evaluation

cc: w/enclosures
See next page

PAD-3
CVogan
01/15/86

PAD-3
DFischer;ps
01/24/86

OELD
M. Kanman
01/27/86

D/PAD-3
SVarga
01/17/86

2/6/86

Please Contact
FED. REG.
Page #

Mr. C. A. McNeill
Public Service Electric & Gas Company Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire
Conner and Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, NW
Washington, DC 20006

Richard B. McGlynn, Commission
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, New Jersey 07102

Richard Fryling, Jr., Esquire
Assistant General Solicitor
Public Service Electric & Gas Company
P. O. Box 570 - Mail Code T5E
Newark, New Jersey 07101

Mr. R. L. Mittl, General Manager
Nuclear Assurance and Regulation
Public Service Electric & Gas Co.
Mail Code T16D - P. O. Box 570
Newark, New Jersey 07101

Gene Fisher, Bureau of Chief
Bureau of Radiation Protection
380 Scotch Road
Trenton, New Jersey 08628

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. John M. Zupko, Jr.
General Manager - Salem Operations
Public Service Electric & Gas Company
Post Office Box E
Hancocks Bridge, New Jersey 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, New Jersey 08038

Robert Traae, Mayor
Lower Alloways Creek Township
Municipal Hall
Hancocks Bridge, New Jersey 08038

Mr. Edwin A. Liden, Manager
Nuclear Licensing & Regulation
Public Service Electric & Gas Company
Hancocks Bridge, New Jersey 08038

Thomas Kenny, Resident Inspector
Salem Nuclear Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, New Jersey 08038

Mr. Charles P. Johnson
General Manager
Nuclear Quality Assurance
Public Service Electric & Gas Company
Hancocks Bridge, New Jersey 08038

Richard F. Engel
Deputy Attorney General
Department of Law and Public Safety
CN-112
State House Annex
Trenton, New Jersey 08625

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, Pennsylvania 17120

Mr. Anthony J. Pietrofitta
General Manager
Power Production Engineering
Atlantic Electric
1199 Black Horse Pike
Pleasantville, New Jersey 08232

Frank Casolito, Action Chief
Bureau of Radiation Protection
Department of Environmental Protection
380 Scotch Road
Trenton, New Jersey 08628



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PHILADELPHIA ELECTRIC COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 71
License No. DPR-70

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated August 6, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:


8602260595 860206
PDR ADOCK 05000272
PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 71, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Director
PWR Project Directorate #3
Division of PWR Licensing-A

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 6, 1986

ATTACHMENT TO LICENSE AMENDMENT NO.71

FACILITY OPERATING LICENSE NO. DPR-70

DOCKET NO. 50-272

Revise Appendix A as follows:

Remove Pages

1-5

2-5

3/4 2-14

Insert Pages

1-5

2-5

3/4 2-14

DEFINITIONS

PHYSICS TESTS

1.20 PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation and 1) described in Chapter 14 of the Updated FSAR, 2) authorized under the provisions of 10CFR50.59, or 3) otherwise by the Commission.

PRESSURE BOUNDARY LEAKAGE

1.21 PRESSURE BOUNDARY LEAKAGE shall be leakage (except steam generator tube leakage) through a non-isolable fault in a Reactor Coolant System component body, pipe wall or vessel wall.

PROCESS CONTROL PROGRAM (PCP)

1.22 The PROCESS CONTROL PROGRAM shall be that program which contains the current formula, sampling, analyses, test, and determinations to be made to ensure that the processing and packaging of solid radioactive wastes, based on demonstrated processing of actual or simulated wet solid wastes, will be accomplished in such a way as to assure compliance with 10 CFR Part 20, 10 CFR Part 71 and Federal and State regulations and other requirements governing the disposal of the radioactive waste.

PURGE - PURGING

1.23 PURGE or PURGING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration, or other operating condition, in such a manner that replacement air or gas is required to purify the confinement.

QUADRANT POWER TILT RATIO

1.24 QUADRANT POWER TILT RATIO shall be the ratio of the maximum upper excore detector calibrated output to the average of the upper excore detector calibrated outputs, or the ratio of the maximum lower excore detector calibrated output to the average of the lower excore detector calibrated outputs, whichever is greater. With one excore detector inoperable, the remaining three detectors shall be used for computing the average.

RATED THERMAL POWER

1.25 RATED THERMAL POWER shall be a total reactor core heat transfer rate to the reactor coolant of 3411Mwt.

TABLE 2.2-1

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. Manual Reactor Trip	Not Applicable	Not Applicable
2. Power Range, Neutron Flux	Low Setpoint - $\leq 25\%$ of RATED THERMAL POWER High Setpoint - $\leq 109\%$ of RATED THERMAL POWER	Low Setpoint - $\leq 26\%$ of RATED THERMAL POWER High Setpoint - $\leq 110\%$ of RATED THERMAL POWER
3. Power Range, Neutron Flux, High Positive Rate	$\leq 5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds	$\leq 5.5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds
4. Power Range, Neutron Flux, High Negative Rate	$\leq 5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds	$\leq 5.5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds
5. Intermediate Range, Neutron Flux	$\leq 25\%$ of RATED THERMAL POWER	$\leq 30\%$ of RATED THERMAL POWER
6. Source Range, Neutron Flux	$\leq 10^5$ counts per second	$\leq 1.3 \times 10^5$ counts per second
7. Overtemperature ΔT	See Note 1	See Note 3
8. Overpower ΔT	See Note 2	See Note 3
9. Pressurizer Pressure--Low	≥ 1865 psig	≥ 1855 psig
10. Pressurizer Pressure--High	≤ 2385 psig	≤ 2395 psig
11. Pressurizer Water Level--High	$\leq 92\%$ of instrument span	$\leq 93\%$ of instrument span
12. Loss of Flow	$\geq 90\%$ of design flow per loop*	$\geq 89\%$ of design flow per loop*

*Design flow is 87,300 gpm per loop.

TABLE 3.2-1DNB PARAMETERS

<u>PARAMETER</u>	<u>LIMITS</u>	
	<u>4 Loops In Operation</u>	<u>3 Loops in Operation</u>
Reactor Coolant System T_{avg}	$\leq 582^{\circ}\text{F}$	$\leq 572^{\circ}\text{F}$
Pressurizer Pressure	$\geq 2220 \text{ psia}^*$	$\geq 2220 \text{ psia}^*$
Reactor Coolant System	$\geq 349,200 \text{ gpm}$	$\geq 278,100 \text{ gpm}$

*Limit not applicable during either a THERMAL POWER ramp increase in excess of 5% RATED THERMAL POWER per minute or a THERMAL POWER step increase in excess of 10% RATED THERMAL POWER.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 71 TO FACILITY OPERATING LICENSE NO. DPR-70

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PHILADELPHIA ELECTRIC COMPANY
DELMARVA POWER AND LIGHT COMPANY, AND
ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATION STATION, UNIT NO. 1

DOCKET NO. 50-272

INTRODUCTION

In a letter dated August 6, 1985, the licensee requested that the Technical Specifications for Salem Unit 1 be changed to permit power operation at the 2% higher power level of 3411 Mwt permitted for Unit 2. The current power limitation for Unit 1 results from the reduced capacity of the main turbine coupling that was originally installed on the plant. The coupling has now been modified to allow Unit No. 1 to operate at higher power levels.

EVALUATION AND SUMMARY

Salem Unit Nos. 1 and 2 are essentially identical. They share a common FSAR. The analyses of all design basis transients and accidents as well as the steady state thermal hydraulic analyses in the FSAR were all performed at the higher power level of Unit 2.

Design limitations initially prevented Unit 1 from being operated at the higher power level of Unit 2. The principal consideration was the lower capacity of the Unit 1 main turbine coupling. Another factor was the lower drainage capacity from the moisture separators within the steam generators of Unit 1. Both the coupling and the moisture separators have been upgraded to the Unit 2 capacity. The licensee and Westinghouse, the plant vendor, evaluated all the significant plant components for both units and determined that they were identical or functionally identical. No additional safety analyses were required. The staff concludes that Salem Unit 1 can be safely operated at the maximum core power level of Unit 2 which is 3411 Mwt.

The licensee requested three technical specification changes. These increase rated thermal power, increase T_{avg} for the DNB parameters by 1°F and reduce the reactor trip system loop flow setpoint by 1.4%. The first two changes permit the power upgrade and the flow setpoint change is for consistency with the combined Unit 1 and 2 FSAR. We conclude the changes are acceptable.

8602260602 860206
PDR ADOCK 05000272
P PDR

ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Sec 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: February 6, 1986

PRINCIPAL CONTRIBUTOR:

W. Jensen