

MAR 14 1983

Docket No. 50-272

DISTRIBUTION
 Docket OPA
 NRC PDR RDiggs
 L PDR JHeltemes
 NSIC Gray
 ORB#1 Rdg
 DEisenhut
 ORAB
 CParrish
 WRoss
 OELD - *K. Cyr*
 ELJordan
 JMTaylor
 TBarnhart-4
 ACRS-10

Mr. Richard A. Uderitz
 Vice President - Nuclear
 Public Service Electric and Gas Company
 Post Office Box 236
 Hancocks Bridge, New Jersey 08038

Dear Mr. Uderitz:

The Commission has issued the enclosed Order confirming your commitments to implement those post-TMI related items set forth in NUREG-0737 for which the staff requested completion on or after July 1, 1981. This Order is based on commitments contained in your letters responding to the NRC's Generic Letters 82-05 and 82-10 dated March 17, 1982 and May 5, 1982, respectively.

The Order references your letters and, in its Attachments, contains lists of the applicable NUREG-0737 items with your scheduler commitments. As discussed in the Order, several of the items listed in Generic Letter 82-10 will be handled outside of this Order.

The Commission's intention when it issued NUREG-0737 was that items would be completed in accordance with the staff's recommended schedule. However, our evaluation of your proposed schedule exceptions concludes that the proposed delays are acceptable. Among other things, the Order requires implementation of these items in accordance with your proposed schedule.

Some of the items set forth in the Attachments to the Order are subject to post implementation review and inspection. Our post implementation review and/or the development of Technical Specifications may identify alterations to your method of implementing and maintaining the requirements. Any identified alterations will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,
 Original signed by
 S. A. Varga

Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

8303290157 830314
 PDR ADCK 05000272
 P PDR

Enclosure:
 Order

cc w/enclosure:
 See next page

OFFICE	ORB#1:DL CParrish	ORB#1:DL WRoss:dm	ORB#1:DL S.Varga	ORAB J.M. Taylor	AD/OR:DL GLainas	OELD K. Cyr	DEisenhut
SURNAME	CParrish	WRoss:dm	S.Varga	J.M. Taylor	GLainas	K. Cyr	DEisenhut
DATE	2/16/83	2/11/83	2/17/82	3/14/83	2/17/82	3/14/83	3/14/82

Mr. R. A. Uderitz
Public Service Electric and Gas Company

cc: Mark J. Wetterhahn, Esquire
Conner and Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, NW
Washington, D. C. 20006

Richard Fryling, Jr., Esquire
Assistant General Solicitor
Public Service Electric and Gas Company
80 Park Place
Newark, New Jersey 07101

Gene Fisher, Bureau of Chief
Bureau of Radiation Protection
380 Scotch Road
Trenton, New Jersey 08628

Mr. Henry J. Midura, General Manager -
Salem Operations
Public Service Electric and Gas Company
P. O. Box 168
Hancocks Bridge, New Jersey 08038

Mr. Dale Bridenbaugh
M.H.B. Technical Associates
1723 Hamilton Avenue
San Jose, California 95125

Leif J. Norrholm, Resident Inspector
Salem Nuclear Generating Station
U. S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, New Jersey 08038

Richard F. Engel
Deputy Attorney General
Department of Law and Public Safety
CN-112
State House Annex
Trenton, New Jersey 08625

Richard B. McGlynn, Commissioner
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, New Jersey 07102

Mr. Edwin A. Liden, Manager
Nuclear Licensing and Regulation
Public Service Electric and Gas Co.
Mail Code T16D - P.O. Box 570
Newark, New Jersey 07101

Regional Radiation Representative
EPA Region II
26 Federal Plaza
New York, New York 10007

Mr. R. L. Mittl, General Manager -
Corporate Quality Assurance
Public Service Electric and Gas Company
Mail Code T16D - P.O. Box 570
Newark, New Jersey 07101

Ronald C. Haynes
Regional Administrator - Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, New Jersey 08038

Mr. Alfred C. Coleman, Jr.
Mrs. Eleanor G. Coleman
35 K Drive
Pennsville, New Jersey 08070

Mr. R. A. Uderitz
Public Service Electric and Gas Company

cc: Carl Valore, Jr., Esquire
Valore, McAllister, Aron and
Westmoreland, P.A.
535 Tilton Road
Northfield, New Jersey 08225

June D. MacArtor, Esquire
Deputy Attorney General
Tatnall Building
P. O. Box 1401
Dover, Delaware 19901

Samuel E. Donelson, Mayor
Lower Alloways Creek Township
Municipal Hall
Hancocks Bridge, New Jersey 08038

- 2 -

additional protection in the operation of nuclear facilities based on the experience from the accident at TMI-2 and the official studies and investigations of the accident. The staff's proposed requirements and schedule for implementation are set forth in NUREG-0737, "Clarification of TMI Action Plan Requirements." Among these requirements are a number of items, consisting of hardware modifications, administrative procedure implementation and specific information to be submitted by the licensee, scheduled to be completed on or after July 1, 1981. On March 17, 1982, a letter (Generic Letter 82-05) was sent to all licensees of operating power reactors for those items that were scheduled to be implemented from July 1, 1981 through March 1, 1982. Subsequently, on May 5, 1982, a letter (Generic Letter 82-10) was also sent to all licensees of operating power reactors for those items that were scheduled for implementation after March 1, 1982. These letters are hereby incorporated by reference. In these letters each licensee was requested to furnish within 30 days pursuant to 10 CFR 50.54(f) the following information for items which the staff had proposed for completion on or after July 1, 1981:

- (1) For applicable items that have been completed, confirmation of completion and the date of completion, (2) for items that have not been completed, a specific schedule for implementation, which the licensee committed to meet, and (3) justification for delay, demonstration of need for the proposed schedule, and a description of the interim compensatory measures being taken.

- 3 -

III.

Public Service Electric and Gas Company responded to Generic Letter 82-05 by letters dated April 15 and June 11, 1982; Public Service Electric and Gas Company responded to Generic Letter 82-10 by letter dated July 15, 1982. In these submittals, Public Service Electric and Gas Company confirmed that some of the items identified in the Generic Letters had been completed and made firm commitments to complete the remainder. The attached Tables summarizing the licensee's schedular commitments or status were developed by the staff from the Generic Letters and the licensee-provided information.

There are six items from Generic Letter 82-10 that, as noted in the Table (Attachment 2), have licensee schedules to be determined and are therefore not included in this Order. Some of the items addressed in this Order are considered by the licensee to be completed or to require no modifications.

We find, based on the above evaluation, that: 1) the licensee has taken corrective actions regarding the delays and has made a responsible effort to implement the NUREG-0737 requirements noted; 2) there is good cause for the several delays (unexpected design complexity, interface problems, and equipment delays); and 3) as noted above, interim compensatory measures have been provided.

In view of the foregoing, I have determined that these modifications and actions are required in the interest of public health and safety and, therefore, the licensee's commitment should be confirmed by Order.

- 4 -

IV.

Accordingly, pursuant to Sections 103, 161i, and 161o of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED EFFECTIVE IMMEDIATELY THAT THE LICENSEE SHALL:

Implement and maintain the specific items described in the Attachments to this Order in the manner described in the licensee's submittals noted in Section III herein no later than the dates in the Attachments.


V.

The licensee may request a hearing on this Order within 20 days of the date of publication of this Order in the Federal Register. A request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy shall also be sent to the Executive Legal Director at the same address. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is requested by the licensee, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licensee should comply with the requirements set forth in Section IV of this Order. This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Purple, Deputy Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland,
this 14th day of March, 1983.

Attachments:

1. Licensee's Commitments on Applicable
NUREG-0737 Requirements from Generic
Letter 82-05
2. Licensee's Commitments on Applicable
NUREG-0737 Requirements from Generic
Letter 82-10

PLANT NAME: Salem Nuclear
Generating Unit 1

LICENSEE COMMITMENTS ON APPLICABLE 0737 ITEMS
FROM GENERIC LETTER 82-05

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
I.A.3.1	Simulator Exams	10/1/81	Include simulator exams in licensing examinations.	Complete
II.B.2	Plant Shielding	1/1/82	Modify facility to provide access to vital areas under accident conditions.	Complete
II.B.3	Post-accident sampling	1/1/82	Install upgrade post-accident sampling capability.	Complete
II.B.4	Training for Mitigating Core Damage	10/1/81	Complete training program.	Complete
II.E.1.2	Aux FW Indication & Flow Indicator	7/1/81	Modify instrumentation to level of safety grade.	Complete
II.E.4.2	Containment Isolation Dependability	7/1/81	Part 5 - lower containment pressure setpoint to level compatible with normal operation.	Complete
II.E.4.2	Containment Isolation Dependability	7/1/81	Part 7 - isolate purge and vent valves on radiation signal.	Complete

PLANT NAME: Salem Nuclear
Generating Unit 1

LICENSEE COMMITMENTS ON APPLICABLE 0737 ITEMS
FROM GENERIC LETTER 82-05

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
II.F.1	Accident Monitoring	1/1/82	(1) Install noble gas effluent monitors.	Complete
		1/1/82	(2) Provide capability for effluent monitoring of iodine.	Complete
		1/1/82	(3) Install in-containment radiation-level monitor.	Complete
		1/1/82	(4) Provide continuous indication of containment pressure.	Complete
		1/1/82	(5) Provide continuous indication of containment water level.	Complete
		1/1/82	(6) Provide continuous indication of hydrogen concentration in containment.	Complete

LICENSEE COMMITMENTS ON APPLICABLE 0737 ITEMS FROM GENERIC LETTER 82-10

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)*
I.A.1.3.1	Limit Overtime	10/1/82 per Gen. Ltr. 82-12 dtd. 6/15/82	Revise administrative procedures to limit overtime in accordance w/NRC Policy Statement issued by Gen. Ltr. No. 82-12, dtd. June 15, 1982.	Complete
I.A.1.3.2	**Minimum Shift Crew	To be Superseded by Proposed Rule	To be addressed in the Final Rule on Licensed Operator Staffing at Nuclear Power Units.	To be addressed when Final Rule is issued.
I.C.1	**Revise Emergency Procedures	Superseded by SECY 82-111	Reference SECY 82-111, Requirements for Emergency Response Capability.	To be determined.
II.D.1.2	RV and SV Test Programs	7/1/82	Submit plant specific rpts on relief and safety valve test program	Complete
II.D.1.3	Block Valve Test Program	7/1/82	Submit report of results of test program	Complete
II.K.3.30 & 31	**SBLOCA Analysis	1 yr. after staff approval of model	Submit plant specific analyses.	To be determined following staff approval of model.
III.A.1.2	**Staffing Levels for Emergency Situations	Superseded by SECY 82-111	Reference SECY 82-111, Requirements for Emergency Response Capability	To be determined.
III.A.1.2	**Upgrade Emergency Support Facilities	""	""	""
III.A.2.2	**Meteorological Data	""	""	""
III.D.3.4	Control Room Habitability	To be determined by licensee	Modify facility as identified by licensee study	Complete

*Where completion date refers to a refueling outage (the estimated date when the outage begins), the item will be completed prior to the restart of the facility.

**Not Part of Confirmatory Order