

November 21, 1990

Docket No. 50-272

DISTRIBUTION w/enclosures:

Mr. Steven E. Miltenberger  
Vice President and Chief Nuclear  
Officer  
Public Service Electric & Gas Company  
Post Office Box 236  
Hancocks Bridge, New Jersey 08038

Docket File MO'Brien Wanda Jones  
WBateman NRC PDR OGC JCalvo  
RBlough Local PDR DHagan  
SVarga PDI-2 Rdg EJordan ACRS(10)  
BBoger WButler GPA/PA JStone  
JRaileigh GHill(4) PSwetland  
OC/LFMB LCunningham Mfranovich

Dear Mr. Miltenberger:

SUBJECT: RADIATION MONITORING SYSTEM, CHANNEL FUNCTIONAL TESTS, SALEM  
GENERATING STATION, UNIT NO. 1 (TAC NO. 75851)

The Commission has issued the enclosed Amendment No.116 to Facility Operating License No. DPR-70 for the Salem Generating Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated January 22, 1990.

This amendment adds a clarifying statement to the Surveillance Requirements specified in Table 4.3-13 of Technical Specification 3.3.3.9 to Table Notation item (1) 3. The clarifying statement changes the CHANNEL FUNCTIONAL TEST response requirements associated with radiation monitor 1-R12A to match its actual design.

Your original license amendment request also proposed adding clarifying statements to Table Notation items (2) 3, and (2) 4, of Table 4.3-13. These proposed clarifying statements were inadvertently removed during issuance of license Amendment No. 79. Therefore, these statements were restored to the Salem Unit 1 TSs by staff correction letter dated March 12, 1990.

You are requested to notify the Commission in writing, when the enclosed amendment is implemented at Salem Unit No. 1.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

James C. Stone, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 116 to License No. DPR-70
  - 2. Safety Evaluation
- cc w/enclosures:

See next page

[TAC NO. 75851 SALEM]

\*Previously Concurred

MO'Brien PDI-2/PM  
JStone:tlc  
11/21/90 11/20/90

\*OGC PDI-2/D \*PRPB  
EHoller WButler LCunningham  
11/07/90 11/21/90 11/02/90

*Handwritten initials: WJ*

*Handwritten initials: JFol*

*Handwritten signature*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

November 21, 1990

Docket No. 50-272

Mr. Steven E. Miltenberger  
Vice President and Chief Nuclear  
Officer  
Public Service Electric & Gas Company  
Post Office Box 236  
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: RADIATION MONITORING SYSTEM, CHANNEL FUNCTIONAL TESTS, SALEM  
GENERATING STATION, UNIT NO. 1 (TAC NO. 75851)

The Commission has issued the enclosed Amendment No. 116 to Facility Operating License No. DPR-70 for the Salem Generating Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated January 22, 1990.

This amendment adds a clarifying statement to the Surveillance Requirements specified in Table 4.3-13 of Technical Specification 3.3.3.9 to Table Notation item (1) 3. The clarifying statement changes the CHANNEL FUNCTIONAL TEST response requirements associated with radiation monitor 1-R12A to match its actual design.

Your original license amendment request also proposed adding clarifying statements to Table Notation items (2) 3, and (2) 4, of Table 4.3-13. These proposed clarifying statements were inadvertently removed during issuance of license Amendment No. 79. Therefore, these statements were restored to the Salem Unit 1 TSs by staff correction letter dated March 12, 1990.

You are requested to notify the Commission in writing, when the enclosed amendment is implemented at Salem Unit No. 1.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "James C. Stone".

James C. Stone, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 116 to  
License No. DPR-70
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. Steven E. Miltenberger  
Public Service Electric & Gas Company      Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire  
Bishop, Cook, Purcell & Reynolds  
1400 L Street NW  
Washington, DC 20005-3502

Richard B. McGlynn, Commission  
Department of Public Utilities  
State of New Jersey  
101 Commerce Street  
Newark, NJ 07102

Richard Fryling, Jr., Esquire  
Law Department - Tower 5E  
80 Park Place  
Newark, NJ 07101

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. L. K. Miller  
General Manager - Salem Operations  
Salem Generating Station  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township  
c/o Mary O. Henderson, Clerk  
Municipal Building, P.O. Box 157  
Hancocks Bridge, NJ 08038

Mr. S. LaBruna  
Vice President - Nuclear Operations  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, New Jersey 08038

Mr. Bruce A. Preston, Manager  
Licensing and Regulation  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Thomas P. Johnson, Senior Resident  
Inspector  
Salem Generating Station  
U.S. Nuclear Regulatory Commission  
Drawer I  
Hancocks Bridge, NJ 08038

Mr. David Wersan  
Assistant Consumer Advocate  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director  
Radiation Protection Programs  
NJ Department of Environmental  
Protection  
CN 415  
Trenton, NJ 08625-0415

Mr. Scott B. Ungerer  
MGR. - Joint Generation Projects  
Atlantic Electric Company  
P.O. Box 1500  
1199 Black Horse Pike  
Pleasantville, NJ 08232

Maryland People's Counsel  
American Building, 9th Floor  
231 East Baltimore Street  
Baltimore, Maryland 21202

Mr. Jack Urban  
General Manager, Fuels Department  
Delmarva Power & Light Company  
800 King Street  
Wilmington, DE 19899

Mr. J. T. Robb, Director  
Joint Owners Affairs  
Philadelphia Electric Company  
955 Chesterbrook Blvd., 51A-13  
Wayne, PA 19087

Public Service Commission of Maryland  
Engineering Division  
ATTN: Chief Engineer  
231 E. Baltimore Street  
Baltimore, MD 21202-3486



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 116  
License No. DPR-70

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
  - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated January 22, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:

9012050039 901121  
PDR ADOCK 05000272  
P PNU

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 116, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and is to be implemented within 60 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/s/

Walter R. Butler, Director  
Project Directorate I-2  
Division of Reactor Projects - I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: November 21, 1990

PDI-2/D  
MC  
11/21/90

PDI-2/PM  
JStone  
10/31/90

OGC  
E Hollen  
11/7/90

PDI-2/D  
WButler  
11/21/90

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 116, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and is to be implemented within 60 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director  
Project Directorate I-2  
Division of Reactor Projects - I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: November 21, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 116

FACILITY OPERATING LICENSE NO. DPR-70

DOCKET NO. 50-272

Revise Appendix A as follows:

Remove Page

3/4 3-69

Insert Page

3/4 3-69

TABLE 4.3-13 (Continued)

TABLE NOTATION

- (1) The CHANNEL FUNCTIONAL TEST shall also demonstrate that automatic isolation of this pathway and control room alarm annunciation occurs if any of the following conditions exist:
    1. Instrument indicates measured levels at or above the alarm/trip setpoint.
    2. Circuit failure. (Loss of Power)
    3. Instrument indicates a downscale failure. (Alarm Only)  
(Indication on instrument drawer in Control Equipment Room only for 1-R12A)
  
  - (2) The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
    1. Instrument indicates measured levels at or above the alarm/trip setpoint.
    2. Circuit failure. (Loss of Power)
    3. Instrument indicates a downscale failure. (Indication on instrument drawer in Control Equipment Room only for 1-R16).
    4. Instrument controls not set in operate mode. (Applicable to 1-R16 only)
  
  - (3) The initial CHANNEL CALIBRATION was performed using appropriate liquid or gaseous calibration sources obtained from reputable suppliers. The activity of the calibration sources were reconfirmed using a multi-channel analyzer which was calibrated using one or more NBS standards.
  
  - (4) The CHANNEL CALIBRATION shall include the use of standard gas samples containing a nominal:
    1. One volume percent oxygen, balance nitrogen, and
    2. Four volume percent oxygen, balance nitrogen.
- \* At all times  
\*\* During waste gas holdup system operation.  
\*\*\* During containment purge or containment pressure - vacuum relief.





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
SUPPORTING AMENDMENT NO. 116 TO FACILITY OPERATING LICENSE NO. DPR-70

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

SALEM GENERATING STATION, UNIT NO. 1

DOCKET NO. 50-272

1.0 INTRODUCTION

By letter dated January 22, 1990 (Ref. 1), Public Service Electric & Gas Company requested an amendment to Facility Operating License No. DPR-70 for the Salem Generating Station, Unit No. 1. The proposed amendment would revise Salem Unit No. 1 Technical Specification (TS) Table 4.3-13, Table Notation, by adding clarification statements that would permit surveillances to be conducted according to the actual design of the 1-R12A and 1-R16 radiation monitor systems

2.0 EVALUATION

The proposed amendment would change the TSs by adding clarifying statements to the Surveillance Requirements specified in Table 4.3-13, Table Notation, of Technical Specification 3.3.3.9. These changes consist of adding statements to Table 4.3.13, Table Notation, as follows: item (1) 3. "(Indication on the instrument drawer in Control Equipment Room only for 1-R12A)"; item (2) 3. "(Indication on the instrument drawer in Control Equipment Room only for 1-R16)"; and item (2) 4. "(Applicable to 1-R16 only)". The clarifying statements change the CHANNEL FUNCTIONAL TEST response requirements associated with radiation monitors 1-R12A and 1-R16 to match their actual design.

The 1-R12A (Containment Radioactive Noble Gas Monitor) Radiation Monitoring System (RMS) channel monitors the radioactive noble gas content of the containment atmosphere via an LFE model MC12C Geiger-Muller tube (Ref. 2). The channel is used in the identification of Reactor Coolant System (RCS) leakage in conjunction with the containment sump level monitoring system, the containment fan cooler condensate flow rate monitors, and the containment radioactive particulate (1-R11A) radiation monitoring system. Containment atmosphere samples are passed through a filter paper where the air flow continuously moves past the 1-R11A detector (Ref. 2). The air sample then passes through a charcoal cartridge (monitored by the 1-R12B monitor) and is then mixed into a fixed shielded volume where it is viewed by the 1-R12A monitor. The air sample is then returned to the containment.

Salem Unit 1 Amendment No. 79 approved the use of 1-R12A as an additional Noble Gas Activity Monitor under the CONTAINMENT PURGE AND PRESSURE - VACUUM RELIEF (CP/P-VR) section of Tables 3.3-13 and 4.3-13. Although radiation monitor 1-R12A already has Surveillance Requirements specified in Technical Specification 3.3.3.1, Table 4.3-3, these requirements were added to the Surveillance Requirements of Table 4.3-13. This change was made in order to ensure a channel check was performed prior to each release through its associated pathway and to ensure that the alarm/trip setpoint of the 1-R12A, when functioning as an effluent monitor, was established per Technical Specification 3.3.3.9 requirements.

Radiation monitor 1-R12A serves as an alternate monitor to radiation monitor 1-R41C (Plant Vent Radiation Noble Gas monitor) during CP/P-VR operations. The 1-R41C corroborates the 1-R12A channel indications when the CP/P-VR valves are open and has the capability of automatic isolation of the CP/P-VR System (as well as the closure of the WG41 valve, "Gas Decay Tank Vent Control Valve") (Ref. 2). When the 1-R12A monitor serves as an alternate to 1-R41C, an alarm signal from the 1-R12A channel will cause the automatic isolation of CP/P-VR System. However, the system is designed such that a downscale failure of radiation monitor 1-R12A will not signal an alarm in the control room (Ref. 1). 1-R12A failure indication is provided only on the instrument drawer. Similar to radiation monitor 1-R41C, a downscale failure on radiation monitor 1-R12A will not actuate automatic termination of the release path.

The 1-R12A Radiation Monitor will still be functionally tested to assure that it is OPERABLE per design and according to the Technical Specifications, the proposed change does not change the requirements to maintain the 1-R12A Radiation Monitor OPERABLE in accordance with the associated Limiting Condition for Operation. The additional statement clarifies the method of verifying the performance of the CHANNEL FUNCTIONAL TEST and does not affect the capability of the 1-R12A instrumentation to isolate the release path on the appropriate high radiation signal. Based on the above discussion, the staff has determined that the additional statement to the Table 4.3-13 Table Notation, item (1) 3. of Technical Specification 3.3.3.9 is acceptable.

Radiation monitor 1-R16 functions as a redundant monitor to 1-R41C when the Plant Vent Header System (PVHS) is in operation. The proposed clarifying statements for Table Notation items (2) 3. and 4. were inadvertently removed during issuance of license Amendment No. 79. The statements were restored to the Salem Unit 1 TSs by a staff correction letter dated March 12, 1990.

In addition, the staff, with the consent of the licensee, made an administrative change to the revised technical specification page. The radiation monitor designated 1R16 in item (2)3. was changed to 1-R16.

### 3.0 ENVIRONMENTAL CONSIDERATION

The amendment involves a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to the surveillance requirements.

The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the type, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Part 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with issuance of the amendment.

#### 4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register (55 FR 8236) on March 7, 1990 and consulted with the State of New Jersey. No public comments were received and the State of New Jersey did not have any comments.

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of the amendment will not be inimical to the common defense and security nor to the health and the safety of the public.

#### 5.0 REFERENCES

1. Letter (LCR-89-14) from S. LaBruna (PSE&G) to USNRC, dated January 22, 1990.
2. "ESF Signal Actuation: Containment Vent Isolation on 1R12A Channel Spike", License Event Report, LER Number 90-013-00, Salem Generating Station - Unit 1, May 9, 1990.

Principal Contributor: M. Franovich

Dated: November 21, 1990