

Docket Nos. 50-272
and 50-311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric and Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Pasted
Collection to
Ammt. 108 to DPR-70

Dear Mr. Miltenberger:

SUBJECT: PRESSURE-TEMPERATURE LIMITS CORRECTION LETTER
(TAC NOS. 71774 AND 71775)

RE: SALEM GENERATING STATION, UNIT NOS. 1 AND 2

By letter dated January 29, 1990, we issued Amendment Nos. 108 and 86 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, respectively. Through an oversight, the Bases for the Reactor Head Vents (Section B 3/4.4.12), which had been previously approved in Amendments 101 and 78 were left out of the revised Bases sections included with Amendments 108 and 86. No changes were made to section B 3/4.4.12 by Amendments 108 and 86. However, because of extensive revisions to Section B 3/4.4.10, Pressure/Temperature Limits, the page numbers changed. The enclosed pages are to be used to replace the pages sent in Amendments 108 and 86 as follows:

Salem Unit 1, Amendment 108 - Replace page B 3/4 4-17 with enclosed page B 3/4 4-17

Salem Unit 2, Amendment 86 - Replace page B 3/4 4-18 with enclosed page B 3/4 4-18.

Sincerely,

/s/

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Technical Specification
Replacement pages

cc w/enclosure: See next page

DISTRIBUTION w/enclosure:

Docket File MO'Brien (2)
NRC PDR OGC
Local PDR DHagan
PDI-2 Reading EJordan
GPA/PA JStone
Rita Jaques, ARM/LFMB

Wanda Jones
JCalvo
Tech Branch
ACRS (10)
MThadani

JDyer
JLinville
BBoger
WButler
GHill (8)

[71774/5]

PDI-2/A
MO'Brien
2/12/90

Jm
PDI-2/PM
JStone:mj
2/19/90

PDI-2/D
WButler
2/15/90

WB



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 15, 1990

Docket Nos. 50-272
and 50-311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric and Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: PRESSURE-TEMPERATURE LIMITS CORRECTION LETTER
(TAC NOS. 71774 AND 71775)

RE: SALEM GENERATING STATION, UNIT NOS. 1 AND 2

By letter dated January 29, 1990, we issued Amendment Nos. 108 and 86 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, respectively. Through an oversight, the Bases for the Reactor Head Vents (Section B 3/4.4.12), which had been previously approved in Amendments 101 and 78 were left out of the revised Bases sections included with Amendments 108 and 86. No changes were made to section B 3/4.4.12 by Amendments 108 and 86. However, because of extensive revisions to Section B 3/4.4.10, Pressure/Temperature Limits, the page numbers changed. The enclosed pages are to be used to replace the pages sent in Amendments 108 and 86 as follows:

Salem Unit 1, Amendment 108 - Replace page B 3/4 4-17 with enclosed page B 3/4 4-17

Salem Unit 2, Amendment 86 - Replace page B 3/4 4-18 with enclosed page B 3/4 4-18.

Sincerely,

A handwritten signature in cursive script that reads "James C. Stone".

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Technical Specification
Replacement pages

cc w/enclosure: See next page

Mr. Steven E. Miltenberger
Public Service Electric & Gas Company

Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire
Conner and Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, NW
Washington, DC 20006

Richard B. McGlynn, Commission
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. L. K. Miller
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. S. LaBruna
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Bruce A. Preston, Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Thomas P. Johnson, Senior Resident
Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Richard F. Engel
Deputy Attorney General
Department of Law and Public Safety
CN-112
State House Annex
Trenton, NJ 08625

Mr. Scott B. Ungerer
MGR. - Joint Generation Projects
Atlantic Electric Company
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, NJ 08232

Dr. Jill Lipoti, Ph.D
New Jersey Department of Environmental
Protection
Division of Environmental Quality
Radiation Protection Programs
State of New Jersey
CN 415
Trenton, NJ 08625

Mr. Jack Urban
General Manager, Fuels Department
Delmarva Power & Light Company
800 King Street
Wilmington, DE 19899

Maryland People's Counsel
American Building, 9th Floor
231 East Baltimore Street
Baltimore, Maryland 21202

Public Service Commission of Maryland
Engineering Division
ATTN: Chief Engineer
231 E. Baltimore Street
Baltimore, MD 21202-3486

REACTOR COOLANT SYSTEM

BASES

3/4.4.10 STRUCTURAL INTEGRITY

The inspection programs for ASME Code Class 1, 2 and 3 components ensure that the structural integrity of these components will be maintained at an acceptable level throughout the life of the plant. To the extent applicable, the inspection program for these components is in compliance with Section XI of the ASME Boiler and Pressure Vessel Code.

REACTOR COOLANT SYSTEM

BASES

3/4.4. 1] STRUCTURAL INTEGRITY

The inservice inspection and testing programs for ASME Code Class 1, 2 and 3 components ensure that the structural integrity and operational readiness of these components will be maintained at an acceptable level through the life of the plant. These programs are in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR Part 50.55a(g) except where specific written relief has been granted by the Commission pursuant to 10 CFR Part 50.55a(g)(6)(i).