February 15 **`990** Docket Nos. 50-272 and 50-311 Mr. Steven E. Miltenberger Vice President and Chief Nuclear Officer Public Service Electric and Gas Company Post Office Box 236 Hancocks Bridge, New Jersey 08038 Dear Mr. Miltenberger: SUBJECT: PRESSURE-TEMPERATURE LIMITS CORRECTION LETTER (TAC NOS. 71774 AND 71775)

RE: SALEM GENERATING STATION, UNIT NOS. 1 AND 2

By letter dated January 29, 1990, we issued Amendment Nos. 108 and 86 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, respectively. Through an oversight, the Bases for the Reactor Head Vents (Section B 3/4.4.12), which had been previously approved in Amendments 101 and 78 were left out of the revised Bases sections included with Amendments 108 and 86. No changes were made to section B 3/4.4.12 by Amendments 108 and 86. However, because of extensive revisions to Section B 3/4.4.10, Pressure/Temperature Limits, the page numbers changed. The enclosed pages are to be used to replace the pages sent in Amendments 108 and 86 as follows:

Salem Unit 1, Amendment 108 - Replace page B 3/4 4-17 with enclosed page B 3/4 4-17

Salem Unit 2. Amendment 86 - Replace page B 3/4 4-18 with enclosed page B 3/4 4-18.

Sincerely,

/s/ James C. Stone, Project Manager Project Directorate I-2 Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

9002260573 900215 PDR ADOCK 05000272

'e •

Enclosure: Technical Specification Replacement pages

cc w/enclosure: See next page

DISTRIBUTION w/enclosure: MO'Brien (2) Docket File OGC NRC PDR DHagan Local PDR EJordan PDI-2 Reading GPA/PA JStone Rita Jaques, ARM/LFMB



PDI-2/D

Wanda Jones

Tech Branch

ACRS (10)

MThadani

JCalvo

JDyer JLinville BBoger WButler GHill (8)

[71774/5]



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

February 15, 1990

Docket Nos. 50-272 and 50-311

> Mr. Steven E. Miltenberger Vice President and Chief Nuclear Officer Public Service Electric and Gas Company Post Office Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: PRESSURE-TEMPERATURE LIMITS CORRECTION LETTER (TAC NOS. 71774 AND 71775)

RE: SALEM GENERATING STATION, UNIT NOS. 1 AND 2

By letter dated January 29, 1990, we issued Amendment Nos. 108 and 86 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, respectively. Through an oversight, the Bases for the Reactor Head Vents (Section B 3/4.4.12), which had been previously approved in Amendments 101 and 78 were left out of the revised Bases sections included with Amendments 108 and 86. No changes were made to section B 3/4.4.12 by Amendments 108 and 86. However, because of extensive revisions to Section B 3/4.4.10, Pressure/Temperature Limits, the page numbers changed. The enclosed pages are to be used to replace the pages sent in Amendments 108 and 86 as follows:

Salem Unit 1, Amendment 108 - Replace page B 3/4 4-17 with enclosed page B 3/4 4-17

Salem Unit 2, Amendment 86 - Replace page B 3/4 4-18 with enclosed page B 3/4 4-18.

Sincerely,

tames C. Stone

James C. Stone, Project Manager Project Directorate I-2 Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

Enclosure: Technical Specification Replacement pages

cc w/enclosure: See next page

Mr. Steven E. Miltenberger Public Service Electric & Gas Company

#### cc:

. :

. . <del>.</del>

.

Mark J. Wetterhahn, Esquire Conner and Wetterhahn Suite 1050 1747 Pennsylvania Avenue, NW Washington, DC 20006

Richard Fryling, Jr., Esquire Law Department - Tower 5E 80 Park Place Newark, NJ 07101

Mr. L. K. Miller General Manager - Salem Operations Salem Generating Station P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. S. LaBruna Vice President - Nuclear Operations Nuclear Department P.O. Box 236 Hancocks Bridge, New Jersey 08038

Mr. Thomas P. Johnson, Senior Resident Inspector Salem Generating Station U.S. Nuclear Regulatory Commission Drawer I Hancocks Bridge, NJ 08038

Richard F. Engel Deputy Attorney General Department of Law and Public Safety CN-112 State House Annex Trenton, NJ 08625

Dr. Jill Lipoti, Ph.D New Jersey Department of Environmental Protection Division of Environmental Quality Radiation Protection Programs State of New Jersey CN 415 Trenton, NJ 08625

Maryland People's Counsel American Building, 9th Floor 231 East Baltimore Street Baltimore, Maryland 21202 Salem Nuclear Generating Station

Richard B. McGlynn, Commission Department of Public Utilities State of New Jersey 101 Commerce Street Newark, NJ 07102

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancocks Bridge, NJ 08038

Mr. Bruce A. Preston, Manager Licensing and Regulation Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. David Wersan Assistant Consumer Advocate Office of Consumer Advocate 1425 Strawberry Square Harrisburg, PA 17120

Mr. Scott B. Ungerer MGR. - Joint Generation Projects Atlantic Electric Company P.O. Box 1500 1199 Black Horse Pike Pleasantville, NJ 08232

Mr. Jack Urban General Manager, Fuels Department Delmarva Power & Light Company 800 King Street Wilmington, DE 19899

Public Service Commission of Maryland Engineering Division ATTN: Chief Engineer 231 E. Baltimore Street Baltimore, MD 21202-3486 REACTOR COOLANT STSTEM

## <u>BASES</u>

# 3/4.4.10 STRUCTURAL INTEGRITY

The inspection programs for ASME Code Class 1, 2 and 3 components ensure that the structural integrity of these components will be maintained at an acceptable level throughout the life of the plant. To the extent applicable, the inspection program for these components is in compliance with Section XI of the ASME Boiler and Pressure Vessel Code.

# 3/4.4.11 THIS SECTION INTENTIONALLY BLANK

#### 3/4.4.12 REACTOR VESSEL HEAD VENTS

Reactor Coolant System vents are provided to exhaust noncondensible gases and/or steam from the Reactor Coolant System that could inhibit natural circulation core cooling. The OPERABILITY of a reactor vessel head vent path ensures the capability exists to perform this function.

The valve redundancy of the Reactor Coolant System vent paths serves to minimize the probability of inadvertant or irreversible actuation while ensuring that a single failure in a vent valve power supply or control system does not prevent isolation of the vent path.

The function, capabilities, and testing requirements of the Reactor Coolant System Vent Systems are consistent with the requirements of Item II.B.1 of NUREG-0737, "Clarification of TMI Action Plan Requirements," November 1980.

Correction letter dated February 15, 1990, to Amendment 108 dated January 29, 1990.

SALEM UNIT 1

B 3/4 4-17

Amendment No. 108

9002270001 900215 PDR ADBCK 05000272 P PNU

#### REACTOR COOLANT SYSTEM

## BASES

.\*

#### 3/4.4. 19 STRUCTURAL INTEGRITY

The inservice inspection and testing programs for ASME Code Class 1, 2 and 3 components ensure that the structural integrity and operational readiness of these components will be maintained at an acceptable level through the life of the plant. These programs are in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR Part 50.55a(g) except where specific written relief has been granted by the Commission pursuant to 10 CFR Part 50.55a(g)(6)(i).

#### 3/4.4.12 REACTOR VESSEL HEAD VENTS

Reactor Coolant System vents are provided to exhaust noncondensible gases and/or steam from the Reactor Coolant System that could inhibit natural circulation core cooling. The OPERABILITY of a reactor vessel head vent path ensures the capability exists to perform this function.

The valve redundancy of the Reactor Coolant System vent paths serves to minimize the probability of inadvertant or irreversible actuation while ensuring that a single failure vent in a valve power supply or control system does not prevent isolation of the vent path.

The function, capabilities, and testing requirements of the Reactor Coolant System Vent Systems are consistent with the requirements of Item II.B.1 of NUREG-0737, "Clarification of TMI Action Plan Requirements," November 1980.

Correction letter dated February 15, 1990, to Amendment 86 dated January 29, 1990.

SALEM UNIT 2

в 3/4 4-18

Amendment No.86