

Union Electric

One Ameren Plaza
1901 Chouteau Avenue
PO Box 66149
St. Louis, MO 63166-6149
314.621.3222

June 12, 2001

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

ULNRC-04486



**DOCKET NUMBER 50-483
UNION ELECTRIC COMPANY
CALLAWAY PLANT
LICENSE AMENDMENT 144**

Union Electric Company hereby informs the Commission of the implementation of Amendment 144 to Facility Operating License NPF-30 for Callaway Plant. Amendment 144 deleted Technical Specification Section 5.5.3, "Post Accident Sampling," for the Callaway Plant and thereby eliminates the requirements to have and maintain the post accident sampling system (PASS). The amendment was implemented at Callaway on June 4, 2001.

Very truly yours,

A handwritten signature in cursive script, appearing to read "J. Blosser".

John D. Blosser
Manager – Regulatory Affairs

BFH/jdg

A001

cc: M. H. Fletcher
Professional Nuclear Consulting, Inc.
19041 Raines Drive
Derwood, MD 20855-2432

Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Mr. Jack Donohew (2)- **OPEN BY ADDRESSEE ONLY**
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop OWFN 7E1
11555 Rockville Pike
Rockville, MD 20852-2738

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

Ron Kucera
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

Denny Buschbaum
TU Electric
P.O. Box 1002
Glen Rose, TX 76043

Pat Nugent
Pacific Gas & Electric
Regulatory Services
P.O. Box 56
Avila Beach, CA 93424