

**From:** Lawrence Burkhart  
**To:** Brian Sepelak  
**Date:** 6/12/01 3:22PM  
**Subject:** RAI #7

Brian,

Attached is a request regarding LOCA analyses parameters that affect the PCT analysis. This reviewer will be at the call tomorrow at 8:00 a.m if you should have any questions. It is very short and a confirmation of the statement, if appropriate, is all that is needed.

To show that the Westinghouse generically approved LBLOCA and SBLOCA analysis methodologies continue to apply specifically to the Beaver Valley plant(s) provide a statement, if appropriate, that Beaver Valley and its vendor have **ongoing processes** which assure that LOCA **analysis input values** for peak cladding temperature-sensitive parameters **bound the as-operated plant values** for those parameters.

**Mail Envelope Properties**

(3B266BE2.537 : 6 : 21370)

**Subject:** RAI #7  
**Creation Date:** 6/12/01 3:22PM  
**From:** Lawrence Burkhart

**Created By:** LJB@nrc.gov

**Recipients**

firstenergycorp.com  
sepelakb (Brian Sepelak)

**Post Office**

firstenergycorp.com

**Route**

internet

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
RAIFrankOrr.wpd	2020	06/12/01 03:18PM
MESSAGE	786	06/12/01 03:22PM

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard