

## CONTAINMENT SYSTEMS

### 3/4.6.5 VACUUM RELIEF VALVES

#### LIMITING CONDITION FOR OPERATION

---

3.6.5 Two vacuum relief lines shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With one vacuum relief line inoperable, restore the vacuum relief line to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.6.5 No additional Surveillance Requirements other than those required by Specification 4.0.5.

or indirectly any control over (i) the facility, (ii) power or energy produced by the facility, or (iii) the licensee of the facility. Further, any rights acquired under this authorization may be exercised only in compliance with and subject to the requirements and restrictions of this operating license, the Atomic Energy Act of 1954, as amended, and the NRC's regulations. For purposes of this condition, the limitations of 10 CFR 50.81, as now in effect and as they may be subsequently amended, are fully applicable to the equity investors and any successors in interest to the equity investors, as long as the license for the facility remains in effect.

- (b) Entergy Louisiana, Inc. (or its designee) to notify the NRC in writing prior to any change in (i) the terms or conditions of any lease agreements executed as part of the above authorized financial transactions, (ii) any facility operating agreement involving a licensee that is in effect now or will be in effect in the future, or (iii) the existing property insurance coverages for the facility, that would materially alter the representations and conditions, set forth in the staff's Safety Evaluation enclosed to the NRC letter dated September 18, 1989. In addition, Entergy Louisiana, Inc. or its designee is required to notify the NRC of any action by equity investors or successors in interest to Entergy Louisiana, Inc. that may have an effect on the operation of the facility.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

1. Maximum Power Level

EOI is authorized to operate the facility at reactor core power levels not in excess of 3390 megawatts thermal (100% power) in accordance with the conditions specified herein.

2. Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 170 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. EOI shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

H. This license is effective as the date of issuance and shall expire at midnight on December 18, 2024.

FOR THE NUCLEAR REGULATORY  
COMMISSION

original signed by H.R. Denton

Harold R. Denton, Director  
Office of Nuclear Reactor Regulation

Enclosures:

1. (DELETED)
2. Attachment 2
3. Appendix A (Technical Specifications) (NUREG-1117)
4. Appendix B (Environmental Protection Plan)
5. Appendix C (Antitrust Conditions)

Date of Issuance: March 16, 1985