



FPL

JUN 11 2001

L-2001-143
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report – May 2001

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the May 2001 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

SM

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE24

DOCKET NO.: 50-250
UNIT: Turkey Point Unit 3
DATE: 6/6/01
COMPLETED BY: Stavroula Mihalakea
TELEPHONE: (305) 246-6454

Reporting Period **May, 2001**

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	3623	181382.8
No. of hours generator was on line (service hours)	744	3623	179147.4
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	514938	2561196	116178824

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training/License Examination
F - Administrative
G - Operational Error (Explain)
H - Other

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100%, until 5/04/01, when power was reduced to 40% to perform the turbine valve testing. Power was returned to 100% on 5/06/01.

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 6/6/01
 COMPLETED BY: Stavroula Mihalakea
 TELEPHONE: (305) 246-6454

Reporting Period **May, 2001**

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	3494.5	177832.5
No. of hours generator was on line (service hours)	744	3486.6	173438.1
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	531445	2473850	113473599

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Schedule d	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% during the month of May 2001.