

February 21, 1995

Mr. Leon R. Eliason  
Chief Nuclear Officer & President  
Nuclear Business Unit  
Public Service Electric and Gas  
Company  
Post Office Box 236  
Hancocks Bridge, NJ 08038

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT,  
COMPRESSED AIR LINE CONTAINMENT ISOLATION VALVES, UNREVIEWED SAFETY  
QUESTION, SALEM NUCLEAR GENERATING STATION, UNITS 1 AND 2 (TAC NOS.  
M82666 AND M82667)

Dear Mr. Eliason:

Enclosed for your information is a copy of the Environmental Assessment and Finding of No Significant Impact related to a request for approval of a license amendment to address an unreviewed safety question associated with the containment isolation valves. By letter dated April 16, 1993, you submitted a request to change the licensing basis for Salem, Units 1 and 2, to reflect the fact that the air-operated outboard isolation valves in the containment penetration for lines supplying control air to equipment in the containment, unlike other isolation valves, do not fail closed on loss of 125 Volt DC power to their control solenoids.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,  
/s/

Leonard N. Olshan, Senior Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/50-311

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION

Docket File	PUBLIC
PDI-2 Reading	SVarga
JZwolinski	LOlshan
MO'Brien	OGC
EJordan	ACRS(4)
OPA	JWhite, RGN-I

NEED FILE CENTER COPY

\*Previously Concurred

OFFICE	SN for 2/16/95 PDI-2/LA	PDI-2/PM	OGC*	PDI-2/D	
NAME	MO'Brien	LOlshan:rb	CMarco	JStolz	
DATE	2/15/95	2/15/95	02/08/95	2/15/95	

OFFICIAL RECORD COPY

DOCUMENT NAME: SA86266.EA

9503100115 950221  
PDR ADOCK 05000272  
P PDR

CP 1  
JFO/ 1/1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

February 21, 1995

Mr. Leon R. Eliason  
Chief Nuclear Officer & President  
Nuclear Business Unit  
Public Service Electric and Gas  
Company  
Post Office Box 236  
Hancocks Bridge, NJ 08038

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT,  
COMPRESSED AIR LINE CONTAINMENT ISOLATION VALVES, UNREVIEWED SAFETY  
QUESTION, SALEM NUCLEAR GENERATING STATION, UNITS 1 AND 2 (TAC NOS.  
M82666 AND M82667)

Dear Mr. Eliason:

Enclosed for your information is a copy of the Environmental Assessment and Finding of No Significant Impact related to a request for approval of a license amendment to address an unreviewed safety question associated with the containment isolation valves. By letter dated April 16, 1993, you submitted a request to change the licensing basis for Salem, Units 1 and 2, to reflect the fact that the air-operated outboard isolation valves in the containment penetration for lines supplying control air to equipment in the containment, unlike other isolation valves, do not fail-closed on loss of 125 Volt DC power to their control solenoids.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "Leonard N. Olshan", is written over the typed name.

Leonard N. Olshan, Senior Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/50-311

Enclosure: Environmental Assessment

cc w/encl: See next page

Mr. Leon R. Eliason  
Public Service Electric & Gas  
Company

cc:

Mark J. Wetterhahn, Esquire  
Winston & Strawn  
1400 L Street NW  
Washington, DC 20005-3502

Richard Fryling, Jr., Esquire  
Law Department - Tower 5E  
80 Park Place  
Newark, NJ 07101

Mr. John Summers  
General Manager - Salem Operations  
Salem Generating Station  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. J. Hagan  
Vice President - Nuclear Operations  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, New Jersey 08038

Mr. Charles S. Marschall, Senior  
Resident Inspector  
Salem Generating Station  
U.S. Nuclear Regulatory Commission  
Drawer I  
Hancocks Bridge, NJ 08038

Dr. Jill Lipoti, Asst. Director  
Radiation Protection Programs  
NJ Department of Environmental  
Protection and Energy  
CN 415  
Trenton, NJ 08625-0415

Maryland Office of People's Counsel  
6 St. Paul Street, 21st Floor  
Suite 2102  
Baltimore, Maryland 21202

Ms. R. A. Kankus  
Joint Owner Affairs  
PECO Energy Company  
965 Chesterbrook Blvd., 63C-5  
Wayne, PA 19087

Mr. S. LaBruna  
Vice President - Nuclear Engineering  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, New Jersey 08038

Salem Nuclear Generating Station,  
Units 1 and 2

Richard Hartung  
Electric Service Evaluation  
Board of Regulatory Commissioners  
2 Gateway Center, Tenth Floor  
Newark, NJ 07102

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Lower Alloways Creek Township  
c/o Mary O. Henderson, Clerk  
Municipal Building, P.O. Box 157  
Hancocks Bridge, NJ 08038

Mr. Frank X. Thomson, Jr., Manager  
Licensing and Regulation  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. David Wersan  
Assistant Consumer Advocate  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, PA 17120

Ms. P. J. Curham  
MGR. Joint Generation Department  
Atlantic Electric Company  
P.O. Box 1500  
6801 Black Horse Pike  
Pleasantville, NJ 08232

Carl D. Schaefer  
External Operations - Nuclear  
Delmarva Power & Light Company  
P.O. Box 231  
Wilmington, DE 19899

Public Service Commission of Maryland  
Engineering Division  
Chief Engineer  
6 St. Paul Centre  
Baltimore, MD 21202-6806

Robert Hargrove (5 copies)  
Environmental Review Coordinator  
Environmental Protection Agency  
26 Federal Plaza  
New York, NY 10278

UNITED STATES NUCLEAR REGULATORY COMMISSIONPUBLIC SERVICE ELECTRIC AND GAS COMPANYDOCKET NOS. 50-272 AND 50-311ENVIRONMENTAL ASSESSMENT ANDFINDING OF NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating License Nos. DPR-70 and DPR-75, issued to Public Service Electric and Gas Company, et al. (PSE&G or the licensee) for operation of Salem Nuclear Generating Station (SNGS), Units 1 and 2, located in Salem County, New Jersey.

ENVIRONMENTAL ASSESSMENTIdentification of the Proposed Action:

By letter dated April 16, 1993 (NLR-N83042), PSE&G requested a license amendment to reflect changes to the Updated Final Safety Analysis Report (UFSAR) for Salem, Units 1 and 2. The proposed UFSAR change would add an exception to a general statement in the containment isolation system description. The general statement is that automatic containment isolation valves that receive signals to close, fail closed on loss of air or power. The proposed exception would apply to the outboard isolation valves for the control air system. These four valves (11, 12, 21, and 22CA330, collectively identified as CA-330) fail closed on loss of air but fail as-is upon loss of the vital 125 VDC power supply to their solenoid control valves.

Need for Proposed Action:

The revision of the licensing basis is needed to exempt the CA-330 valves from the general statement in the UFSAR that automatic containment

isolation valves that receive signals to close, fail closed on loss of air or power. The staff has examined the design of the isolation system for the control air header piping penetration. With the exception of the failure position for valve CA-330 on loss of its 125 VDC power supply, the design meets all applicable criteria. Failure of the 125 VDC power supply results in a slight degradation in containment isolation reliability. Upon failure of the 125 VDC power supply, the valve will remain in the "as is" position. Since the valve is normally open, this means that the valve will stay open and will not close on an isolation signal or loss of air header pressure. For all other single failures, the valve will automatically close upon either loss of air or an isolation signal.

Environmental Impacts of the Proposed Action:

The staff has evaluated the conditions for the "as-is" failure and finds that the reduction in safety margin due to this condition is acceptably small. First of all, there is a check valve in series with the air-operated valve so that containment integrity is maintained at all times. Secondly, the probability of loss of air pressure is quite low since the normal air supply is backed up with a safety grade supply which is activated automatically upon sensing low air pressure. With an operable air supply, the penetration is not a containment leak path since the air pressure is greater than the peak calculated containment pressure.

The change will not increase the probability or consequences of accidents, no changes are being made in the types of any effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure. Accordingly, the

Commission concludes that there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential nonradiological impacts, the proposed action does involve features located entirely within the restricted area as defined in 10 CFR Part 20. It does not affect nonradiological plant effluents and has no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed action.

Alternatives to the Proposed Action:

Since the Commission has concluded there is no measurable environmental impact associated with the proposed action, any alternatives with equal or greater environmental impact need not be evaluated. As an alternative to the proposed action, the staff considered denial of the proposed action. Denial of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

Alternate Use of Resources:

This action does not involve the use of any resources not previously considered in the Final Environmental Statement for the Salem Nuclear Generating Station, Units 1 and 2, dated April 1973.

Agencies and Person Contacted:

In accordance with its stated policy, the staff consulted with the New Jersey State official regarding the environmental impact of the proposed action. The State official had no comments.


FINDING OF NO SIGNIFICANT IMPACT

Based upon the environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the application for license amendments dated April 16, 1993, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and the local public document room located at the Salem Free Public Library, 112 West Broadway, Salem, NJ 08079.

Dated at Rockville, Maryland, this 21st day of February 1995.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in dark ink, appearing to read "John F. Stolz", is written over the printed name and title.

John F. Stolz, Director  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation