September 8, 194

Mr. Steven E. Miltenbe er
Vice President and Chiw Nuclear
Officer
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: EMERGENCY DIESEL GENERATOR SURVEILLANCE TESTING, SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2 (TAC NOS. M89317 AND M89318)

The Commission has issued the enclosed Amendment Nos. 156 and 137 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications (Tss) in response to your application dated April 12, 1994 as supplemented by letter dated July 15, 1994.

These amendments eliminate the required loss of offsite power plus an engineered safety feature actuation signal test following the 24-hour endurance test, revise the 5-minute emergency diesel generator (EDG) hot restart test by separating it from the 24-hour endurance test and add a new surveillance requirement of a simple hot restart test following a 2-hour loaded run of the EDG.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal</u> <u>Register</u> notice. You are requested to notify the NRC, in writing, when these amendments have been implemented at Salem 1 and 2.

Sincerely, Original signed by: James C. Stone, Senior Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-272 and 50-311 Enclosures: 1. Amendment No. 156 to License No. DPR-70 Amendment No. 137 to License No. DPR-75 Safety Evaluation cc w/enclosures: See next page **DISTRIBUTION:** Docket File MO'Brien(2) CGrimes NRC & Local PDRs JStone **OChopra** PDI-2 Reading OGC ACRS(10) OC/LFDCB FOR FOR COMPY DHagan SVarga CMiller GHill(4) MThadani EWenzinger, RGN-I JWhite, RGN-I **OFC** :PDI-2/PM :OGC NAME :MO'Brien :JStone:tlc: :MThadani

FILENAME: A:\SA89317.AMD

<del>9409200058</del>-200032

OFFICIAL RECORD