

June 17 1995

Mr. Leon R. Eliason
Chief Nuclear Officer & President-
Nuclear Business Unit
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2 (TAC NOS. M90968 AND M90969)

Dear Mr. Eliason:

The Commission has issued the enclosed Amendment Nos. 169 and 151 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated November 18, 1994.

These amendments revise the Reactivity Control System TS Limiting Conditions for Operation for boration flow paths and charging pumps by reducing the number of operable charging pumps required for boron addition in Mode 4 from two to one.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Leonard N. Olshan, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/50-311

- Enclosures: 1. Amendment No. 169 to License No. DPR-70
- 2. Amendment No. 151 to License No. DPR-75
- 3. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

Docket File	MO'Brien	CGrimes
PUBLIC	LOlshan	SBrewer
PDI-2 Reading	OGC	ACRS(4)
SVarga	OPA	OC/LFDCB
JZwolinski	GHill(4)	JWhite, RGN-I
JStolz		

OFC	: PDI-2/LA	: PDI-2/PM	: OGC	: PDI-2/D	:	:
NAME	: MO'Brien	: LOlshan:mw:		: JStolz	:	:
DATE	: 5/18/95	: 5/22/95	: 5/31/95	: 5/24/95	:	:

OFFICIAL RECORD COPY

FILENAME: A:\SA90968.AMD

9506290350 260065

WRC FILE CENTER COPY

CP1



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 12, 1995

Mr. Leon R. Eliason
Chief Nuclear Officer & President-
Nuclear Business Unit
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2 (TAC NOS. M90968
AND M90969)

Dear Mr. Eliason:

The Commission has issued the enclosed Amendment Nos. 169 and 151 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated November 18, 1994.

These amendments revise the Reactivity Control System TS Limiting Conditions for Operation for boration flow paths and charging pumps by reducing the number of operable charging pumps required for boron addition in Mode 4 from two to one.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "Leon N. Olshan".

Leonard N. Olshan, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/50-311

Enclosures: 1. Amendment No. 169 to
License No. DPR-70
2. Amendment No. 151 to
License No. DPR-75
3. Safety Evaluation

cc w/encls: See next page

Mr. Leon R. Eliason
Public Service Electric & Gas
Company

Salem Nuclear Generating Station,
Units 1 and 2

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street NW
Washington, DC 20005-3502

Richard Hartung
Electric Service Evaluation
Board of Regulatory Commissioners
2 Gateway Center, Tenth Floor
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. John Summers
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. J. Hagan
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Frank X. Thomson, Jr., Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Charles S. Marschall, Senior
Resident Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection and Energy
CN 415
Trenton, NJ 08625-0415

Ms. P. J. Curham
MGR. Joint Generation Department
Atlantic Electric Company
P.O. Box 1500
6801 Black Horse Pike
Pleasantville, NJ 08232

Maryland Office of People's Counsel
6 St. Paul Street, 21st Floor
Suite 2102
Baltimore, Maryland 21202

Carl D. Schaefer
External Operations - Nuclear
Delmarva Power & Light Company
P.O. Box 231
Wilmington, DE 19899

Ms. R. A. Kankus
Joint Owner Affairs
PECO Energy Company
965 Chesterbrook Blvd., 63C-5
Wayne, PA 19087

Public Service Commission of Maryland
Engineering Division
Chief Engineer
6 St. Paul Centre
Baltimore, MD 21202-6806

Mr. S. LaBruna
Vice President - Nuclear Engineering
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 169
License No. DPR-70


1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated November 18, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 169, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: June 12, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 169

FACILITY OPERATING LICENSE NO. DPR-70

DOCKET NO. 50-272

Revise Appendix A as follows:

Remove Pages

3/4 1-7
3/4 1-8
3/4 1-10
3/4 1-11
3/4 1-12
3/4 1-13
3/4 1-14
3/4 1-16
B 3/4 1-3

Insert Pages

3/4 1-7
3/4 1-8
3/4 1-10
3/4 1-11
3/4 1-12
3/4 1-13
3/4 1-14
3/4 1-16
B 3/4 1-3

REACTIVITY CONTROL SYSTEMS

3/4.1.2 BORATION SYSTEMS

FLOW PATHS - SHUTDOWN

LIMITING CONDITION FOR OPERATION
=====

3.1.2.1 As a minimum, one of the following boron injection flow paths shall be OPERABLE:

- a. A flow path from the boric acid tanks via a boric acid transfer pump and a charging pump to the Reactor Coolant System if the boric acid storage system is OPERABLE, per Specification 3.1.2.6a while in MODE 4, or per Specification 3.1.2.5a while in MODE 5 or 6, or
- b. A flow path from the refueling water storage tank via a charging pump to the Reactor Coolant System if the refueling water storage tank is OPERABLE per Specification 3.1.2.6b while in MODE 4, or per Specification 3.1.2.5b while in MODE 5 or 6.

APPLICABILITY: MODES 4, 5 and 6.

ACTION:

With none of the above flow paths OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until at least one injection path is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.1 At least one of the above required flow paths shall be demonstrated OPERABLE:

- a. When the boric acid tank is a required water source, by verifying at least once per 7 days that:
 - (1) The flow path from the boric acid tank to the boric acid transfer pump, the boric acid transfer pump, and the recirculation path from the boric acid transfer pump to the boric acid tank is $\geq 63^{\circ}\text{F}$, and
 - (2) The flow path between the boric acid transfer pump recirculation line to the charging pump suction line is $\geq 50^{\circ}\text{F}$,
- b. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

REACTIVITY CONTROL SYSTEMS

FLOW PATHS - OPERATING

LIMITING CONDITION FOR OPERATION
=====

3.1.2.2 At least two of the following three boron injection flow paths shall be OPERABLE:

- a. A flow path from the boric acid tanks via a boric acid transfer pump and a charging pump to the Reactor Coolant System.
- b. Two flow paths from the refueling water storage tank via charging pumps to the Reactor Coolant System.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With only one of the above required boron injection flow paths to the Reactor Coolant System OPERABLE, restore at least two boron injection flow paths to the Reactor Coolant System to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta k/k at 200°F within the next 6 hours; restore at least two flow paths to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.2 Each of the above required flow paths shall be demonstrated OPERABLE:

- a. By verifying at least once per 7 days that:
 - (1) The flow path from the boric acid tank to the boric acid transfer pump and from the recirculation line back to the boric acid tank is $\geq 63^{\circ}\text{F}$, and
 - (2) the flow path between the boric acid tank recirculation line to the charging pump suction line is $\geq 50^{\circ}\text{F}$,
- b. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

REACTIVITY CONTROL SYSTEMS

CHARGING PUMP - SHUTDOWN

LIMITING CONDITION FOR OPERATION
=====

3.1.2.3 At least one charging pump in the boron injection flow path required by Specification 3.1.2.1 shall be OPERABLE.#

APPLICABILITY: MODES 4, 5 and 6.

ACTION:

With no charging pump OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until one charging pump is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.3 No additional Surveillance Requirements other than those required by Specification 4.0.5.

A maximum of one centrifugal charging pump shall be OPERABLE while in MODE 4 when the temperature of one or more of the RCS cold legs is less than or equal to 312°F, MODE 5, or MODE 6 when the head is on the reactor vessel.

REACTIVITY CONTROL SYSTEMS

CHARGING PUMPS - OPERATING

LIMITING CONDITION FOR OPERATION
=====

3.1.2.4 At least two charging pumps shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

With only one charging pump OPERABLE, restore at least two charging pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN equivalent to at least $1\% \Delta k/k$ at 200°F within the next 6 hours; restore at least two charging pumps to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.4 No additional Surveillance Requirements other than those required by Specification 4.0.5.

THIS PAGE LEFT INTENTIONALLY BLANK

THIS PAGE LEFT INTENTIONALLY BLANK

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES - SHUTDOWN

LIMITING CONDITION FOR OPERATION
=====

3.1.2.5 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. A boric acid storage system with:
 - 1. A minimum contained volume of 2,600 gallons,
 - 2. Between 6,560 and 6,990 ppm of boron, and,
 - 3. A minimum solution temperature of 63°F.

- b. The refueling water storage tank with:
 - 1. A minimum contained volume of 37,000 gallons,
 - 2. A minimum boron concentration of 2300 ppm, and
 - 3. A minimum solution temperature of 35°F.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no borated water source OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until at least one borated water source is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.5 The above required borated water source shall be demonstrated OPERABLE:

- a. For the boric acid storage system, when it is the source of borated water at least once per 7 days by:
 - 1. Verifying the boron concentration of the water,
 - 2. Verifying the water level of the tank, and
 - 3. Verifying the boric acid storage tank solution temperature when it is the source of borated water.

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION
=====

- 3.1.2.6 As a minimum, the following borated water source(s) shall be OPERABLE as required by specifications 3.1.2.1 and 3.1.2.2:
- a. A boric acid storage system with:
 - 1. A contained volume of borated water in accordance with figure 3.1.2,
 - 2. A boron concentration in accordance with figure 3.1.2, and
 - 3. A minimum solution temperature of 63°F.
 - b. The refueling water storage tank with:
 - 1. A contained volume of between 364,500 and 400,000 gallons of water,
 - 2. A boron concentration of between 2,300 and 2,500 ppm, and
 - 3. A minimum solution temperature of 35°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With the boric acid storage system inoperable and being used as one of the above required boration water systems, restore the storage system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta K/k at 200°F; restore the boric acid storage system to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the refueling water storage tank inoperable, restore the tank to OPERABLE status within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.6 Each borated water source shall be demonstrated OPERABLE:

REACTIVITY CONTROL SYSTEMS

BASES

=====

3/4.1.2 BORATION SYSTEMS

The boron injection system ensures that negative reactivity control is available during each mode of facility operation. The components required to perform this function include: 1) borated water sources, 2) charging pumps, 3) separate flow paths, 4) boric acid transfer pumps, and 5) an emergency power supply from OPERABLE diesel generators.

With the RCS average temperature $\geq 350^{\circ}\text{F}$, a minimum of two boron injection flow paths are required to ensure single functional capability in the event an assumed failure renders one of the flow paths inoperable. The boration capability of either flow path is sufficient to provide a SHUTDOWN MARGIN from expected operating conditions of 1.6% delta k/k after xenon decay and cooldown to 200°F . The maximum expected boration capability (minimum boration volume) requirement is established to conservatively bound expected operating conditions throughout core operating life. The analysis assumes that the most reactive control rod is not inserted into the core. The maximum expected boration capability requirement occurs at EOL from full power equilibrium xenon conditions and requires borated water from a boric acid tank in accordance with TS Figure 3.1-2, and additional makeup from either: (1) the second boric acid tank and/or batching, or (2) a maximum of 41,800 gallons of 2,300 ppm borated water from the refueling water storage tank. With the refueling water storage tank as the only borated water source, a maximum of 73,800 gallons of 2,300 ppm borated water is required. However, to be consistent with the ECCS requirements, the RWST is required to have a minimum contained volume of 350,000 gallons during operations in MODES 1, 2, 3 and 4.

The boric acid tanks, pumps, valves, and piping contain a boric acid solution concentration of between 3.75% and 4.0% by weight. To ensure that the boric acid remains in solution, the tank fluid temperature and the process pipe wall temperatures are monitored to ensure a temperature of 63°F , or above is maintained. The tank fluid and pipe wall temperatures are monitored in the main control room. A 5°F margin is provided to ensure the boron will not precipitate out.

Should ambient temperature decrease below 63°F , the boric acid tank heaters, in conjunction with boric acid pump recirculation, are capable of maintaining the boric acid in the tank and in the pump at or above 63°F . A small amount of boric acid in the flow path between the boric acid recirculation line and the suction line to the charging pump will precipitate out, but it will not cause flow blockage even with temperatures below 50°F .

With the RCS temperature below 350°F , one injection system is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE ALTERATIONS and positive reactivity change in the event the single injection system becomes inoperable.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 151
License No. DPR-75


1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated November 18, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.151, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: June 12, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 151

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages

- 3/4 1-7
- 3/4 1-8
- 3/4 1-9
- 3/4 1-10
- 3/4 1-12
- B 3/4 1-3

Insert Pages

- 3/4 1-7
- 3/4 1-8
- 3/4 1-9
- 3/4 1-10
- 3/4 1-12
- B 3/4 1-3

REACTIVITY CONTROL SYSTEMS

3/4.1.2 BORATION SYSTEMS

FLOW PATHS - SHUTDOWN

LIMITING CONDITION FOR OPERATION

=====

3.1.2.1 As a minimum, one of the following boron injection flow paths shall be OPERABLE:

- a. A flow path from the boric acid tanks via a boric acid transfer pump and a charging pump to the Reactor Coolant System if the boric acid storage system is OPERABLE, per Specification 3.1.2.6a while in MODE 4, or per Specification 3.1.2.5a while in MODE 5 or 6, or
- b. A flow path from the refueling water storage tank via a charging pump to the Reactor Coolant System if the refueling water storage tank is OPERABLE per Specification 3.1.2.6b while in MODE 4, or per Specification 3.1.2.5b while in MODE 5 or 6.

APPLICABILITY: MODES 4, 5 and 6.

ACTION:

With none of the above flow paths OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until at least one injection path is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

=====

4.1.2.1 At least one of the above required flow paths shall be demonstrated OPERABLE:

- a. When the boric acid tank is a required water source, by verifying at least once per 7 days that:
 - (1) The flow path from the boric acid tank to the boric acid transfer pump, the boric acid transfer pump, and the recirculation path from the boric acid transfer pump to the boric acid tank is $\geq 63^{\circ}\text{F}$, and
 - (2) The flow path between the boric acid transfer pump recirculation line to the charging pump suction line is $\geq 50^{\circ}\text{F}$,
- b. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

REACTIVITY CONTROL SYSTEMS

FLOW PATHS - OPERATING

LIMITING CONDITION FOR OPERATION

=====

3.1.2.2 At least two of the following three boron injection flow paths shall be OPERABLE:

- a. A flow path from the boric acid tanks via a boric acid transfer pump and a charging pump to the Reactor Coolant System.
- b. Two flow paths from the refueling water storage tank via charging pumps to the Reactor Coolant System.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With only one of the above required boron injection flow paths to the Reactor Coolant System OPERABLE, restore at least two boron injection flow paths to the Reactor Coolant System to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta k/k at 200°F within the next 6 hours; restore at least two flow paths to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.

SURVEILLANCE REQUIREMENTS

=====

4.1.2.2 Each of the above required flow paths shall be demonstrated OPERABLE:

- a. By verifying at least once per 7 days that:
 - (1) The flow path from the boric acid tank to the boric acid transfer pump and from the recirculation line back to the boric acid tank is $\geq 63^{\circ}\text{F}$, and
 - (2) The flow path between the boric acid tank recirculation line to the charging pump suction line is $\geq 50^{\circ}\text{F}$,
- b. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
- c. At least once per 18 months during shutdown by verifying that each automatic valve in the flow path actuates to its correct position on a safety injection test signal.
- d. At least once per 18 months by verifying that the flow path required by Specification 3.1.2.2.a delivers at least 33 gpm to the Reactor Coolant System.

REACTIVITY CONTROL SYSTEMS

CHARGING PUMP - SHUTDOWN

LIMITING CONDITION FOR OPERATION

=====

3.1.2.3 At least one charging pump in the boron injection flow path required by Specification 3.1.2.1 shall be OPERABLE.#

APPLICABILITY: MODES 4, 5 and 6.

ACTION:

With no charging pump OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until one charging pump is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

=====

4.1.2.3 No additional Surveillance Requirements other than those required by Specification 4.0.5.

A maximum of one centrifugal charging pump shall be OPERABLE while in MODE 4 when the temperature of one or more of the RCS cold legs is less than or equal to 312°F, MODE 5, or MODE 6 when the head is on the reactor vessel.

REACTIVITY CONTROL SYSTEMS

CHARGING PUMPS - OPERATING

LIMITING CONDITION FOR OPERATION
=====

3.1.2.4 At least two charging pumps shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With only one charging pump OPERABLE, restore at least two charging pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta k/k at 200°F within the next 6 hours; restore at least two charging pumps to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.4 No additional Surveillance Requirements other than those required by Specification 4.0.5.

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION
=====

3.1.2.6 As a minimum, the following borated water source(s) shall be OPERABLE as required by Specifications 3.1.2.1 and 3.1.2.2:

- a. A boric acid storage system with:
 - 1. A contained volume of borated water in accordance with figure 3.1-2,
 - 2. A Boron concentration in accordance with Figure 3.1-2, and
 - 3. A minimum solution temperature of 63°F.

- b. The refueling water storage tank with:
 - 1. A contained volume of between 364,500 and 400,000 gallons of water,
 - 2. A boron concentration of between 2,300 and 2,500 ppm, and
 - 3. A minimum solution temperature of 35°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With the boric acid storage system inoperable and being used as one of the above required borated water sources, restore the storage system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta k/k at 200°F; restore the boric acid storage system to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.

- b. With the refueling water storage tank inoperable, restore the tank to OPERABLE status within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS
=====

4.1.2.6 Each borated water source shall be demonstrated OPERABLE:

- a. For the boric acid storage system, when it is the source of borated water at least once per 7 days by:
 - 1. Verifying the boron concentration in each water source.
 - 2. Verifying the water level of each water source, and
 - 3. Verifying the boric acid storage system solution temperature.

- b. For the refueling water storage tank by:
 - 1. Verifying the boron concentration at least once per 7 days,
 - 2. Verifying the borated water volume at least once per 7 days, and
 - 3. Verifying the solution temperature at least once per 24 hour when the outside air temperature is less than 35°F.

REACTIVITY CONTROL SYSTEMS

BASES

3/4.1.2 BORATION SYSTEMS

The boron injection system ensures that negative reactivity control is available during each mode of facility operation. The components required to perform this function include: 1) borated water sources, 2) charging pumps, 3) separate flow paths, 4) boric acid transfer pumps, and 5) an emergency power supply from OPERABLE diesel generators.

With the RCS average temperature $\geq 350^{\circ}\text{F}$, a minimum of two boron injection flow paths are required to ensure single functional capability in the event an assumed failure renders one of the flow paths inoperable. The boration capability of either flow path is sufficient to provide a SHUTDOWN MARGIN from expected operating conditions of 1.6% delta k/k after xenon decay and cooldown to 200°F . The maximum expected boration capability (minimum boration volume) requirement is established to conservatively bound expected operating conditions throughout core operating life. The analysis assumes that the most reactive control rod is not inserted into the core. The maximum expected boration capability requirement occurs at EOL from full power equilibrium xenon conditions and requires borated water from a boric acid tank in accordance with TS Figure 3.1-2, and additional makeup from either: (1) the second boric acid tank and/or batching, or (2) a maximum of 41,800 gallons of 2,300 ppm borated water from the refueling water storage tank. With the refueling water storage tank as the only borated water source, a maximum of 73,800 gallons of 2,300 ppm borated water is required. However, to be consistent with the ECCS requirements, the RWST is required to have a minimum contained volume of 350,000 gallons during operations in MODES 1, 2, 3 and 4.

The boric acid tanks, pumps, valves, and piping contain a boric acid solution concentration of between 3.75% and 4% by weight. To ensure that the boric acid remains in solution, the tank fluid temperature and the process pipe wall temperatures are monitored to ensure a temperature of 63°F , or above is maintained. The tank fluid and pipe wall temperatures are monitored in the main control room. A 5°F margin is provided to ensure the boron will not precipitate out.

Should ambient temperature decrease below 63°F , the boric acid tank heaters, in conjunction with boric acid pump recirculation, are capable of maintaining the boric acid in the tank and in the pump at or about 63°F . A small amount of boric acid in the flowpath between the boric acid recirculation line and the suction line to the charging pump will precipitate out, but it will not cause flow blockage even with temperatures below 50°F .

With the RCS temperature below 350°F , one injection system is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE OPERATIONS and positive reactivity change in the event the single injection system becomes inoperable.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NOS. 169 AND 151 TO FACILITY OPERATING
LICENSE NOS. DPR-70 AND DPR-75
PUBLIC SERVICE ELECTRIC & GAS COMPANY
PHILADELPHIA ELECTRIC COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY
SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2
DOCKET NOS. 50-272 AND 50-311

1.0 INTRODUCTION

By letter dated November 18, 1994, the Public Service Electric & Gas Company (the licensee) submitted a request for changes to the Salem Nuclear Generating Station, Unit Nos. 1 and 2, Technical Specifications (TSs). The requested changes would revise the Reactivity Control System TS Limiting Conditions for Operation (LCO) for boration flow paths and charging pumps by reducing, from two to one, the number of operable charging pumps required for boron addition in Mode 4.

The licensee proposes the change to resolve a conflict between (1) the cold overpressure protection analysis that assumes a maximum of one centrifugal charging pump operable when the temperature of one or more reactor coolant system (RCS) cold legs is ≤ 312 °F, (2) TS 3.5.3, which requires a maximum of one emergency core cooling system (ECCS) be operable when the RCS temperature is less than 350 °F, and (3) TS 3.1.2.4 which requires at least two charging pumps be operable during Mode 4 with the RCS temperature between 200 °F and 350 °F. By making these changes the licensee is modifying the TSs to reflect Mode 4 as a shutdown Mode.

2.0 EVALUATION

The charging pumps and the associated flow paths are used to control the boron concentration in the RCS during normal operation and to provide high pressure injection for emergency core cooling and boron addition during accident conditions.

9506290373

The ECCS subsystem consists of one centrifugal charging pump discharging into each RCS cold leg and a residual heat removal pump discharging into the cold leg (and capable of discharging into two RCS hot legs upon manual initiation). The current Bases of the ECCS TS 3.5.3 permit only one operable ECCS subsystem when the RCS temperature is ≤ 350 °F without single failure consideration since the reactivity of the core is stable and the core cooling requirements are limited. In addition, to provide assurance that a mass pressure transient can be relieved by the operation of a single pressurizer overpressurize protection system (POPS) relief valve, a maximum of one safety injection pump or one centrifugal charging pump is allowed to be operable when one or more of the RCS cold legs is ≤ 312 °F.

TSs 3.1.2.2 and 3.1.2.4, Reactivity Control Systems Flow Path and Charging Pump, respectively, require two operable charging pumps and associated flow paths during Mode 4, (when the RCS temperature is between 200 °F and 350 °F).

To meet the requirements as stated above, the licensee would have to have one centrifugal charging pump and one positive displacement pump operable when one or more RCS cold leg is ≥ 200 °F and ≤ 312 °F. This is in direct conflict with the requirements of ECCS and POPS analyses. Therefore, to remain consistent with the analysis, the licensee is proposing to modify TSs 3.1.2.1 and 3.1.2.3 to reflect Mode 4 applicability and, conversely, remove the Mode 4 applicability from TSs 3.1.2.2 and 3.1.2.4. These changes reduce the number of required charging pumps in the Chemical and Volume Control System from two to one, when the RCS temperature is between 350 °F and 200 °F. The Bases 3/4.1.2 were also updated to reflect the reduction in the number of operable pumps required.

To clarify TS 3.1.2.1, the licensee also proposes to reference the TSs that specify the operability requirements for the Refueling Water Storage Tank and the Boric Acid Storage Tank.

The changes discussed above apply to both Units 1 and 2. To make the Unit 1 TSs consistent with Unit 2, the licensee proposed to modify the Action section of the Unit 1 TSs 3.1.2.2 to be consistent with Unit 2. They also proposed to delete the TS 3.1.2.5 and 3.1.2.6, Boric Acid Pumps - Shutdown and Operating, and renumber the existing TSs. The licensee indicated that the requirements for the Boric Acid Transfer Pumps is adequately covered in the TSs 3.1.2.1 and 3.1.2.2, which specify the boron injection flow path operability.

The licensee has provided justification for removing the requirement for having two charging pumps and their flow paths operable when the RCS temperature is between 350 °F and 200 °F. Basically, the approved ECCS and POPS analyses limit the charging pumps to one during Mode 4 operation and during Mode 4 plant reactivity is stable. Therefore, the staff finds the reduction of charging pumps and associated flow paths during Mode 4, along with the changes proposed for consistency and clarification, as described above, acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New Jersey State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (60 FR 505). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: S. Brewer.

Date: June 12, 1995