

From: Lawrence Burkhart
To: Brian Sepelak
Date: 6/12/01 3:14PM
Subject: RTDP - RAI 061201-2

The following are 2 additional questions (in addition to the previous RAI from the technical specifications branch) for our discussions on Thursday.

(1) Provide safety justification for:

Unit 2 - deletion of TS 3.3.2.1, Actions a, b.1, and b.2 contained in LCO 3.3.2.1 (item number 67)

(2) You propose to delete the Technical Specification (TS) special test exception requirements (3.10.3 (Unit 1 and 2), 3.10.4 (Unit 1 only), and 3.10.5 (Unit 1 only)) that establish reactor trip setpoints on operable intermediate and power range nuclear channels are less than or equal to 25 percent of rated thermal power. Proposed TS would permit a nominal trip setpoint of 25 percent plus a delta for a calibration band. This appears to provide a less restrictive change to the current LCO 3.10.3 (Unit 1 and 2), 3.10.4 (Unit 1), and 3.10.5 (Unit 1). Please provide safety basis for this change. (These are items 70 and 71).

Mail Envelope Properties (3B266A25.537 : 6 : 21370)

Subject: RTDP - RAI 061201-2
Creation Date: 6/12/01 3:14PM
From: Lawrence Burkhart

Created By: LJB@nrc.gov

Recipients

firstenergycorp.com
sepelakb (Brian Sepelak)

Post Office
firstenergycorp.com

Route
internet

Files	Size	Date & Time
MESSAGE	1607	06/12/01 03:14PM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard