

March 31, 1997

Mr. Leon R. Eliason
Chief Nuclear Officer & President-
Nuclear Business Unit
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES AND OPPORTUNITY FOR A HEARING, SALEM NUCLEAR
GENERATING STATION, UNITS 1 AND 2 (TAC NOS. M97827 AND M97828)

Dear Mr. Eliason:

Enclosed is a copy of the subject notice for your information. This notice relates to your application dated January 31, 1997, for Salem Nuclear Generating Station, Units 1 and 2. Your application proposes changes to Technical Specification (TS) 3.4.3, "Relief Valves," for Salem Unit 1, and TS 3.4.5, "Relief Valves," for Salem Unit 2, to ensure that the automatic capability of the power operated relief valves (PORVs) to relieve pressure is maintained when these valves are isolated by closure of the block valves. A March 14, 1997, supplement to the application proposes additional actions to eliminate single failure vulnerabilities in the PORV circuitry and upgrade the circuitry to qualify the PORVs as safety related.

This notice will be forwarded to the Office of the Federal Register for publication.

Sincerely,
/s/

Leonard N. Olshan, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/311

Enclosure: Notice

cc w/encl: See next page

NRG FILE CENTER COPY

DISTRIBUTION:

Docket File MO'Brien
PUBLIC LOlshan/DJaffe
PDI-2 Reading OGC
SVarga ACRS
JStolz JLinville, RGN-I

OFFICE	PDI-2/PM	PDI-2/LA	PDI-2/D		
NAME	LOlshan:rb	MO'Brien	JStolz		
DATE	3/13/97	3/13/97	3/13/97		

OFFICIAL RECORD COPY
DOCUMENT NAME: SACAT3.IND

9704140256 970331
PDR ADOCK 05000272
PDR

4/1
DFU1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

March 31, 1997

Mr. Leon R. Eliason
Chief Nuclear Officer & President-
Nuclear Business Unit
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES AND OPPORTUNITY FOR A HEARING, SALEM NUCLEAR
GENERATING STATION, UNITS 1 AND 2 (TAC NOS. M97827 AND M97828)

Dear Mr. Eliason:

Enclosed is a copy of the subject notice for your information. This notice relates to your application dated January 31, 1997, for Salem Nuclear Generating Station, Units 1 and 2. Your application proposes changes to Technical Specification (TS) 3.4.3, "Relief Valves," for Salem Unit 1, and TS 3.4.5, "Relief Valves," for Salem Unit 2, to ensure that the automatic capability of the power operated relief valves (PORVs) to relieve pressure is maintained when these valves are isolated by closure of the block valves. A March 14, 1997, supplement to the application proposes additional actions to eliminate single failure vulnerabilities in the PORV circuitry and upgrade the circuitry to qualify the PORVs as safety related.

This notice will be forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Olshan for".

Leonard N. Olshan, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/311

Enclosure: Notice

cc w/encl: See next page

Mr. Leon R. Eliason
Public Service Electric & Gas
Company

Salem Nuclear Generating Station,
Units 1 and 2

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street NW
Washington, DC 20005-3502

Richard Hartung
Electric Service Evaluation
Board of Regulatory Commissioners
2 Gateway Center, Tenth Floor
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. D. F. Garchow
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. Louis Storz
Sr. Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. David R. Powell, Manager
Licensing and Regulation
Nuclear Business Unit
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Charles S. Marschall, Senior
Resident Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer 0509
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection and Energy
CN 415
Trenton, NJ 08625-0415

P. M. Goetz
MGR. Joint Generation
Atlantic Energy
6801 Black Horse Pike
Egg Harbor Twp., NJ 08234-4130

Maryland Office of People's Counsel
6 St. Paul Street, 21st Floor
Suite 2102
Baltimore, Maryland 21202

Carl D. Schaefer
External Operations - Nuclear
Delmarva Power & Light Company
P.O. Box 231
Wilmington, DE 19899

Ms. R. A. Kankus
Joint Owner Affairs
PECO Energy Company
965 Chesterbrook Blvd., 63C-5
Wayne, PA 19087

Public Service Commission of Maryland
Engineering Division
Chief Engineer
6 St. Paul Centre
Baltimore, MD 21202-6806

Mr. Elbert Simpson
Senior Vice President - Nuclear Engineering
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

UNITED STATES NUCLEAR REGULATORY COMMISSION
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
SALEM NUCLEAR GENERATING STATION, UNITS 1 AND 2
DOCKET NOS. 50-272 AND 50-311
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-70 and DPR-75, issued to Public Service Electric and Gas Company (the licensee) for operation of the Salem Nuclear Generating Station, Units 1 and 2, located in Salem County, New Jersey.

The proposed amendment would revise Technical Specification (TS) 3.4.3, "Relief Valves," for Salem Unit 1, and TS 3.4.5, "Relief Valves," for Salem Unit 2, to ensure that the automatic capability of the power operated relief valves (PORVs) to relieve pressure is maintained when these valves are isolated by closure of the block valves. A March 14, 1997, supplement to the application proposes additional actions to eliminate single failure vulnerabilities in the PORV circuitry and upgrade the circuitry to qualify the PORVs as safety related.

This notice supersedes the previous notice dated February 3, 1997, published in the Federal Register on February 7, 1997 (62 FR 5861) in its entirety.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By May 5, 1997 , the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Salem Free Public Library, 112 West Broadway, Salem, New Jersey. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may

be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number NI023 and the following message addressed to John F. Stolz, Director, Project Directorate I-2: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Mark J. Wetterhahn, Esquire, Winston and Strawn, 1400 L Street, NW., Washington, DC 20005-3502, attorney for the licensee.


Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for a hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated January 31, 1997, as supplemented March 14, 1997, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Salem Free Public Library, 112 West Broadway, Salem, New Jersey.

Dated at Rockville, Maryland, this 31st day of March 1997.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, reading "John F. Stolz".

John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation