January 29, 199

Mr. Leon R. Eliason Chief Nuclear Officer & President-Nuclear Business Unit Public Service Electric & Gas Company Post Office Box 236 Hancocks Bridge, NJ 08038

SUBJECT: SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2 - ISSUANCE OF AMENDMENTS RE: POWER RANGE NEUTRON FLUX REACTOR TRIP (TAC NOS. M99834 AND M99835)

Dear Mr. Eliason:

The Commission has issued the enclosed Amendment Nos. 205 and 187 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 21, 1997.

These amendments revise the TSs to extend the Modes from 1 and 2 that the Reactor Trip System Power Range Nuclear Instrumentation - low setpoint is to be operable to Modes 1, 2, and 3, when the reactor trip breakers are in the closed position and the control drive system is capable of rod withdrawl.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely.

/s/ Patrick D. Milano, Senior Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

ł

Docket Nos. 50-272 and 50-311

Enclosures: 1. Amendment No. 205 to License No. DPR-70 2. Amendment No. 187 to License No. DPR-75 3. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION DOCKEL File PUBLIC	BBoger JStolz PMilano	PDI-2 r/f JLinville, RGN-I TClark	TCollins OGC GHill (4)	WBeckner ACRS	DF01
---------------------------------------	-----------------------------	---	------------------------------	------------------	------

OFFICE	PDI-36PM	PDI-2/LA	SRXB/C_/	OGC CONS	(PD)2/D
NAME	PMilano:cw	TCIAN	TCollins	RBachmann	JSTOIZ
DATE	1/8/98	1 11.3198	1112198	1114198	1128198
OFFICIAL	RECORD COPY		IN S.D.		

DOCUMENT NAME: SA99834.AMD

AN

9802240297 980129 ADOCK 05000272 PDR PDR



WASHINGTON, D.C. 20555-0001

January 29, 1998

Mr. Leon R. Eliason Chief Nuclear Officer & President-Nuclear Business Unit Public Service Electric & Gas Company Post Office Box 236 Hancocks Bridge, NJ 08038

SUBJECT: SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2 - ISSUANCE OF AMENDMENTS RE: POWER RANGE NEUTRON FLUX REACTOR TRIP (TAC NOS. M99834 AND M99835)

Dear Mr. Eliason:

-

The Commission has issued the enclosed Amendment Nos. 205 and 187 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 21, 1997.

These amendments revise the TSs to extend the Modes from 1 and 2 that the Reactor Trip System Power Range Nuclear Instrumentation - low setpoint is to be operable to Modes 1, 2, and 3, when the reactor trip breakers are in the closed position and the control drive system is capable of rod withdrawl.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely.

Patrick D. Milano, Senior Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-272 and 50-311

Enclosures: 1. Amendment No. 205 2.

Amendment No. 187 Safety Evaluation 3.

to License No. DPR-70 to License No. DPR-75

cc w/encls: See next page

Mr. Leon R. Eliason Public Service Electric & Gas Company

cc:

Mr. Jeffrie J. Keenan, Esquire Nuclear Business Unit - N21 P.O. Box 236 Hancocks Bridge, NJ 08038

General Manager - Salem Operations Salem Nuclear Generating Station P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. Louis Storz Sr. Vice President - Nuclear Operations Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038

Senior Resident Inspector Salem Nuclear Generating Station U.S. Nuclear Regulatory Commission Drawer 0509 Hancocks Bridge, NJ 08038

Dr. Jill Lipoti, Asst. Director Radiation Protection Programs NJ Department of Environmental Protection and Energy CN 415 Trenton, NJ 08625-0415

Maryland Office of People's Counsel 6 St. Paul Street, 21st Floor Suite 2102 Baltimore. MD 21202

Ms. R. A. Kankus Joint Owner Affairs PECO Energy Company 965 Chesterbrook Blvd., 63C-5 Wayne, PA 19087

Mr. Elbert Simpson Senior Vice President-Nuclear Engineering Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038 Salem Nuclear Generating Station, Units 1 and 2

Richard Hartung Electric Service Evaluation Board of Regulatory Commissioners 2 Gateway Center, Tenth Floor Newark, NJ 07102

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancocks Bridge, NJ 08038

Manager-Licensing and Regulation Nuclear Busienss Unit - N21 P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. David Wersan Assistant Consumer Advocate Office of Consumer Advocate 1425 Strawberry Square Harrisburg, PA 17120

Manager - Joint Generation Atlantic Energy 6801 Black Horse Pike Egg Harbor Twp., NJ 08234-4130

Carl D. Schaefer External Operations - Nuclear Delmarva Power & Light Company P.O. Box 231 Wilmington, DE 19899

Public Service Commission of Maryland Engineering Division Chief Engineer 6 St. Paul Centre Baltimore, MD 21202-6806



WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 205 License No. DPR-70

- 1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated October 21, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:

9802240300 980129 PDR ADOCK 05000272 PDR (2) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No 20^{05} , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

John/F. Stolz, Director Project Directorate 1-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: January 29, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 205 FACILITY OPERATING LICENSE NO. DPR-70 DOCKET NO. 50-272

Revise Appendix A as follows:

<u>Remove Pages</u>	<u>Insert Pages</u>
3/4 3-2	3/4 3-2
3/4 3-11	3/4 3-11

FUNCI	TIONAL UNIT	TOTAL NUMBER OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
1.	Manual Reactor Trip	2	1	2	1,2 and *	12
2.	Power Range, Neutron Flux	4	2	3	1,2, and 3*	2
3.	Power Range, Neutron Flux High Positive Rate	4	2	3	1,2	2
4.	Power Range, Neutron Flux High Negative Rate	4	2	3	1,2	2
5.	Intermediate Range, Neutron Flu	ux 2	1	2	1,2 and *	3
6	Source Bange, Neutron Flux					
0.	A. Startup	2	1	2	2## and *	4
	B. Shutdown	2	0	1	3,4, and 5	5
7.	Overtemperature Δ T	4	2	3	1,2	6
8.	Overpower ΔT	4	2	3	1,2	6
9.	Pressurizer Pressure-Low	4	2	3	1,2	6
10.	Pressurizer PressureHigh	4	2	3	1,2	6

TABLE 3.3-1 REACTOR TRIP SYSTEM INSTRUMENTATION

.

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUN	CTIONAL UNIT	CHANNEL CHECK	CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
1.	Manual Reactor Trip Switch	N.A.	N.A.	R ⁽⁹⁾	1, 2, and $*$
2.	Power Range, Neutron Flux	S	$D^{(2)}$, $M^{(3)}$ and $Q^{(6)}$	Q	1, 2, and 3*
3.	Power Range, Neutron Flux, High Positive Rate	N.A.	R ⁽⁶⁾	Q	1, 2
4.	Power Range, Neutron Flux, High Negative Rate	N.A.	R ⁽⁶⁾	Q	1, 2
5.	Intermediate Range, Neutron Flux	S	R ⁽⁶⁾	S/U ⁽¹⁾	1, 2 and $*$
6.	Source Range, Neutron Flux	S ⁽⁷⁾	R ⁽⁶⁾	Q and $S/U^{(1)}$	2, 3, 4, 5 and *
7.	Overtemperature ΔT	S	R	Q	1, 2
8.	Overpower ΔT	S	R	Q	1, 2
9.	Pressurizer PressureLow	S	R	Q	1, 2
10.	Pressurizer PressureHigh	S	R	Q	1, 2
11.	Pressurizer Water LevelHigh	S	R	Q	1, 2
12.	Loss of Flow - Single Loop	S	R	Q	1



WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION. UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 187 License No. DPR-75

- 1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated October 21, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.187, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

John F. Stolz, Director Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: January 29, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 187 FACILITY OPERATING LICENSE NO. DPR-75 DOCKET NO. 50-311

Revise Appendix A as follows:

<u>Remove Pages</u>	<u>Insert Pages</u>
3/4 3-2	3/4 3-2
3/4 3-11	3/4 3-11

FUNC'	FIONAL UNIT	TOTAL NUMBER OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
1.	Manual Reactor Trip	2	1	2	1,2 and *	12
2.	Power Range, Neutron Flux	4	2	3	1,2 and 3*	2
3.	Power Range, Neutron Flux High Positive Rate	4	2	3	1,2	2
4.	Power Range, Neutron Flux, High Negative Rate	4	2	3	1,2	2
5.	Intermediate Range, Neutron F	lux 2	1	2	1,2 and *	3
6.	Source Range, Neutron Flux A. Startup B. Shutdown	2 2	1 0	2 1	2##, and * 3,4 and 5	4 5
7.	Overtemperature ΔT	4	2	3	1,2	6
8.	Overpower Δ T	4	2	3	1,2	6
9.	Pressurizer Pressure-Low	4	2	3	1,2	6
10.	Pressurizer PressureHigh	4	2	3	1,2	6

TABLE 3.3-1 REACTOR TRIP SYSTEM INSTRUMENTATION

SALEM - UNIT 2

Amendment No.113, 187

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUN	CTIONAL UNIT	CHANNEL _CHECK	CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED	
1.	Manual Reactor Trip Switch	N.A.	N.A.	R ⁽⁹⁾	1, 2, and *	
2.	Power Range, Neutron Flux	S	$D^{(2)}$, $M^{(3)}$ and $Q^{(6)}$	Q	1, 2, and 3*	e.
3.	Power Range, Neutron Flux, High Positive Rate	N.A.	R ⁽⁶⁾	Q	1, 2	Ś
4.	Power Range, Neutron Flux, High Negative Rate	N.A.	R ⁽⁶⁾	Q	1, 2	
5.	Intermediate Range, Neutron Flux	S	R ^(b)	S/U ⁽¹⁾	1, 2 and *	
6.	Source Range, Neutron Flux	s ⁽⁷⁾	R ⁽⁶⁾	Q and $S/U^{(1)}$	2, 3, 4, 5 and	*
7.	Overtemperature ΔT	S	R	Q	1, 2	
8.	Overpower AT	S	R	Q	1, 2	
9.	Pressurizer PressureLow	S	R	Q	1, 2	
10.	Pressurizer PressureHigh	S	R	Q	1, 2	(
11.	Pressurizer Water LevelHigh	S	R	Q	1, 2	
12.	Loss of Flow - Single Loop	S	R	Q	1	



WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 205 AND 187 TO FACILITY OPERATING

LICENSE NOS. DPR-70 AND DPR-75

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2

DOCKET NOS. 50-272 AND 50-311

1.0 INTRODUCTION

By letter dated October 21, 1997, the Public Service Electric & Gas Company (the licensee) submitted a request for changes to the Salem Nuclear Generating Station, Unit Nos. 1 and 2, Technical Specifications (TSs). The requested changes would revise the TSs to require the Reactor Trip System Power Range Nuclear Instrumentation (Low Setpoint) to be operable in Mode 3 (hot shutdown), when the reactor trip breakers are in the closed position and the rod control drive system is capable of rod withdrawl. Currently, the Reactor Trip System Power Range Nuclear Instrumentation is required to be operable in Modes 1 and 2 (power operation and startup, respectively).

2.0 EVALUATION

The NRC staff issued Generic Letter (GL) 93-04, "Rod Control System Failure and Withdrawl of Rod Control Cluster Assemblies," on June 21, 1993, addressing a single failure vulnerability in the Westinghouse solid state rod control system that could cause an inadvertent withdrawl of control rods in a sequence resulting in a power distribution not considered in the design basis analysis. This GL was issued as the result of a Salem Unit 2 rod control system failure that caused a signal rod to withdraw although the plant operator had applied a rod insertion command signal. During its evaluation of this incident and the GL, the licensee conducted a review of the relevant accident analyses. procedures and TSs. The licensee found that, should a control rod withdrawl occur during Mode 3 (hot shutdown), there is a possibility for an inadvertent criticality to occur. On the basis of this possibility, the licensee has revised its startup procedures to require the Power Range Nuclear Instrumentation - low setpoint trip to be operable during Mode 3 if the reactor trip breakers are closed and the control rod drive system is capable of rod withdrawl. The proposed amendments would incorporate this requirement into the TSs.

7802240303 780127 PDR ADDCK 05000272 PDR PDR TS Table 1-1 defines Mode 3 as $K_{eff} \leq 0.95$, reactor power = 0, and reactor coolant system temperature ≥ 350 °F. The licensee's proposed change would now provide that the Power Range Nuclear Instrumentation reactor trip is operable in Mode 3 during hot control rod testing and rod withdrawl for the approach to criticality (entering Mode 2). This instrumentation does not require TS operability during lower Modes because the reactor coolant system boron concentration is maintained at a level that produces a $K_{eff} \leq 0.95$ for any rod configuration.

Section 15.2.1, "Uncontrolled Rod Cluster Assembly Bank Withdrawl from a Subcritical Condition," of the Salem Updated Final Safety Analysis Report (UFSAR) discusses the results of the transient analysis for this fault condition resulting in a power excursion. The maximum reactivity insertion rate analyzed was that occurring with the simultaneous withdrawl of the combination of the two control banks having the maximum combined worth at maximum speed. The power supplied to the banks prevents more than two banks being simultaneously withdrawn. This reactivity insertion rate is also greater than the maximum insertion rate associated with the withdrawl of a part length rod cluster control assembly.

Should this fault occur, the transient analysis relied on the following automatic features to terminate the transient:

- (1) Source Range High Neutron Flux Trip
- (2) Intermediate Range High Neutron Flux Trip
- (3) Power Range High Neutron Flux Trip (Low Setting)
- (4) Power Range High Neutron Flux Trip (High Setting)

The Power Range High Neutron Flux Trip consists of two independent trip settings, High Setting and Low Setting. While the High Setting provides protection during power operation, the Low Setting is primarily designed for protection during startup. The Low Setting is automatically inserted whenever three of the four Power Range Nuclear Instrumentation (PRNI) channels sense the power level is below 10 percent (i.e., the P-10 interlock). The PRNI circuitry will allow the operators to manually bypass the Low Setting when two of the four PRNI channels read above 10 percent reactor power. The High Setting remains active at all power levels when the PRNI is operable. The bounding analysis described in UFSAR Section 15.2.1 indicates that the Power Range High Neutron Flux Trip (Low Setting) will prevent the fuel limits from being exceeded during the above transient.

Since the licensee's proposed change incorporates the requirement into the TSs that are in the plant procedures and increases Mode operability requirements, the NRC staff finds that the proposed changes are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New Jersey State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (62 FR 68146). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: P. Milano

Date: January 29, 1998