

May 14, 1990

Docket No. 50-311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: REPLACEMENT PAGE FOR AMENDMENT 84 (TAC NO. 75122)

RE: SALEM GENERATING STATION, UNIT NO. 2

Amendment 84 was issued on January 17, 1990, but, because modifications have to be made to the plant, is not to be implemented until prior to startup from the fifth refueling outage, that began in March 1990. On April 20, 1990, Amendment 90 was issued for immediate implementation. One page (3/4 5-6a) in Amendment 84 is also in Amendment 90. The changes approved in Amendment 84 were intentionally left out of Amendment 90 because the plant modifications required before implementing Amendment 84 had not been completed.

Enclosed is a replacement for page 3/4 5-6a that incorporates the changes approved in Amendment 90. This page should be inserted in Amendment 84 and implemented before startup from the fifth refueling outage.

Sincerely,

ORIGINAL SIGNED BY:

James C. Stone, Project Manager
Project Directorate 1-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Replacement page 3/4 5-6a

cc w/enclosure:
See next page

DISTRIBUTION w/enclosure:

Docket File MO'Brien (2)
NRC PDR OGC
Local PDR DHagan
PDI-2 Reading EJordan
GPA/PA JStone
Rita Jacques, ARM/LFMB

Wanda Jones
JCalvo
Tech Branch
ACRS (10)
MThandani

JDyer
JLinville
BBoger
WButler
GHill (4)

[75122]

PDI-2/PA
MO'Brien
5/14/90

Jm
PDI-2/PM
JStone:mj
5/11/90

PDI-2/D
WButler
5/14/90 *WB.*

DF01
11



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 14, 1990

Docket No. 50-311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: REPLACEMENT PAGE FOR AMENDMENT 84 (TAC NO. 75122)

RE: SALEM GENERATING STATION, UNIT NO. 2

Amendment 84 was issued on January 17, 1990, but, because modifications have to be made to the plant, is not to be implemented until prior to startup from the fifth refueling outage, that began in March 1990. On April 20, 1990, Amendment 90 was issued for immediate implementation. One page (3/4 5-6a) in Amendment 84 is also in Amendment 90. The changes approved in Amendment 84 were intentionally left out of Amendment 90 because the plant modifications required before implementing Amendment 84 had not been completed.

Enclosed is a replacement for page 3/4 5-6a that incorporates the changes approved in Amendment 90. This page should be inserted in Amendment 84 and implemented before startup from the fifth refueling outage.

Sincerely,

A handwritten signature in cursive script that reads "James C. Stone".

James C. Stone, Project Manager
Project Directorate 1-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Replacement page 3/4 5-6a

cc w/enclosure:
See next page

Mr. Steven E. Miltenberger
Public Service Electric & Gas Company

Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire
Conner and Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, NW
Washington, DC 20006

Richard B. McGlynn, Commission
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. L. K. Miller
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. S. LaBruna
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Bruce A. Preston, Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Thomas P. Johnson, Senior Resident
Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection
CN 415
Trenton, NJ 08625

Mr. Scott B. Ungerer
MGR. - Joint Generation Projects
Atlantic Electric Company
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, NJ 08232

Maryland People's Counsel
American Building, 9th Floor
231 East Baltimore Street
Baltimore, Maryland 21202

Mr. Jack Urban
General Manager, Fuels Department
Delmarva Power & Light Company
800 King Street
Wilmington, DE 19899

Mr. J. T. Robb, Director
Joint Owners Affairs
Philadelphia Electric Company
955 Chesterbrook Blvd., 51A-13
Wayne, PA 19087

Public Service Commission of Maryland
Engineering Division
ATTN: Chief Engineer
231 E. Baltimore Street
Baltimore, MD 21202-3486

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

1. The automatic interlock function of the RHR System shall be verified within the seven (7) days prior to placing the RHR System in service for cooling of the Reactor Coolant System. This shall be done by verifying with a test signal corresponding to a reactor coolant pressure of 375 psig or greater, that the 2RH1 and 2RH2 valves cannot be opened.

* (Footnote from page 3/4 5-6)

Flow balance testing pursuant to Specification 4.5.2.h shall be performed the first time the unit is in COLD SHUTDOWN after December 15, 1981.

** (Footnote to page 3/4 5-6 item h.2)

The maximum limit (i.e. ≤ 550 gpm) on ECCS Centrifugal Charging Pump Flow is waived on a one-time basis for the period commencing January 4, 1990 and ending upon initial entry into Mode 5 during the Unit 2 5th Refueling Outage.

To be implemented before startup from the fifth refueling outage.

SALEM - UNIT 2

3/4 5-6a

Amendment No. 84

CORRECTION LETTER DATED MAY 14, 1990

9005220182 900514
PDR ADOCK 05000311
P PDC