November 3, 1988

Docket No.: 50-311

Mr. Steven E. Miltenberger Vice President and Chief Nuclear Officer Public Service Electric and Gas Company Post Office Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: CONFIRMATION OF CHANGE TO TECHNICAL SPECIFICATIONS (TAC 69804)

RF: SALEM GENERATING STATION, UNIT 2

This confirms our telephone authorization given on November 3, 1988, for the change to the Technical Specifications for Salem Generating Station, Unit 2 as requested on an emergency basis in your letter dated October 19, 1988 and supplemented with additional information by letter dated October 26, 1988. Facility Operating License DPR-75 is amended on November 3, 1988. The revised Technical Specification pages 3/4 2-9, 3/4 2-11 and B 3/4 2-5 are enclosed.

The formal license amendment, our completed safety evaluation, and the Federal Register Notice of this change to the Technical Specifications for Salem Generating Station, Unit 2 are being processed and copies of these documents will be sent to you in the near future.

Sincerely,

/s/

Bruce A. Boger, Assistant Director for Region I Reactors Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

Enclosures: Technical Specification Pages

PNU

ADOCK 05000311

8811070192 88110

cc w/enclosures: See next page

PDR

DISTRIBUTION Docket File WButler/MO'Brid EJordan EButcher Brent Clayton	NRC PDR/L en JStone/M BGrimes ACRS (10 RGAllo	PDR PDI- Fhadani OGC TBan) CMil HBal	-2 Reading rnhart (4) les,GPA/PA lukjian	SVarga/BBoger DHagan Wanda Jones RDiggs,ARM/LFMB
* Previously Co	oncurred	IR	AAAX	
PDI-2/LA* MO'Brien 11/02/88	PDI-2/PM* JStone:mr 11/02/88	PDI-2/D WButler \\/3/88	Вводет И /3 /88	



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

November 3, 1988

Docket No.: 50-311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric and Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: CONFIRMATION OF CHANGE TO TECHNICAL SPECIFICATIONS (TAC 69804)

RE: SALEM GENERATING STATION, UNIT 2

This confirms our telephone authorization given on November 3, 1988, for the change to the Technical Specifications for Salem Generating Station, Unit 2 as requested on an emergency basis in your letter dated October 19, 1988 and supplemented with additional information by letter dated October 26, 1988. Facility Operating License DPR-75 is amended on November 3, 1988. The revised Technical Specification pages 3/4 2-9, 3/4 2-11 and B 3/4 2-5 are enclosed.

The formal license amendment, our completed safety evaluation, and the <u>Federal</u> <u>Register</u> Notice of this change to the Technical Specifications for Salem Generating Station, Unit 2 are being processed and copies of these documents will be sent to you in the near future.

Sincerely,

ucell. Dasc.

Bruce A. Boger, Assistant Director for Region I Reactors Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

Enclosures: Technical Specification Pages

cc w/enclosures: See next page Mr. Steven E. Miltenberger Public Service Electric & Gas Company

cc:

Ì.,

Mark J. Wetterhahn, Esquire Conner and Wetterhahn Suite 1050 1747 Pennsylvania Avenue, NW Washington, PC 20006

Richard Fryling, Jr., Esquire Law Department - Tower 5E 80 Park Place Newark, NJ 07101

Mr. L. K. Miller General Manager - Salem Operations Salem Generating Station P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. S. LaBruna Vice President - Nuclear Operations Nuclear Department P.O. Box 236 Hancocks Bridge, New Jersey 08038

Robert Traee, Mayor Lower Alloways Creek Township Municipal Hall Hancocks Bridge, NJ 08038

Richard W. Borchardt, Resident Inspector Salem Nuclear Generating Station U.S. Nuclear Regulatory Commission Drawer I Hancocks Bridge, NJ 08038

Richard F. Engel Deputy Attorney General Department of Law and Public Safety CN-112 State House Annex Trenton, NJ 08625

Mr. David M. Scott, Chief Bureau of Nuclear Engineering Department of Environmental Protection State of New Jersey CN 411 Trenton, NJ 08625 Salem Nuclear Generating Station

Richard B. McGlynn, Commission Department of Public Utilities State of New Jersev 101 Commerce Street Newark, NJ 07102

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancocks Bridge, NJ 08038

Mr. Bruce A. Preston, Manager Licensing and Regulation Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. David Wersan Assistant Consumer Advocate Office of Consumer Advocate 1425 Strawberry Square Harrisburg, PA 17120

Morgan J. Morris, III General Manager - Operating License Atlantic Electric P.O. Box 1500 1199 Black Horse Pike Pleasantville, NJ 08232

Delmarva Power & Light Company c/o Jack Urban General Manager, Fuel Supply 800 King Street P.O. Box 231 Wilmington, DE 19899

POWER DISTRIBUT N LIMITS

3/4.2.3 RCS FLOW RATE AND R

LIMITING CONDITION FOR OPERATION

3.2.3 The combination of indicated Reactor Coolant System (RCS) total flow rate and R_1 , R_2 shall be maintained within the region of allowable operation shown on Figure 3.2-3 for 4 loop operation.

where:

a.	R ₁	$= \frac{F_{\Delta H}^{N}}{1 + (0 + 1) + (0 + 2) + (1 + 0) + (1 $
		$1.49 [1.0 \pm 0.3 (1.0 - P)]$
ь.	R ₂	$= \frac{R_1}{(1 - PRP(PII))}$
c.	P	= THERMAL POWER , and
		RATED THERMAL POWER

- d. $F_{\Delta H}^{N}$ = Measured values of $F_{\Delta H}^{N}$ obtained by using the movable incore detectors to obtain a power distribution map. The measured values of $F_{\Delta H}^{N}$ shall be used to calculate R since Figure 3.2-3 includes penalties for undetected feedwater venturi fouling of 0.1% and for measurement uncertainties of $N_{\Delta H}^{2}$.2% for flow and 4% for incore measurement of $F_{\Delta H}^{N}$.
- e. RBP(BU) = Rod Bow Penalty as a function of region average burnup as shown in Figure 3.2-4, where a region is defined as those assemblies with the same loading date (reloads) or enrichment (first core).

APPLICABILITY: MODE 1

ACTION:

With the combination of RCS total flow rate and R_1 , R_2 outside the region of acceptable operation shown on Figure 3.2-3:

- a. Within 2 hours:
 - 1. Either restore the combination of RCS total flow rate and R_1 , R_2 to within the above limits, or
 - 2. Reduce THERMAL POWER to less than 50% of RATED THERMAL POWER and reduce the Power Range Neutron Flux - High trip setpoint to less than or equal to 55% of RATED THERMAL POWER within the next 4 hours.



 $R1 = F_{\Delta H}^{N} / 1.49[1.0+0.3(1.0 - P)]$ R2 = R1 /[1 - R9P(8U)]



SALEM - UNIT 2

3/4 2-11

Amendment No. Effective Date: November 3, 1988

POWER DISTRIBUT

BASES

3/4.2.2 and 3/4.2.3 HEAT FLUX HOT CHANNEL FACTOR F (Z), RCS FLOW RATE AND NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR (Continued)

event. The penalties applied to $F_{\Delta H}^{N}$ to account for Rod Bow (Figure 3.2-4) as a function of burnup are consistent with those described in Mr. John F. Stolz's (NRC) letter to T. M. Anderson (Westinghouse) dated April 5, 1979 and W 8691 Rev. 1 (partial rod bow test data).

When an F_0 measurement is taken, an allowance for both experimental error and manufacturing tolerance must be made. An allowance of 5% is appropriate for a full core map taken with the incore detector flux mapping system and a 3% allowance is appropriate for manufacturing tolerance.

When RCS flow rate and $F_{\Delta H}^{N}$ are measured, no additional allowances are necessary prior to comparison with the limits of Figure 3.2-3. Measurement errors of 2.2% for Reactor Coolant System total flow rate, 0.1% for feedwater venturi fouling, and 4% for $F_{\Delta H}$ have been allowed for in the determination of the design DNBR value.

The measurement error for Reactor Coolant System total flow rate is based upon performing a precision heat balance and using the result to calibrate the RCS flow rate indicators. Potential fouling of the feedwater venturi which might not be detected could bias the result from the precision heat balance in a nonconservative manner. Therefore, a penalty of 0.1% for undetected fouling of the feedwater venturi is included in Figure 3.2-3. Any fouling which might bias the RCS flow rate measurement greater than 0.1% can be detected by monitoring and trending various plant performance parameters. If detected, action shall be taken before performing subsequent precision heat balance measurements, i.e., either the effect of the fouling shall be quantified and compensated for in the RCS flow rate measurement or the venturi shall be cleaned to eliminate the fouling.

The 12 hour period surveillance of indicated RCS flow is sufficient to detect only flow degradation which could lead to operation outside the acceptable region of operation shown in Figure 3.2-3.

The radial peaking factor F (Z) is measured periodically to provide assurance that the hot channel factor FQ(Z), remains within its limit. The F limit for RATED THERMAL POWER (Fru), as provided in the Radial Peaking Factor Limit Report per specification 6.9.1.10, was determined from expected power control maneuvers over the full range of burnup conditions in the core.

3/4.2.4 QUADRANT POWER TILT RATIO

The quadrant power tilt ratio limit assures that the radial power distribution satisfies the design values used in the power capability analysis. Radial power distribution measurements are made during startup testing and periodically during power operation.

B 3/4 2-5

SALEM - UNIT 2