

Mr. Leon R. Eliason
Chief Nuclear Officer & President-
Nuclear Business Unit
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, NJ 08038

September 1995

SUBJECT: SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2 (TAC NOS. M90555 AND M90556)

Dear Mr. Eliason:

The Commission has issued the enclosed Amendment Nos. 176 and 157 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated September 20, 1994.

These amendments adopt the Westinghouse Standard Technical Specifications Channel Functional Test surveillance frequency for the Manual Reactor Trip Switches and for the Reactor Trip Breakers (RTB) and relocate RTB maintenance requirements from the Technical Specifications to the Updated Final Safety Analysis Report.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Leonard N. Olshan, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/50-311

Enclosures:

1. Amendment No. 176 to License No. DPR-70
2. Amendment No. 157 to License No. DPR-75
3. Safety Evaluation

cc w/encls:

See next page

DISTRIBUTION:

Docket File MO'Brien
PUBLIC LOlshan
PDI-2 Reading OGC
SVarga GHill(4)
JStolz

CGrimes
IAhmed
ACRS(4)
JWhite, RGN-I

OFC :PDI-2/LA :PDI-2/PM :OGC :PDI-2/D : OGC :

NAME :MO'Brien :LOlshan:mw: R. Baumann :JStolz : OGC :

DATE : 8/10/95 : 8/11/95 : 8/17/95 : 8/11/95 : 8/29/95 :

OFFICIAL RECORD COPY

FILENAME: A:\SA90555.AMD

9509210353 950918
PDR ADOCK 05000272
PDR

010052

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 18, 1995

Mr. Leon R. Eliason
Chief Nuclear Officer & President-
Nuclear Business Unit
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2 (TAC NOS. M90555
AND M90556)

Dear Mr. Eliason:

The Commission has issued the enclosed Amendment Nos. 176 and 157 to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2. These amendments consist of changes to the Technical Specifications (TSs) in response to your application dated September 20, 1994.

These amendments adopt the Westinghouse Standard Technical Specifications Channel Functional Test surveillance frequency for the Manual Reactor Trip Switches and for the Reactor Trip Breakers (RTB) and relocate RTB maintenance requirements from the Technical Specifications to the Updated Final Safety Analysis Report.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "Leonard N. Olshan", is written over the typed name.

Leonard N. Olshan, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-272/50-311

Enclosures:

1. Amendment No. 176 to
License No. DPR-70
2. Amendment No. 157 to
License No. DPR-75
3. Safety Evaluation

cc w/encls:
See next page

Mr. Leon R. Eliason
Public Service Electric & Gas
Company

Salem Nuclear Generating Station,
Units 1 and 2

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street NW
Washington, DC 20005-3502

Richard Hartung
Electric Service Evaluation
Board of Regulatory Commissioners
2 Gateway Center, Tenth Floor
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. John Summers
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. J. Hagan
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Frank X. Thomson, Jr., Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Charles S. Marschall, Senior
Resident Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer 0509
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection and Energy
CN 415
Trenton, NJ 08625-0415

Ms. P. J. Curham
MGR. Joint Generation Department
Atlantic Electric Company
P.O. Box 1500
6801 Black Horse Pike
Pleasantville, NJ 08232

Maryland Office of People's Counsel
6 St. Paul Street, 21st Floor
Suite 2102
Baltimore, Maryland 21202

Carl D. Schaefer
External Operations - Nuclear
Delmarva Power & Light Company
P.O. Box 231
Wilmington, DE 19899

Ms. R. A. Kankus
Joint Owner Affairs
PECO Energy Company
965 Chesterbrook Blvd., 63C-5
Wayne, PA 19087

Public Service Commission of Maryland
Engineering Division
Chief Engineer
6 St. Paul Centre
Baltimore, MD 21202-6806

Mr. S. LaBruna
Vice President - Nuclear Engineering
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 176
License No. DPR-70

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated September 20, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:


9509210356 950918
PDR ADDCK 05000272
P PDR

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 176, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 18, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 176

FACILITY OPERATING LICENSE NO. DPR-70

DOCKET NO. 50-272

Revise Appendix A as follows:

Remove Pages

3/4 3-11

3/4 3-12

3/4 3-13

Insert Pages

3/4 3-11

3/4 3-12

3/4 3-13

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. Manual Reactor Trip Switch	N.A.	N.A.	R ⁽⁹⁾	1, 2, and *
2. Power Range, Neutron Flux	S	D ⁽²⁾ , M ⁽³⁾ and Q ⁽⁶⁾	Q	1, 2
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R ⁽⁶⁾	Q	1, 2
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R ⁽⁶⁾	Q	1, 2
5. Intermediate Range, Neutron Flux	S	R ⁽⁶⁾	S/U ⁽¹⁾	1, 2 and *
6. Source Range, Neutron Flux	S ⁽⁷⁾	R ⁽⁶⁾	Q and S/U ⁽¹⁾	2, 3, 4, 5 and *
7. Overtemperature ΔT	S	R	Q	1, 2
8. Overpower ΔT	S	R	Q	1, 2
9. Pressurizer Pressure--Low	S	R	Q	1, 2
10. Pressurizer Pressure--High	S	R	Q	1, 2
11. Pressurizer Water Level--High	S	R	Q	1, 2
12. Loss of Flow - Single Loop	S	R	Q	1

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
13. Loss of Flow Two Loops	S	R	N.A.	1
14. Steam Generator Water Level--Low-Low	S	R	Q	1, 2
15. Deleted				
16. Undervoltage - Reactor Coolant Pumps	N.A.	R	Q	1
17. Underfrequency - Reactor Coolant Pumps	N.A.	R	Q	1
18. Turbine Trip				
a. Low Autostop Oil Pressure	N.A.	N.A.	S/U ⁽¹⁾	1, 2
b. Turbine Stop Valve Closure	N.A.	N.A.	S/U ⁽¹⁾	1, 2
19. Safety Injection Input from ESF	N.A.	N.A.	M ⁽⁴⁾ (5)	1, 2
20. Reactor Coolant Pump Breaker Position Trip	N.A.	N.A.	R	N.A.
21. Reactor Trip Breaker	N.A.	N.A.	M ⁽⁵⁾ (11)(13) and R ⁽¹⁴⁾	1, 2 and *
22. Automatic Trip Logic	N.A.	N.A.	M ⁽⁵⁾	1, 2 and *

TABLE 4.3-1 (Continued)

NOTATION

- * With the reactor trip system breakers closed and the control rod drive system capable of rod withdrawal.
- (1) - If not performed in previous 31 days.
- (2) - Heat balance only, above 15% of RATED THERMAL POWER.
- (3) - Compare incore to excore axial offset above 15% of RATED THERMAL POWER. Recalibrate if absolute difference \geq 3 percent.
- (4) - Manual SSPS functional input check every 18 months.
- (5) - Each train or logic channel shall be tested at least every 62 days on a STAGGERED TEST BASIS.
- (6) - Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (7) - Below P-6 (Block of Source Range Reactor Trip) setpoint.
- (8) - Deleted
- (9) - The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the Undervoltage and Shunt Trip mechanism for the Manual Reactor Trip Function.

The Test shall also verify OPERABILITY of the Bypass Breaker Trip circuits.
- (10) - DELETED
- (11) - The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the Reactor Trip Breaker Undervoltage and Shunt Trip mechanisms.
- (12) - DELETED



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 157
License No. DPR-75


1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated September 20, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 157, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 18, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 157

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages

3/4 3-11
3/4 3-12
3/4 3-13
3/4 3-13a

Insert Pages

3/4 3-11
3/4 3-12
3/4 3-13
3/4 3-13a

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. Manual Reactor Trip Switch	N.A.	N.A.	R ⁽⁹⁾	1, 2, and *
2. Power Range, Neutron Flux	S	D ⁽²⁾ , M ⁽³⁾ and Q ⁽⁶⁾	Q	1, 2
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R ⁽⁶⁾	Q	1, 2
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R ⁽⁶⁾	Q	1, 2
5. Intermediate Range, Neutron Flux	S	R ⁽⁶⁾	S/U ⁽¹⁾	1, 2 and *
6. Source Range, Neutron Flux	S ⁽⁷⁾	R ⁽⁶⁾	Q and S/U ⁽¹⁾	2, 3, 4, 5 and *
7. Overtemperature ΔT	S	R	Q	1, 2
8. Overpower ΔT	S	R	Q	1, 2
9. Pressurizer Pressure--Low	S	R	Q	1, 2
10. Pressurizer Pressure--High	S	R	Q	1, 2
11. Pressurizer Water Level--High	S	R	Q	1, 2
12. Loss of Flow - Single Loop	S	R	Q	1

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
13. Loss of Flow Two Loops	S	R	N.A.	1
14. Steam Generator Water Level--Low-Low	S	R	Q	1, 2
15. Deleted				
16. Undervoltage - Reactor Coolant Pumps	N.A.	R	Q	1
17. Underfrequency - Reactor Coolant Pumps	N.A.	R	Q	1
18. Turbine Trip				
a. Low Autostop Oil Pressure	N.A.	N.A.	S/U ⁽¹⁾	N.A.
b. Turbine Stop Valve Closure	N.A.	N.A.	S/U ⁽¹⁾	N.A.
19. Safety Injection Input from ESF	N.A.	N.A.	M ⁽⁴⁾⁽⁵⁾	1, 2
20. Reactor Coolant Pump Breaker Position Trip	N.A.	N.A.	R	N.A.
21. Reactor Trip Breaker	N.A.	N.A.	M ⁽⁵⁾⁽¹¹⁾⁽¹³⁾ and R ⁽¹⁴⁾	1, 2 and *
22. Automatic Trip Logic	N.A.	N.A.	M ⁽⁵⁾	1, 2 and *

TABLE 4.3-1 (Continued)

NOTATION

- * With the reactor trip system breakers closed and the control rod drive system capable of rod withdrawal.
- (1) - If not performed in previous 31 days.
 - (2) - Heat balance only, above 15% of RATED THERMAL POWER.
 - (3) - Compare incore to excore axial offset above 15% of RATED THERMAL POWER. Recalibrate if absolute difference \geq 3 percent.
 - (4) - Manual SSPS functional input check every 18 months.
 - (5) - Each train or logic channel shall be tested at least every 62 days on a STAGGERED TEST BASIS.
 - (6) - Neutron detectors may be excluded from CHANNEL CALIBRATION.
 - (7) - Below P-6 (Block of Source Range Reactor Trip) setpoint.
 - (8) - Deleted
 - (9) - The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the Undervoltage and Shunt Trip mechanism for the Manual Reactor Trip Function.

The Test shall also verify OPERABILITY of the Bypass Breaker Trip circuits.
 - (10) - DELETED
 - (11) - The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the Reactor Trip Breaker Undervoltage and Shunt Trip mechanisms.
 - (12) - DELETED

TABLE 4.3-1 (Continued)

NOTATION

- (13) - Verify operation of Bypass Breakers Shunt Trip function from local pushbutton while breaker is in the test position prior to placing breaker in service.
- (14) - Perform a functional test of the Bypass Breakers U.V. Attachment via the SSPS.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NOS. 176 AND 157 TO FACILITY OPERATING
LICENSE NOS. DPR-70 AND DPR-75
PUBLIC SERVICE ELECTRIC & GAS COMPANY
PHILADELPHIA ELECTRIC COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY
SALEM NUCLEAR GENERATING STATION, UNIT NOS. 1 AND 2
DOCKET NOS. 50-272 AND 50-311

1.0 INTRODUCTION

By letter dated September 20, 1994, the Public Service Electric & Gas Company (the licensee) submitted a request for changes to the Salem Nuclear Generating Station, Unit Nos. 1 and 2, Technical Specifications (TS). The requested changes would change the Channel Functional Test surveillance frequency for the Manual Reactor trip switches and Reactor Trip Breakers (RTB) and relocate the RTB maintenance requirements from the TS to the Salem Updated Final Safety Analysis Report (FSAR). In addition to the changes in the surveillance test frequency, there are several editorial and notational changes for consistency and standardization in the nomenclature.

2.0 EVALUATION

Presently the TS for both Salem Units require that channel functional testing of Manual Trip Switches be performed within 24 hours prior to each start-up. The proposed change is to perform the channel functional test only in the refueling outage. This change of test interval reduces the potential for inadvertent actuation of the plant protective system and is in accordance with the new improved Westinghouse Standard Technical Specification, NUREG-1431 and is, therefore, acceptable.

Similarly, the Salem TS require channel functional testing of reactor trip breakers within 24 hours prior to each start-up, once every month, and once every refueling outage. The proposed change deletes the requirement of testing the channel within 24 hours prior to each start-up and changes the channel monthly test requirement to at least every 62 days on a staggered test basis. These changes are also in accordance with NUREG-1431 and are, therefore, acceptable.

9509210361 950918
PDR ADOCK 05000272
P PDR

The anticipated transient without scram (ATSW) event that occurred at Salem on February 29, 1983, was primarily caused by inadequate maintenance of the RTBs. The plant TS do not normally include preventive maintenance requirements during power operation. However, in order to improve the RTB reliability and availability, and to minimize the possibility of ATWS recurrence at Salem, the NRC staff required that a semi-annual preventive maintenance of the RTBs be incorporated in the Salem TS. The proposed relocation of the RTB maintenance requirement from the TS to the Salem FSAR will allow flexibility in re-evaluating the effectiveness and adequacy of the maintenance activity and optimize maintenance practice without an unnecessary change of the plant TS and an amendment request by the licensee. The Commission has provided guidance for the contents of TS in its "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors" ("Final Policy Statement"), published in the Federal Register on July 22, 1993 (58 FR 39132), in which the Commission indicated that compliance with the Final Policy Statement satisfies §182a of the Act. In particular, the Commission indicated that certain items could be relocated from the TS to licensee-controlled documents. Consistent with this approach, the Final Policy Statement identified four criteria to be used in determining whether a particular matter is required to be included in the TS.¹ The RTB maintenance requirement does not fall within any of the four criteria set forth in the Commission's Final Policy Statement discussed above. In addition, the staff finds that sufficient regulatory controls exist under 10 CFR 50.59. Accordingly, the staff has concluded that these requirements may be relocated from the TS to the licensee's FSAR.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New Jersey State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a

¹The Commission recently adopted amendments to 10 CFR 50.36, pursuant to which the rule was revised to codify and incorporate these criteria. See Final Rule, "Technical Specifications," published in the Federal Register July 19, 1995 (60 FR 36953). The Commission indicated that reactor core isolation cooling, isolation condenser, residual heat removal, standby liquid control, and recirculation pump are to be included in the TS under Criterion 4, although it recognized that other structures, systems and components could also meet this criterion. Federal Register citation (60 FR 36956).

proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (59 FR 55890). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: I. Ahmed

Date: September 18, 1995