

JUN 11 1980

Docket No.: 50-311

Mr. R. L. Mittl, General Manager  
Licensing and Environment  
Engineering and Construction Department  
Public Service Electric and Gas Company  
80 Park Place  
Newark, New Jersey 07101

Dear Mr. Mittl:

SUBJECT: ISSUANCE OF AMENDMENT NO. 1 TO LICENSE NO. DPR-75, SALEM NUCLEAR  
GENERATING STATION, UNIT NO. 2

The Commission has issued the enclosed Amendment No. 1 to Facility Operating License No. DPR-75 for the Salem Nuclear Generating Station, Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your request dated June 6, 1980.

The amendment suspends the limitations of Technical Specification (Appendix A to License No. DPR-75) 3.1.3.2.2 during the performance of individual full length rod testing and during rod position indication system calibration.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing

Enclosures:

1. Amendment No. 1 to DPR-75
2. Safety Evaluation
3. Notice of Issuance

cc: See next page

8006240308 P

CP  
1

BD

OFFICE	DB:LB #3	DL:LB #3	DL:LB #3		
SURNAME	JLee-mec	JKernigan	ASchwencer		
DATE	6/11/80	6/11/80	6/11/80		

Mr. R. L. Mittl, General Manager

- 2 -

cc: Richard Fryling, Jr., Esq.  
Assistant General Counsel  
Public Service Electric & Gas Company  
80 Park Place  
Newark, New Jersey 07100

Mark Wetterhahn, Esq.  
Conner, Moore & Cober  
1747 Pennsylvania Avenue, N.W.  
Suite 1050  
Washington, D. C. 20006

Mr. Leif J. Norrholm  
U. S. Nuclear Regulatory Commission  
Region I  
Drawer I  
Hancocks Bridge, New Jersey 08038

Attorney General  
Department of Law & Public Safety  
State House Annex  
Trenton, New Jersey 08625

State House Annex  
ATTN: Deputy Attorney General  
State of New Jersey  
36 West State Street  
Trenton, New Jersey 08625

Richard B. McGlynn, Commissioner  
Department of Public Utilities,  
State of New Jersey  
101 Commerce Street  
Newark, New Jersey 07102

The Honorable Samuel E. Donelson, Mayor  
Lower Alloways Creek Township  
Municipal Hall  
Hancock's Bridge, New Jersey 08038

Mr. Bruce Blanchard  
Environmental Projects Review  
Department of the Interior  
Room 4256  
18th and C Street, N. W.  
Washington, D. C. 20240

U. S. Environmental Protection Agency  
ATTN: Ms. Elizabeth V. Jankus  
Office of Environmental Review  
Room 2119M, A-104  
401 M Street, S. W.  
Washington, D. C. 20460

EIS Coordinator  
U. S. Environmental Protection Agency  
Region II Office  
26 Federal Plaza  
New York, New York 10097

Director, Technical Assessment Division  
Office of Radiation Programs (AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

President  
New Jersey Board of Public Utilities  
101 Commerce Street  
Newark, New Jersey 07102

PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
PHILADELPHIA ELECTRIC COMPANY  
DELMARVA POWER AND LIGHT COMPANY  
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 1  
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated June 6, 1980 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8006240310 p

OFFICE ▶						
SURNAME ▶						
DATE ▶						

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 1, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: June 11, 1980

*Legal form only*

OFFICE ▶	DL:LB #3	DL:LB #3	OELD	DL:LB #3	
SURNAME ▶	JLec <i>me</i>	JKerr <i>gan</i>	<i>W.D. Patton</i>	ASchwencer	
DATE ▶	6/11/80	6/11/80	6/11/80	6/11/80	

ATTACHMENT TO LICENSE AMENDMENT NO. 1

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages

3/4 10-4  
3/4 10-5

Insert Pages

3/4 10-4  
3/4 10-5

OFFICE ▶  
SURNAME ▶  
DATE ▶

--	--	--	--	--	--	--

## SPECIAL TEST EXCEPTIONS

### NO FLOW TESTS

### LIMITING CONDITION FOR OPERATION

---

3.10.4 The limitations of Specification 3.4.1.1 may be suspended during the performance of startup and PHYSICS TESTS, provided:

- a. The THERMAL POWER does not exceed the P-7 Interlock Setpoint, and
- b. The Reactor Trip Setpoints on the OPERABLE Intermediate and Power Range Channels are set less than or equal to 25% of RATED THERMAL POWER

APPLICABILITY: During operation below the P-7 Interlock Setpoint.

#### ACTION:

With the THERMAL POWER greater than the P-7 Interlock Setpoint, immediately open the reactor trip breakers.

### SURVEILLANCE REQUIREMENTS

---

4.10.4.1 The THERMAL POWER shall be determined to be less than P-7 Interlock Setpoint at least once per hour during startup and PHYSICS TESTS.

4.10.4.2 Each Intermediate, Power Range Channel and P-7 Interlock shall be subjected to a CHANNEL FUNCTIONAL TEST within 12 hours prior to initiating startup or PHYSICS TESTS.

## SPECIAL TEST EXCEPTIONS

### POSITION INDICATION SYSTEM - SHUTDOWN

#### LIMITING CONDITION FOR OPERATION

---

- 3.10.5 The limitations of Specification 3.1.3.2.2 may be suspended during the performance of individual full length (shutdown and control) rod testing and during rod position indication system calibration provided:
- a. Only one shutdown or control bank is withdrawn from the fully inserted position at a time, and
  - b. Either
    1. The rod position indicator is OPERABLE during the withdrawal of the rods, or
    2. k-effective is maintained less than or equal to 0.95.

#### APPLICABILITY:

MODES 3, 4 and 5 during performance of rod testing and during rod position indication system calibration.

#### ACTION:

If either condition a or condition b above are not met, immediately open the reactor trip breakers.

#### SURVEILLANCE REQUIREMENTS

---

- 4.10.5 The above required rod position indication systems shall be determined to be OPERABLE within 24 hours prior to the start of and at least once per 24 hours thereafter during rod drop time measurements by verifying the demand position indication system and the rod position indication systems agree:
- a. Within 12 steps when the rods are stationary, and
  - b. Within 24 steps during rod motion.

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 1 TO FACILITY OPERATING LICENSE NO. DPR-75

PUBLIC SERVICE ELECTRIC AND GAS COMPANY,  
PHILADELPHIA ELECTRIC COMPANY,  
DELMARVA POWER AND LIGHT COMPANY, AND  
ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

DOCKET NO. 50-311

The proposed Technical Specification change provides that during control rod drop measurements, testing, and position indication calibration, either the rod position indicator is operable during withdrawal of the rods or k-effective is maintained less than or equal to 0.95. This applies in Modes 3, 4, and 5. The change consists of addition of control rod testing and position indication calibration and maintaining k-effective less than or equal to 0.95. The original purpose of the specification was to ensure that the position of the rods being moved was known, in order to preclude the remote possibility that the reactor inadvertently would be made critical. Substitution of the requirement that k-effective is maintained less than or equal to 0.95 is also an acceptable method for avoiding inadvertent criticality of the reactor. This criterion is one of the options specified for refueling (to avoid inadvertent criticality). We therefore find the proposed Technical Specification change will have no adverse effect on the safety of the power plant, and is acceptable.

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

8 0062 40444

OFFICE ▶						
SURNAME ▶						
DATE ▶						

Conclusion

We have concluded, based on the considerations discussed above, that:  
(1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: June 11, 1980

OFFICE ▶	DL:LB #3	DL:LB #3				
SURNAME ▶	JKeenan	ASchwencer				
DATE ▶	6/11/80	6/11/80				

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-311

PUBLIC SERVICE ELECTRIC AND GAS COMPANY,  
PHILADELPHIA ELECTRIC COMPANY,  
DELMARVA POWER AND LIGHT COMPANY, AND  
ATLANTIC CITY ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to Facility Operating License No. DPR-75, issued to Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees), which revised Technical Specifications for operation of the Salem Nuclear Generating Station, Unit No. 2 (the facility) located in Salem County, New Jersey. The amendment is effective as of the date of issuance.

The amendment suspends the limitations of one of the Technical Specifications during the performance of individual full length rod testing and during rod position indication system calibration.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

8 0062 40448

OFFICE ▶  
SURNAME ▶  
DATE ▶

--	--	--	--	--	--	--

- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated June 6, 1980, (2) Amendment No. 1 to License No. DPR-75, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Salem Free Public Library, 112 West Broadway, Salem, New Jersey. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 11th day of June, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing

OFFICE ▶	DL:LB #3	DL:LB #3	OELD	DL:LB #3	
SURNAME ▶	JL [Signature]	JK [Signature]	W. D. [Signature]	ASchwencer	
DATE ▶	6/11/80	6/11/80	6/11/80	6/11/80	

*Legal form only*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
PHILADELPHIA ELECTRIC COMPANY  
DELMARVA POWER AND LIGHT COMPANY  
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 1  
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated June 6, 1980 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8 006240310

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 1, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: June 11, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 1

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages

3/4 10-4  
3/4 10-5

Insert Pages

3/4 10-4  
3/4 10-5



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 1 TO FACILITY OPERATING LICENSE NO. DPR-75

PUBLIC SERVICE ELECTRIC AND GAS COMPANY,  
PHILADELPHIA ELECTRIC COMPANY,  
DELMARVA POWER AND LIGHT COMPANY, AND  
ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

DOCKET NO. 50-311

The proposed Technical Specification change provides that during control rod drop measurements, testing, and position indication calibration, either the rod position indicator is operable during withdrawal of the rods or k-effective is maintained less than or equal to 0.95. This applies in Modes 3, 4, and 5. The change consists of addition of control rod testing and position indication calibration and maintaining k-effective less than or equal to 0.95. The original purpose of the specification was to ensure that the position of the rods being moved was known, in order to preclude the remote possibility that the reactor inadvertently would be made critical. Substitution of the requirement that k-effective is maintained less than or equal to 0.95 is also an acceptable method for avoiding inadvertent criticality of the reactor. This criterion is one of the options specified for refueling (to avoid inadvertent criticality). We therefore find the proposed Technical Specification change will have no adverse effect on the safety of the power plant, and is acceptable.

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

8008240344

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: June 11, 1980

**DISTRIBUTION:**

**Docket File - 50-311**

**NRC PDR**

**Local PDR**

**LB#3 Files**

**RPurple**

**RTedesco**

**ASchwencer**

**JKerrigan**

**JLee**

**Lana Cobb, I&E**

**I&E 5**

**DBiddle, MPA**

**RDiggs, ADM**

**WKreger**

**MErnst**

**RMattson**

**JKnight**

**SHanauer**

**DSkovholt**

**IDinitz, AIG**

**RCleveland**

**MDuncan**

**HBristow, NMSS**

**DEisenhut**

**BGrimes**

**EHughes**

**OELD**

**JMoore, OELD**

**WPasciak**

**bcc: ACRS (16)**

**NSIC**

**TIC**

**A. Rosenthal, ASLAB**

**ASLBP**

JUN 11 1980

Docket No.: 50-311

Mr. R. L. Mittl, General Manager  
Licensing and Environment  
Engineering and Construction Department  
Public Service Electric and Gas Company  
80 Park Place  
Newark, New Jersey 07101

Dear Mr. Mittl:

SUBJECT: ISSUANCE OF AMENDMENT NO. 1 TO LICENSE NO. DPR-75, SALEM NUCLEAR  
GENERATING STATION, UNIT NO. 2

The Commission has issued the enclosed Amendment No. 1 to Facility Operating  
License No. DPR-75 for the Salem Nuclear Generating Station, Unit No. 2.  
This amendment consists of changes to the Technical Specifications in re-  
sponse to your request dated June 6, 1980.

The amendment suspends the limitations of Technical Specification (Appendix A  
to License No. DPR-75) 3.1.3.2.2 during the performance of individual full  
length rod testing and during rod position indication system calibration.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing

Enclosures:

- 1. Amendment No. 1 to DPR-75
- 2. Safety Evaluation
- 3. Notice of Issuance

cc: See next page

8006240308 P

OFFICE	DL:LB #3	DL:LB #3	DL:LB #3		
SURNAME	JLee:mec	JKerrigan	ASchwencer		
DATE	6/11/80	6/11/80	6/11/80		

Mr. R. L. Mittl, General Manager

- 2 -

cc: Richard Fryling, Jr., Esq.  
Assistant General Counsel  
Public Service Electric & Gas Company  
80 Park Place  
Newark, New Jersey 07100

Mark Wetterhahn, Esq.  
Conner, Moore & Cober  
1747 Pennsylvania Avenue, N.W.  
Suite 1050  
Washington, D. C. 20006

Mr. Leif J. Norrholm  
U. S. Nuclear Regulatory Commission  
Region I  
Drawer I  
Hancocks Bridge, New Jersey 08038

Attorney General  
Department of Law & Public Safety  
State House Annex  
Trenton, New Jersey 08625

State House Annex  
ATTN: Deputy Attorney General  
State of New Jersey  
36 West State Street  
Trenton, New Jersey 08625

Richard B. McGlynn, Commissioner  
Department of Public Utilities,  
State of New Jersey  
101 Commerce Street  
Newark, New Jersey 07102

The Honorable Samuel E. Donelson, Mayor  
Lower Alloways Creek Township  
Municipal Hall  
Hancock's Bridge, New Jersey 08038

Mr. Bruce Blanchard  
Environmental Projects Review  
Department of the Interior  
Room 4256  
18th and C Street, N. W.  
Washington, D. C. 20240

U. S. Environmental Protection Agency  
ATTN: Ms. Elizabeth T. Jenkins  
Office of Environmental Review  
Room 2119M, A-104  
401 M Street, S. W.  
Washington, D. C. 20460

EIS Coordinator  
U. S. Environmental Protection Agency  
Region II Office  
26 Federal Plaza  
New York, New York 10117

Director, Technical Assessment Division  
Office of Radiation Programs (A4-259)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

President  
New Jersey Board of Public Utilities  
101 Commerce Street  
Newark, New Jersey 07102

PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
PHILADELPHIA ELECTRIC COMPANY  
DELMARVA POWER AND LIGHT COMPANY  
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 1  
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated June 6, 1980 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8006240 310 P

OFFICE ▶						
SURNAME ▶						
DATE ▶						

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 1, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: June 11, 1980

OFFICE ▶	DL:LB #3	DL:LB #3	OELD	DL:LB #3		
SURNAME ▶	JLee:mec	JKerrigan	W.D. Patin	AShwencer		
DATE ▶	6/11/80	6/11/80	6/11/80	6/11/80		

ATTACHMENT TO LICENSE AMENDMENT NO. 1

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages

3/4 10-4  
3/4 10-5

Insert Pages

3/4 10-4  
3/4 10-5

OFFICE ▶	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 1 TO FACILITY OPERATING LICENSE NO. DPR-75

PUBLIC SERVICE ELECTRIC AND GAS COMPANY,  
PHILADELPHIA ELECTRIC COMPANY,  
DELMARVA POWER AND LIGHT COMPANY, AND  
ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

DOCKET NO. 50-311

The proposed Technical Specification change provides that during control rod drop measurements, testing, and position indication calibration either the rod position indicator is operable during withdrawal of the rods or  $k_{\text{effective}}$  is maintained less than or equal to 0.95. This applies in nodes 3, 4, and 5. The change consists of addition of control rod testing and position indication calibration and maintaining  $k_{\text{effective}}$  less than or equal to 0.95. The original purpose of the specification was to ensure that the position of the rods being moved was known, in order to preclude the remote possibility that the reactor inadvertently would be made critical. Substitution of the requirement that  $k_{\text{effective}}$  is maintained less than or equal to 0.95 is also an acceptable method for avoiding inadvertent criticality of the reactor. This criterion is one of the options specified for refueling (to avoid inadvertent criticality). We therefore find the proposed Technical Specification change will have no adverse effect on the safety of the power plant, and is acceptable.

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types of total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

8 0062 40 4414

OFFICE ▶						
SURNAME ▶						
DATE ▶						

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: June 11, 1980

OFFICE ▶	DL:LB #3	DL:LB #3				
SURNAME ▶	JKeenan:med	ASchwencer				
DATE ▶	6/11/80	6/11/80				

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-311

PUBLIC SERVICE ELECTRIC AND GAS COMPANY,  
PHILADELPHIA ELECTRIC COMPANY,  
DELMARVA POWER AND LIGHT COMPANY, AND  
ATLANTIC CITY ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to Facility Operating License No. DPR-75, issued to Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees), which revised Technical Specifications for operation of the Salem Nuclear Generating Station, Unit No. 2 (the facility) located in Salem County, New Jersey. The amendment is effective as of the date of issuance.

The amendment suspends the limitations of one of the Technical Specifications during the performance of individual full length rod testing and during rod position indication system calibration.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

8006240448

OFFICE ▶

SURNAME ▶

DATE ▶

--	--	--	--	--	--	--

- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated June 6, 1980, (2) Amendment No. 1 to License No. DPR-75, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Salem Free Public Library, 112 West Broadway, Salem, New Jersey. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 11th day of June, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Acting Chief  
Licensing Branch No. 3  
Division of Licensing

OFFICE	DL:LB #3	DL:LB #3	OELD	DL:LB #3	
SURNAME	J Lee mec	J Key dan	<i>W.D. Patton</i>	A Schwencer	
DATE	6/11/80	6/11/80	6/11/80	6/11/80	

*Legal form only*

DISTRIBUTION:

Docket File - 50-311

NRC PDR

Local PDR

LB #3 Files

RPurple

RTedesco

ASchwencer

JKerrigan

JLee

Lana Cobb, I&E

I&E 5

DBiddle, MPA

RDiggs, ADM

WKreger

MErnst

RMattson

JKnight

SHanauer

DSkovholt

IDinitz, AIG

RCleveland

MDuncan

HBristow, NMSS

DEisenhut

BGrimes

EHughes

OELD

JMoore, OELD

WPasciak

bcc: ACRS (16)

NSIC

TIC

A. Rosenthal, ASLAB

ASLBP