

MAY 05 1983

DISTRIBUTION
Docket WJones
NRC PDR Gray
L PDR TBarnhart-4
NSIC
ORB#1 Rdg
DEisenhut
OELD
JMTaylor
LJHarmon
ELJordan
ACRS-10
CParrish
DFischer
Brinkman
OPA
RDiggs

Docket No. 50-311

Mr. R. A. Uderitz
Vice President - Nuclear
Public Service Electric and Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Uderitz:

The Commission has issued the enclosed Amendment No. 19 to Facility Operating License No. DPR-75 for the Salem Nuclear Generating Station, Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your request dated January 31, 1983.

The amendment changes the Technical Specifications on Fxy to remove the cycle dependent values of Fxy as a function of core height and provide these Fxy values by means of Peaking Factor Limit Report.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

ORIGINAL SIGNED

Donald Fischer, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosures:

- 1. Amendment No. 19 to DPR-75
- 2. Safety Evaluation
- 3. Notice of Issuance

cc w/enclosures:
See next page

8305170015 830505
PDR ADDCK 05000311
P PDR

OFFICE	ORB#1:DL	ORB#1:DL	ORB#1:DL	AD/OR:DL	OELD	
SURNAME	CParrish	DFischer:dn	SVarga	GLinas	M. KARMAN	
DATE	05/5/83	05/5/83	05/5/83	05/5/83	05/3/83	

Mr. R. A. Uderitz
Public Service Electric and Gas Company

cc: Mark J. Wetterhahn, Esquire
Conner and Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, NW
Washington, D. C. 20006

Richard Fryling, Jr., Esquire
Assistant General Solicitor
Public Service Electric and Gas Company
P.O. Box 570 - Mail Code T5E
Newark, New Jersey 07101

Gene Fisher, Bureau of Chief
Bureau of Radiation Protection
380 Scotch Road
Trenton, New Jersey 08628

Mr. Henry J. Midura, General Manager -
Salem Operations
Public Service Electric and Gas Company
P. O. Box E
Hancocks Bridge, New Jersey 08038

Mr. Dale Bridenbaugh
M.H.B. Technical Associates
1723 Hamilton Avenue
San Jose, California 95125

Leif J. Norrholm, Resident Inspector
Salem Nuclear Generating Station
U. S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, New Jersey 08038

Richard F. Engel
Deputy Attorney General
Department of Law and Public Safety
CN-112
State House Annex
Trenton, New Jersey 08625

Richard B. McGlynn, Commissioner
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, New Jersey 07102

Mr. Edwin A. Liden, Manager
Nuclear Licensing and Regulation
Public Service Electric and Gas Co.
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Regional Radiation Representative
EPA Region II
26 Federal Plaza
New York, New York 10007

Mr. R. L. Mittl, General Manager -
Nuclear Assurance and Regulation
Public Service Electric and Gas Company
Mail Code T16D - P.O. Box 570
Newark, New Jersey 07101

Regional Administrator - Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, New Jersey 08038

Mr. Alfred C. Coleman, Jr.
Mrs. Eleanor G. Coleman
35 K Drive
Pennsville, New Jersey 08070

Mr. R. A. Uderitz
Public Service Electric and Gas Company

cc: Carl Valore, Jr., Esquire
Valore, McAllister, Aron and
Westmoreland, P.A.
535 Tilton Road
Northfield, New Jersey 08225

June D. MacArtor, Esquire
Deputy Attorney General
Tatnall Building
P. O. Box 1401
Dover, Delaware 19901

Harry M. Coleman, Mayor
Lower Alloways Creek Township
Municipal Hall
Hancocks Bridge, New Jersey 08038

Mr. Charles P. Johnson
Assistant To Vice President - Nuclear
Public Service Electric and Gas Company
P. O. Box 570
80 Park Plaza - 15A
Newark, New Jersey 07101



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PHILADELPHIA ELECTRIC COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 19
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated January 31, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8305170019 830505
PDR ADOCK 05000311
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 19, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 5, 1983

ATTACHMENT TO LICENSE AMENDMENT NO. 19.

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Pages

3/4 2-7

B 3/4 2-5

6-17

3/4 1-21

Insert Pages

3/4 2-7

B 3/4 2-5

B 3/4 2-6

6-17

6-17a

3/4 1/21

POWER DISTRIBUTION LIMITS

SURVEILLANCE REQUIREMENTS (Continued)

- b) At least once per 31 EFPD, whichever occurs first.
2. When the F_{xy}^C is less than or equal to the F_{xy}^{RTP} limit for the appropriate measured core plane, additional power distribution maps shall be taken and F_{xy}^C compared to F_{xy}^{RTP} and F_{xy}^L at least once per 31 EFPD.
- e. The F_{xy} limit for RATED THERMAL POWER (F_{xy}^{RTP}) shall be provided for all core planes containing bank "D" control rods and all unrodded core planes in a Radial Peaking Factor Limit Report per specification 6.9.1.10.
- f. The F_{xy} limits of e., above, are not applicable in the following core plane regions as measured in percent of core height from the bottom of the fuel:
1. Lower core region from 0% to 15%, inclusive.
 2. Upper core region from 85% to 100%, inclusive.
 3. Grid plane regions at $17.8\% \pm 2\%$, $32.1 \pm 2\%$, $46.4\% \pm 2\%$, $60.6\% \pm 2\%$ and $74.9\% \pm 2\%$, inclusive.
 4. Core plane regions within $\pm 2\%$ of core height (± 2.88 inches) about the bank demand position of the bank "D" control rods.
- g. Evaluating the effects of F_{xy} on $F_Q(Z)$ to determine if $F_Q(Z)$ is within its limit whenever F_{xy}^C exceeds F_{xy}^L .

4.2.2.3 When $F_Q(Z)$ is measured pursuant to specification 4.10.2.2, an overall measured $F_Q(Z)$ shall be obtained from a power distribution map and increased by 3% to account for manufacturing tolerances and further increased by 5% to account for measurement uncertainty.

POWER DISTRIBUTION LIMITS

BASES

event. The penalties applied to $F_{\Delta H}$ to account for Rod Bow (Figure 3.2-4) as a function of burnup are consistent with those described in Mr. John F. Stolz's (NRC) letter to T. M. Anderson (Westinghouse) dated April 5, 1979 and W 8691 Rev. 1 (partial rod bow test data).

When an F_Q measurement is taken, an allowance for both experimental error and manufacturing tolerance must be made. An allowance of 5% is appropriate for a full core map taken with the incore detector flux mapping system and a 3% allowance is appropriate for manufacturing tolerance. When RCS flow rate and $F_{\Delta H}$ are measured, no additional allowances are necessary prior to comparison with the limits of Figure 3.2-3. Measurement errors of 3.5% for RCS total flow rate and 4% for $F_{\Delta H}$ have been allowed for in determination of the design DNBR value.

The 12 hour periodic surveillance of indicated RCS flow is sufficient to detect only flow degradation which could lead to operation outside the acceptable region of operation shown in Figure 3.2-3.

The radial peaking factor $F_{xy}(z)$ is measured periodically to provide assurance that the hot channel factor, $FQ(z)$, remains within its limit. The F_{xy} limit for RATED THERMAL POWER (F_{xy}^{RTP}), as provided in the Radial Peaking Factor Limit Report per specification 6.9.1.10, was determined from expected power control maneuvers over the full range of burnup conditions in the core.

3/4.2.4 QUADRANT POWER TILT RATIO

The quadrant power tilt ratio limit assures that the radial power distribution satisfies the design values used in the power capability analysis. Radial power distribution measurements are made during startup testing and periodically during power operation.

POWER DISTRIBUTION LIMITS

BASES

The limit of 1.02 at which corrective action is required provides DNB and linear heat generation rate protection with x-y plane power tilts. A limiting tilt of 1.025 can be tolerated before the margin for uncertainty in F_Q is depleted. The limit of 1.02 was selected to provide an allowance for the uncertainty associated with the indicated power tilt.

The 2 hour time allowance for operation with a tilt condition greater than 1.02 but less than 1.09 is provided to allow identification and correction of a dropped or misaligned rod. In the event such action does not correct the tilt, the margin for uncertainty on F_Q is reinstated by reducing the power by 3% from RATED THERMAL POWER for each percent of tilt in excess of 1.0.

3/4.2.5 DNB PARAMETERS

The limits on the DNB related parameters assure that each of the parameters are maintained with the normal steady state envelope of operation assumed in the transient and accident analyses. The limits are consistent with the initial FSAR assumptions and have been analytically demonstrated adequate to maintain a minimum DNBR of 1.30 throughout each analyzed transient.

The 12 hour periodic surveillance of these parameters through instrument readout is sufficient to ensure that the parameters are restored within their limits following load changes and other expected transient operation.

ADMINISTRATIVE CONTROLS

- h. Errors discovered in the transient or accident analyses or in the methods used for such analyses as described in the safety analysis report or in the bases for the technical specifications that have or could have permitted reactor operation in a manner less conservative than assumed in the analyses.
- i. Performance of structures, systems, or components that requires remedial action or corrective measures to prevent operation in a manner less conservative than assumed in the accident analyses in the safety analysis report or technical specifications bases; or discovery during unit life of conditions not specifically considered in the safety analysis report or technical specifications that require remedial action or corrective measures to prevent the existence or development of an unsafe condition.

THIRTY DAY WRITTEN REPORTS

6.9.1.9 The types of events listed below shall be the subject of written reports to the Administrator of the Regional Office within thirty days of occurrence of the event. The written report shall include, as a minimum, a completed copy of a licensee event report form. Information provided on the licensee event report form shall be supplemented, as needed, by additional narrative material to provide complete explanation of the circumstances surrounding the event.

- a. Reactor protection system or engineered safety feature instrument settings which are found to be less conservative than those established by the technical specifications but which do not prevent the fulfillment of the functional requirements of affected systems.
- b. Conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation.
- c. Observed inadequacies in the implementation of administrative or procedural controls which threaten to cause reduction of degree of redundancy provided in reactor protection systems or engineered safety feature systems.
- d. Abnormal degradation of systems other than those specified in 6.9.1.8.c above designed to contain radioactive material resulting from the fission process.

ADMINISTRATIVE CONTROLS

RADIAL PEAKING FACTOR LIMIT REPORT

6.9.1.10 The F_{xy} limits for RATED THERMAL POWER (F_{xy}^{RTP}) for all core planes containing bank "D" control rods and all unrodded core planes and the plot of predicted ($F_Q^{T.P. Rel}$) vs. Axial Core Height with the limit envelope shall be provided to the NRC Regional Administrator with a copy to Director of Nuclear Reactor Regulation, Attention: Chief, Core Performance Branch, U.S. Nuclear Regulatory Commission, Washington, D. C. 20555 at least 60 days prior to each cycle initial criticality unless otherwise approved by the Commission by letter.


In addition, in the event that the limit should change requiring a new submittal or an amended submittal to the Peaking Factor Limit Report, it will be submitted 60 days prior to the date the limit would become effective unless otherwise approved by the Commission by letter.

Any information needed to support F_{xy}^{RTP} will be by request from the NRC and need not be included in this report.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Director of the Office of Inspection and Enforcement Regional Office within the time period specified for each report

(Fully Withdrawn)



(Fully Inserted)

Fraction of Rated Thermal Power

Figure 3.1-1

ROD BANK INSERTION LIMITS VERSUS THERMAL POWER
FOUR LOOP OPERATION



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 19 TO FACILITY OPERATING LICENSE NO. DPR-75

PUBLIC SERVICE ELECTRIC AND GAS COMPANY,
PHILADELPHIA ELECTRIC COMPANY,
DELMARVA POWER AND LIGHT COMPANY, AND
ATLANTIC CITY ELECTRIC COMPANY

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

DOCKET NO. 50-311

Introduction

In a letter dated January 31, 1983, Public Service Electric and Gas Company submitted the results of a Reload Safety Evaluation (RSE) and a request for amendment to the Salem Unit 2 Technical Specifications. The Cycle 2 RSE was performed by Westinghouse using the methodology described in WCAP 9272. The evaluation showed the need for changes to the F_{xy} and rod insertion limit Technical Specifications.

Discussion

A change to the Technical Specifications on F_{xy} was requested to remove the cycle dependent values of F_{xy} as a function of core height and provide these F_{xy} values by means of a Peaking Factor Limit Report. It is anticipated that F_{xy} will change from cycle to cycle and this change would eliminate the necessity of making a Technical Specification change for each reload. A similar change has been approved on other plants. A Radial Peaking Factor Limit Report was submitted with the January 31, 1983 letter for Cycle 2. We find this change acceptable. The rod insertion limit Technical Specification is also acceptable.

The dropped RCCA event was analyzed by the new Westinghouse Dropped Rod Methodology. Results show the DNB design basis is met for all dropped rod events initiated from full power for Cycle 2. Since the new Westinghouse Dropped Rod Methodology has been approved, the interim restrictions on power operation above 90 percent power may be removed. The new Westinghouse Dropped Rod Methodology must continue to be used to evaluate the dropped rod event for each cycle.

Summary

Based on our review we find that the proposed Technical Specification changes to the F_{xy} and rod insertion limit are acceptable.

8305170023 830505
PDR ADOCK 05000311
P PDR

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated, does not create the possibility of an accident of a type different from any evaluated previously, and does not involve a significant reduction in a margin of safety, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: May 5, 1983

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-311PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PHILADELPHIA ELECTRIC COMPANY,
DELMARVA POWER AND LIGHT COMPANY, AND
ATLANTIC CITY ELECTRIC COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 15 to Facility Operating License No. DPR-75, issued to Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company, and Atlantic City Electric Company (the licensees), which revised Technical Specifications for operation of the Salem Nuclear Generating Station, Unit No. 2 (the facility) located in Salem County, New Jersey. The amendment is effective as of the date of issuance.

The amendment changes the Technical Specifications on Fxy to remove the cycle dependent values of Fxy as a function of core height and provide these Fxy values by means of a Peaking Factor Limit Report.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment does not involve a significant hazards consideration.


The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

- 2 -

For further details with respect to this action, see (1) the application for amendment dated January 31, 1983, (2) Amendment No. 19 to License No. DPR-75, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Salem Free Public Library, 112 West Broadway, Salem, New Jersey. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 5th day of May, 1983.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing