



State of New Jersey
Department of Environmental Protection and Energy
Division of Environmental Safety, Health and Analytical Programs
CN 415
Trenton, NJ 08625-0415

Scott A. Weiner
Commissioner

Gerald P. Nicholls, Ph.D.
Director

May 21, 1993

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Salem Generating Station Unit 2
Docket Nos. 50-311
Amendment to the Facility Operating License
LCR 92-10

The subject amendment request was submitted to the NRC by PSE&G letter dated January 25, 1993. This request proposes to revise the Salem Unit 2 Technical Specifications to incorporate revised Reactor Coolant System heatup and cooldown curves. The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91(b). On the revised heatup curve, Page 3/4 4-28, the area of acceptable operation is incorrectly shown to be above the criticality limit. Note that the area of acceptable operation is correctly shown on the existing heatup curve.

If you have any questions, please contact Rich Pinney at (609) 987-2086.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

c: Distribution
270073

9306010125 930521
PDR ADDCK 05000311
PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

Adol
1/0

Distribution

Jill Lipoti
N.J. DEPE

M. Miller
NRC Region I State Liaison Officer

T. Johnson
NRC Sr. Resident Inspector

J. Stone
NRC Project Manager

F. Thompson
PSE&G