



State of New Jersey  
Department of Environmental Protection and Energy  
Division of Environmental Safety, Health and Analytical Programs  
CN 415  
Trenton, NJ 08625-0415

Scott A. Weiner  
Commissioner

Gerald P. Nicholls, Ph.D.  
Director

May 21, 1993

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Gentlemen:

Subject: Salem Generating Station Unit 2  
Docket Nos. 50-311  
Amendment to the Facility Operating License  
LCR 92-10

The subject amendment request was submitted to the NRC by PSE&G letter dated January 25, 1993. This request proposes to revise the Salem Unit 2 Technical Specifications to incorporate revised Reactor Coolant System heatup and cooldown curves. The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91(b). On the revised heatup curve, Page 3/4 4-28, the area of acceptable operation is incorrectly shown to be above the criticality limit. Note that the area of acceptable operation is correctly shown on the existing heatup curve.

If you have any questions, please contact Rich Pinney at (609) 987-2086.

Sincerely,

Kent W. Tosch, Manager  
Bureau of Nuclear Engineering

c: Distribution  
270073

9306010125 930521  
PDR ADDCK 05000311  
PDR

Adol  
1/0

Distribution

Jill Lipoti  
N.J. DEPE

M. Miller  
NRC Region I State Liaison Officer

T. Johnson  
NRC Sr. Resident Inspector

J. Stone  
NRC Project Manager

F. Thompson  
PSE&G