

May 16, 1991

Docket No. 50-311

Mr. Steven E. Miltenberger  
Vice President and Chief Nuclear  
Officer  
Public Service Electric and Gas  
Company  
Post Office Box 236  
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

DISTRIBUTION:

Docket File  
NRC & Local PDRs  
PDI-2 Reading  
SVarga  
JCalvo  
MO'Brien(2)  
JStone  
OGC  
DHagan, 3206  
ACRS(10)  
GPA/PA  
LDoerflein, RGN-I  
JWhite, RGN-I

SUBJECT: WITHDRAWAL OF AMENDMENT REQUEST, SALEM NUCLEAR GENERATING STATION,  
UNIT 2 (TAC NO. 75560)

By letter dated April 17, 1990, Public Service Electric and Gas Company (PSE&G) requested withdrawal of an emergency license amendment request dated January 4, 1990. The January 4, 1990 request modified the charging pump flow requirements to allow Salem Unit 2 to complete the fourth fuel cycle with maximum charging pump flow exceeding the technical specification limit of 550 gpm by less than 1%. The fourth fuel cycle ended on April 1, 1990, when Salem 2 entered Mode 5.

By letter dated April 20, 1990, amendment 90 was issued for Salem Unit 2 in response to the January 4, 1990 request. Because the amendment was issued before receipt of the request for withdrawal, your request is denied.

Sincerely,

/S/

James C. Stone, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

OFC	:PDI-2/LA	:PDI-2/PM	:PDI-2/D	:	:
NAME	:MO'BRIEN	:JSTONE:tlc	:WBUTLER	:	:
DATE	:5/16/91	:5/16/91	:5/16/91	:	:

OFFICIAL RECORD COPY  
Document Name: TAC 75560

9105220254 910516  
FDR ADOCK 05000311  
P FDR

**NRC FILE CENTER COPY**

DF01  
110



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

May 16, 1991

Docket No. 50-311

Mr. Steven E. Miltenberger  
Vice President and Chief Nuclear  
Officer  
Public Service Electric and Gas  
Company  
Post Office Box 236  
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: WITHDRAWAL OF AMENDMENT REQUEST, SALEM NUCLEAR GENERATING STATION,  
UNIT 2 (TAC NO. 75560)

By letter dated April 17, 1990, Public Service Electric and Gas Company (PSE&G) requested withdrawal of an emergency license amendment request dated January 4, 1990. The January 4, 1990 request modified the charging pump flow requirements to allow Salem Unit 2 to complete the fourth fuel cycle with maximum charging pump flow exceeding the technical specification limit of 550 gpm by less than 1%. The fourth fuel cycle ended on April 1, 1990, when Salem 2 entered Mode 5.

By letter dated April 20, 1990, amendment 90 was issued for Salem Unit 2 in response to the January 4, 1990 request. Because the amendment was issued before receipt of the request for withdrawal, your request is denied.

Sincerely,

A handwritten signature in black ink, reading "James C. Stone".

James C. Stone, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Steven E. Miltenberger  
Public Service Electric & Gas Company

Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire  
Winston & Strawn  
1400 L Street NW  
Washington, DC 20005-3502

Richard B. McGlynn, Commission  
Department of Public Utilities  
State of New Jersey  
101 Commerce Street  
Newark, NJ 07102

Richard Fryling, Jr., Esquire  
Law Department - Tower 5E  
80 Park Place  
Newark, NJ 07101

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Calvin A. Vondra  
General Manager - Salem Operations  
Salem Generating Station  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township  
c/o Mary O. Henderson, Clerk  
Municipal Building, P.O. Box 157  
Hancocks Bridge, NJ 08038

Mr. S. LaBruna  
Vice President - Nuclear Operations  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, New Jersey 08038

Mr. Bruce A. Preston, Manager  
Licensing and Regulation  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Thomas P. Johnson, Senior Resident  
Inspector  
Salem Generating Station  
U.S. Nuclear Regulatory Commission  
Drawer I  
Hancocks Bridge, NJ 08038

Mr. David Wersan  
Assistant Consumer Advocate  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director  
Radiation Protection Programs  
NJ Department of Environmental  
Protection  
CN 415  
Trenton, NJ 08625-0415

Mr. Scott B. Ungerer  
MGR. - Joint Generation Projects  
Atlantic Electric Company  
P.O. Box 1500  
1199 Black Horse Pike  
Pleasantville, NJ 08232

Maryland People's Counsel  
American Building, 9th Floor  
231 East Baltimore Street  
Baltimore, Maryland 21202

Mr. Jack Urban  
General Manager, Fuels Department  
Delmarva Power & Light Company  
800 King Street  
Wilmington, DE 19899

Mr. J. T. Robb, Director  
Joint Owners Affairs  
Philadelphia Electric Company  
955 Chesterbrook Blvd., 51A-13  
Wayne, PA 19087

Public Service Commission of Maryland  
Engineering Division  
ATTN: Chief Engineer  
231 E. Baltimore Street  
Baltimore, MD 21202-3486