

August 22, 1990

Docket No. 50-311

DISTRIBUTION

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Docket file
NRC PDR & L PDRs
PDI-2 Rdg
GPA/PA
OC/LFMB
Wanda Jones
Ochopra
MThadani
RBlough

MO'Brien (2)
OGC
DHagan PSwetland
EJordan GHill (4)
JStone SVarga
JCalvo BBoger
ACRS (10)
JDyer FRosa
BBoger WButler

Dear Mr. Miltenberger:

SUBJECT: DIESEL GENERATOR SURVEILLANCE TESTING SALEM GENERATING STATION,
UNIT NO. 2 (TAC NO. 69042)

The Commission has issued the enclosed Amendment No. 93 to Facility Operating License No. DPR-75 for the Salem Generating Station, Unit No. 2. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated July 27, 1990, and is being issued on an exigent basis.

This amendment revises the diesel generator surveillance test frequency requirements in the Salem 2 Technical Specifications.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/ W. R. Butler for

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 93 to License No. DPR-75
- 2. Safety Evaluation

cc w/enclosures:
See next page

OFC	: PDI-2:LA	: PDI-2:PM	: OGC	: PDI-2:D	:
NAME	: MO'Brien	: JStone/Bah	: R Bachmann	: WButler	:
DATE	: 8/19/90	: 8/8/90	: 8/10/90	: 8/21	:

OFFICIAL RECORD COPY
Document Name: AMEND 69042

00052

JFol CP-1

9008270048 900822
PDR ADDCK 05000311
P PDC



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 22, 1990

Docket No. 50-311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:


SUBJECT: DIESEL GENERATOR SURVEILLANCE TESTING SALEM GENERATING STATION,
UNIT NO. 2 (TAC NO. 69042)

The Commission has issued the enclosed Amendment No. 93 to Facility Operating License No. DPR-75 for the Salem Generating Station, Unit No. 2. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated July 27, 1990, and is being issued on an exigent basis.

This amendment revises the diesel generator surveillance test frequency requirements in the Salem 2 Technical Specifications.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

(for) 
James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 93 to
License No. DPR-75
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. Steven E. Miltenberger
Public Service Electric & Gas Company

Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire
Bishop, Cook, Purcell & Reynolds
1400 L Street NW
Washington, DC 20005-3502

Richard B. McGlynn, Commission
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. L. K. Miller
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. S. LaBruna
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Bruce A. Preston, Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Thomas P. Johnson, Senior Resident
Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection
CN 415
Trenton, NJ 08625-0415

Mr. Scott B. Ungerer
MGR. - Joint Generation Projects
Atlantic Electric Company
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, NJ 08232

Maryland People's Counsel
American Building, 9th Floor
231 East Baltimore Street
Baltimore, Maryland 21202

Mr. Jack Urban
General Manager, Fuels Department
Delmarva Power & Light Company
800 King Street
Wilmington, DE 19899

Mr. J. T. Robb, Director
Joint Owners Affairs
Philadelphia Electric Company
955 Chesterbrook Blvd., 51A-13
Wayne, PA 19087

Public Service Commission of Maryland
Engineering Division
ATTN: Chief Engineer
231 E. Baltimore Street
Baltimore, MD 21202-3486



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 93
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated July 27, 1990 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:


9008270050 900822
PDR ADCK 05000311
P PDC

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 93 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects - I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 22, 1990

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 93, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/s/

Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects - I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 22, 1990

[Signature]
PDI-2/LA
M Brien
8/7/90

[Signature]
PDI-2/PM
JStone
8/18/90

[Signature]
OGC
R Bachmann
8/10/90

[Signature]
PDI-2/D
WButler
8/21/90

ATTACHMENT TO LICENSE AMENDMENT NO. 93

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Page

3/4 8-6

Insert Page

3/4 8-6

TABLE 4.8-1

DIESEL GENERATOR TEST SCHEDULE

<u>Number of Failures in Last 20 Valid Tests *</u>	<u>Test Frequency</u>
Less than or Equal to 1	At least once per 31 days
Greater than or Equal to 2	At least once per 7 days

* Criteria for determining the number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.e of Regulatory Guide 1.108, Revision 1, August 1977, where the number of tests and failures is determined on a per diesel generator basis.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 93 TO FACILITY OPERATING LICENSE NO. DRP-75

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

SALEM GENERATING STATION, UNIT NO. 2

DOCKET NO. 50-311

1.0 INTRODUCTION

By letter dated July 27, 1990, Public Service Electric & Gas Company requested an amendment to Facility Operating License No. DPR-75 for the Salem Generating Station, Unit No. 2. The proposed amendment would change the emergency diesel generator (EDG) surveillance test frequency basis in the Salem 2 technical specifications (TS) from the number of failures in the last 100 valid starts per nuclear unit to the number of failures in the last 20 valid starts per diesel generator. The NRC staff recommended these changes in Generic Letter 84-15.

2.0 EVALUATION

Table 4.8-1 of Salem Unit 2 technical specifications addresses emergency diesel generator testing frequency. The present requirement bases the diesel generator test frequency on the number of failures in the last 100 tests on a per nuclear unit basis. Based on the results of the last 100 valid tests, the present test frequency is once per 3 days for each of the three Salem Unit 2 emergency diesel generators, or one diesel generator start per day. The licensee has estimated that 30 consecutive successful tests would be required to increase the EDG test interval to 7 days per present TS and 35 consecutive successful tests would be required for a 31 day test interval. In order to prevent excessive diesel starts, the licensee has proposed to base the test frequency on the last 20 tests rather than the last 100 tests. With this proposed change, if a diesel generator has one or less failures in the last 20 tests, its test frequency would be once per 31 days. Whenever a diesel generator unit has experienced two or more failures in the last 20 tests, the test frequency would be reduced to seven days. This test frequency would be maintained until seven consecutive failure-free tests have been

9008270051 900822
PDR ADDCK 05000311
P PIC

performed and the number of failures in the last 20 tests has been reduced to one or less. In addition, the licensee has proposed to base the test frequency on a per diesel generator basis rather than per nuclear unit basis. This would result in an immediate reduction in test frequency and prevent PSE&G from having to perform the excessively high number of tests required in the present situation (i.e., one diesel start per day).

Based on the above, the staff finds the proposed revised Table 4.8-1 to be consistent with the recommendations of Generic Letter 84-15 to improve and maintain EDG reliability by reducing unnecessary EDG testing and is acceptable.

3.0 EXIGENT CIRCUMSTANCES

The Commission's regulation, 10 CFR 50.91, provides special exceptions for issuance of amendments when the usual 30-day public notice period cannot be met. One type of special exception is an exigency. An exigency is a case in which the staff and licensee need to act quickly and time does not permit the Commission to publish a Federal Register notice allowing 30 days for prior public comment, and the Commission also determines that the amendment involves no significant hazards considerations. In this instance, the need for action is based on the excessive number of EDG surveillance tests. The current TS require a test frequency of once every 3-days for each of the Salem 2 EDG's.

In addition, 30 consecutive successful tests would be required to increase the EDG test interval to 7 days per the present Technical Specifications; 35 tests would be required for a 31 day interval. In order to prevent excessive diesel starts, consistent with the staff's recommendations, exigent approval of proposed Table 4.8-1 would result in a 31 day interval for each Unit 2 EDG, and would assure that the interval would not be less than 7 days. If the normal approval process is used, including the thirty day public comment period, then the accelerated testing schedule would result in a significant number of additional diesel starts. These additional starts have been shown to be unnecessary by Generic Letter 84-15. Therefore, approval of this request on an exigent basis will eliminate undue wear and stress on the diesel engines, without resulting in a reduction in safety.

The licensee had made application to change the EDG technical specifications in late 1987. The staff determined that significant revisions to the application had to be made and the licensee was so notified in mid 1989. Table 4.8-1 was only a small part of the proposed change. The licensee was in the process of revising the application when the fourth EDG failure to start occurred at Salem 2. When the licensee's licensing staff became aware of the test frequency of the EDGs, application was made to change that portion of the TS. The staff finds that

the licensee did not deliberately or negligently cause the exigent situation to come into being. Failure of the Commission to act on the licensee's request would result in undue wear and stress on the EDGs at Salem 2.

4.0 FINAL NO SIGNIFICANT HAZARDS DETERMINATION CONSIDERATION

The Commission has provided standards for determining whether a significant hazards consideration exists (10 CFR 50.92(c)). A proposed amendment to an operating license for a facility involves no significant hazards consideration if operation of the facility in accordance with the proposed amendment would not: (1) involve a significant increase in the probability or consequences of an accident previously evaluated; (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety.

The licensee has analyzed the proposed amendment to determine if a significant hazards consideration exists:

The proposed change to Technical Specifications Table 4.8-1 for Salem Unit No. 2:

- (1) does not involve a significant increase in the probability or consequences of an accident previously evaluated. Reducing the test frequency is intended to increase overall diesel reliability by minimizing severe test conditions which can lead to premature failures. The proposed change will continue to assure availability of the diesels and should serve to enhance the reliability and consequently the overall safe operation of the diesel generators.
- (2) do[es] not create the possibility of a new or different kind of accident from any accident previously evaluated. The proposed change affects only EDG testing frequency and has no impact on the accident analysis. No new operating modes or equipment are introduced which could initiate or affect the progression of an accident.
- (3) [does not] involve a significant reduction in a margin of safety. The change in the testing frequency does not adversely affect the capability of the diesels to perform their required function. Rather, the purpose of the proposed change is to increase the overall reliability of the diesels consistent with Generic Letter 84-15.

Based on the above considerations, including the staff's safety evaluation, the staff concludes that the amendment meets the standards set forth in 10 CFR 50.92 for a no significant hazards determination. Therefore, the staff has made a final determination that the proposed amendment involves no significant hazards consideration.

5.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to the surveillance requirements. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register (55 FR 31919) on August 6, 1990 and consulted with the State of New Jersey. No public comments were received and the State of New Jersey did not have any comments.

We have concluded, based on the consideration discussed above, that (1) because the requested changes do not involve a significant increase in the probability or consequences of an accident previously evaluated, do not create the possibility of an accident of a type different from any evaluated previously, and do not involve a significant reduction in a margin of safety, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: August 22, 1990

Principal Contributors:

O. Chopra
J. Stone