July 7, 1987

Docket No. 50-354

Mr. Corbin A. McNeill, Jr. Senior Vice President - Nuclear Public Service Electric & Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. McNeill:

SUBJECT: SECONDARY CONTAINMENT DAMPER CLOSURE TIME (TAC NO. 64950)

Re: HOPE CREEK GENERATING STATION

The Commission has issued the enclosed Amendment No. 6 to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated March 13, 1987, as supplemented March 26, 1987.

This amendment reduces the maximum isolation times for the secondary containment ventilation automatic isolation dampers.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Georgell Rivenbark

George Rivenbark, Project Manager Project Directorate I-2 Division of Reactor Projects I/II

Enclosures:

- 1. Amendment No. 6 to License No. NPF-57
- 2. Safety Evaluation

cc w/enclosures: See next page

DISTRIBUTION:Docket FileMO'Brien (2)NRC PDROGC - BethesdaLocal PDRDHaganPDI-2 ReadingEJordanWButlerJPartlowGRivenbark/RLoTBarnhart (4)

Wanda Jones EButcher LJWink ACRS (10) CMiles, GPA/PA RDiggs, ARM/LFMB BClayton RGallo LWink

Previously concurred\*:

LA:PDI-2:DRPI/	I	I	*
MO'Brien			
06/18/87			

PM:PDI-2:DRPI/II\* GRivenbark:ca 06/18/87 OGC\* D:PDI-2:DRPI/II EChan WButler 06/26/87 07/7/87

8707160219 870707 PDR ADOCK 05000354 PDR PDR



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

July 7, 1987

Docket No. 50-354

Mr. Corbin A. McNeill, Jr. Senior Vice President - Nuclear Public Service Electric & Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. McNeill:

SUBJECT: SECONDARY CONTAINMENT DAMPER CLOSURE TIME (TAC NO. 64950)

Re: HOPE CREEK GENERATING STATION

The Commission has issued the enclosed Amendment No. 6 to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated March 13, 1987, as supplemented March 26, 1987.

This amendment reduces the maximum isolation times for the secondary containment ventilation automatic isolation dampers.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Rivenbach

Ł

George Rivenbark, Project Manager Project Directorate I-2 Division of Reactor Projects J/II

Enclosures: 1. Amendment No. 6 to License No. NPF-57 2. Safety Evaluation

cc w/enclosures: See next page Mr. C. A. McNeill Public Service Electric & Gas Co.

#### cc:

S. E. Miltenberger Vice President - Nuclear Operations Nuclear Department P. O. Box 236 Hancocks Bridge, NJ 08038

Gregory Minor Richard Hubbard Dale Bridenbaugh MHB Technical Associates 1723 Hamilton Avenue, Suite K San Jose, California 95125

M. J. Wetterhahn, Esquire Conner & Wetterhahn Suite 1050 1747 Pennsylvania Avenue Washington, D.C. 20006

R. Fryling, Jr., Esquire Law Department - Tower 5E 80 Park Place Newark, New Jersey 07101

Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 241 Hancocks Bridge, New Jersey 08038

Richard F. Engel Deputy Attorney General Division of Law Environmental Protection Section Richard J. Hughes Justice Complex CN-112P Trenton, New Jersey 08625

Mr. S. LaBruna General Manager-Hope Creek Operations Hope Creek Generating Station P.O. Box 118 Hancocks Bridge, New Jersey 08038

í

Hope Creek Generating Station

Mr. B. A. Preston, Manager Licensing and Regulation Nuclear Department P. O. Box 236 Hancocks Bridge, New Jersey 08038

Susan C. Remis Division of Public Interest Advocacy New Jersey State Department of the Public Advocate Richard J. Hughes Justice Comples CN-850 Trenton, New Jersey 08625

Office of Legal Counsel Department of Natural Resources and Environmental Control 89 Kings Highway P.O. Box 1401 Dover, Delaware 19903

Ms. Rebecca Green New Jersey Bureau of Radiation Protection 380 Scotch Road Trenton, New Jersey 08628

Mr. Anthony J. Pietrofitta General Manager Power Production Engineering Atlantic Electric 1199 Black Horse Pike Pleasantville, New Jersey 08232

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

## PUBLIC SERVICE ELECTRIC & GAS COMPANY

## ATLANTIC CITY ELECTRIC COMPANY

ţ.

## DOCKET NO. 50-354

## HOPE CREEK GENERATING STATION

## AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 6 License No. NPF-57

- 1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
  - A. The application for amendment filed by the Public Service Electric & Gas Company (PSE&G) dated March 13, 1987, as supplemented March 26, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-57 is hereby amended to read as follows:
  - (2) Technical Specifications and Environmental Protection Plan

8707160229 870707 PDR ADOCK 05000354

PDR

The Technical Specifications contained in Appendix A, as revised through Amendment No. 6, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PSE&G shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan. 3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/s/ Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II

Attachment: Changes to the Technical Specifications

۰.

Date of Issuance: July 7, 1987



PM:HUL-2:DRPI/II GRivenbark 6 /\6 /87

OGC E.Charl D:PDI-2:DRPI/II WButler 6 /26/87 7/7/87

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATOR FORMISSION

Zitter

Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II

Attachment: Changes to the Technical Specifications

Date of Issuance: July 7, 1987

## ATTACHMENT TO LICENSE AMENDMENT NO. 6

## FACILITY OPERATING LICENSE NO. NPF-57

## DOCKET NO. 50-354

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Overleaf page provided to maintain document completeness.\*

Remove	Insert
3/4 6-49	3/4 6-49*
3/4 6-50	3/4 6-50

í

## CONTAINMENT SYSTEMS

## SECONDARY CONTAINMENT AUTOMATIC ISOLATION DAMPERS

LIMITING CONDITION FOR OPERATION

3.6.5.2 The secondary containment ventilation system (RBVS) automatic isolation dampers shown in Table 3.6.5.2-1 shall be OPERABLE with isolation times less than or equal to the times shown in Table 3.6.5.2-1.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, 3 and \*.

### ACTION:

With one or more of the secondary containment ventilation system automatic isolation dampers shown in Table 3.6.5.2-1 inoperable, maintain at least one isolation damper OPERABLE in each affected penetration that is open and within 8 hours either:

- a. Restore the inoperable dampers to OPERABLE status, or
- b. Isolate each affected penetration by use of at least one deactivated damper secured in the isolation position, or
- c. Isolate each affected penetration by use of at least one closed manual valve or blind flange.

Otherwise, in OPERATIONAL CONDITION 1, 2 or 3, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

Otherwise, in Operational Condition \*, suspend handling of irradiated fuel in the secondary containment, CORE ALTERATIONS and operations with a potential for draining the reactor vessel. The provisions of Specification 3.0.3 are not applicable.

### SURVEILLANCE REQUIREMENTS

4.6.5.2 Each secondary containment ventilation system automatic isolation damper shown in Table 3.6.5.2-1 shall be demonstrated OPERABLE:

- a. Prior to returning the damper to service after maintenance, repair or replacement work is performed on the damper or its associated actuator, control or power circuit by cycling the damper through at least one complete cycle of full travel and verifying the specified isolation time.
- b. During COLD SHUTDOWN or REFUELING at least once per 18 months by verifying that on a containment isolation test signal each isolation damper actuates to its isolation position.
- c. By verifying the isolation time to be within its limit at least once per 92 days.

<sup>\*</sup>When irradiated fuel is being handled in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel.

## TABLE 3.6.5.2-1

# SECONDARY CONTAINMENT VENTILATION SYSTEM AUTOMATIC ISOLATION DAMPERS

## ISOLATION GROUP NO. 19

DAMF	PER FUNCTION	MAXIMUM ISOLATION TIME (Seconds)
1.	Reactor Building Ventilation Supply Damper HD-9370A	7
2.	Reactor Building Ventilation Supply Damper HD-9370B	7
3.	Reactor Building Ventilation Exhaust Damper HD-9414A	7
4.	Reactor Building Ventilation Exhaust Damper HD-9414B	7

#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 6 TO FACILITY OPERATING LICENSE NO. NPF-57

## PUBLIC SERVICE ELECTRIC & GAS COMPANY

## ATLANTIC CITY ELECTRIC COMPANY

### HOPE CREEK GENERATING STATION

## DOCKET NO. 50-354

### 1.0 INTRODUCTION

NUCLEAR REGULA,

By letter dated March 13, 1987, as supplemented March 26, 1987, Public Service Electric & Gas Company requested an amendment to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. The proposed amendment would reduce the maximum isolation times for the four secondary containment ventilation system automatic isolation dampers listed in Technical Specification (TS) Table 3.6.5.2-1 from 10 seconds to 7 seconds.

### 2.0 EVALUATION

8707160239 870707

PDR

ADOCK 05000354

The licensee states that the change is required to conservatively correct the TSs and satisfy the functional design basis for the system as stated in the Final Safety Analysis Report (FSAR). FSAR Section 9.4.2.3 states that "the exhaust air transit time between the refueling area monitors and the Reactor Building Ventilation System (RBVS) exhaust system isolation dampers is greater than the combined time of damper closure and the monitor response. The exhaust air transit time is 12 seconds, and the combined monitor response and valve closing time is within 11 seconds." Current TSs allow a monitor response time of  $\leq 4.0$ seconds (TS Table 3.3.2-3) and a damper closure time of  $\leq$  10 seconds (TS Table 3.6.5.2-1) which yields a combined monitor response/damper closure time of  $\leq$  14 seconds. Since this value is in conflict with, and less conservative than, the functional design requirements, the licensee proposes revising the damper isolation time from  $\leq$  10 seconds to  $\leq$  7 seconds in TS Table 3.6.5.2-1 to achieve the original design intent.

The staff review of the proposed change determined that the secondary containment is designed to minimize any ground level release of radioactive material which may result from a postulated accident. The NRC's Standard Review Plan, NUREG-0800, (Section 9.4.2) requires that the system have the capability to detect and control leakage of radioactive contamination from the system and include the capability of automatically isolating the normal ventilation system before the first contaminated airborne particles and gases reach the normal ventilation

exhaust ducts. The proposed change would ensure that this capability exists by requiring that the maximum combined monitor response/damper closure time be less than the exhaust air transit time. The staff, therefore, concludes that the proposed change in secondary qontainment ventilation system automatic isolation dampers maximum isolation time is acceptable.

### 3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

#### 4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the <u>Federal</u> <u>Register</u> (52 FR 13348) on April 22, 1987, and consulted with the State of New Jersey. No public comments were received and the State of New Jersey did not have any comments.

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security nor to the health and safety of the public.

Principal Contributor: L. J. Wink

Dated: July 7, 1987

Docket No. 50-354

Mr. Corbin A. McNeill, Jr. Senior Vice President - Nuclear Public Service Electric & Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. McNeill:

SUBJECT: SECONDARY CONTAINMENT DAMPER CLOSURE TIME (TAC NO. 64950)

Re: HOPE CREEK GENERATING STATION

The Commission has issued the enclosed Amendment No. to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated March 13, 1987, as supplemented March 26, 1987.

This amendment reduces the maximum isolation times for the secondary containment ventilation automatic isolation dampers.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

George Rivenbark, Project Manager Project Directorate I-2 Division of Reactor Projects I/II

Enclosures:

- 1. Amendment No. to License No. NPF-57
- 2. Safety Evaluation

cc w/enclosures: See next page

DISTRIBUTION: Docket File NRC PDR Local PDR PDI-2 Reading WButler GRivenbark/RLo LAPPEDA MOVE Ten 06/14/87

MO'Brien (2) OGC - Bethesda DHagan EJordan JPartlow TBarnhart (4)

PM:RDV-2:DRPI/II GRivenbark:ca 06/%/87 Wanda Jones EButcher LJWink ACRS (10) CMiles, GPA/PA RDiggs, ARM/LFMB BClayton RGallo LWink Ú

OGC ege D:PDI-2:DRPI/II E. Chan WButler 06/26/87 06/ /87