

August 30, 1993

MEMORANDUM FOR: Sholly Coordinator

FROM: Michael J. Davis, Acting Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC NO. M86306)

Public Service Electric & Gas Company, Docket No. 50-354, Hope Creek
Generating Station, Salem County, New Jersey

Date of application for amendment: April 23, 1993

Brief description of amendment: This amendment revises TS 3.11.2.8 and
Surveillance Requirement 4.11.2.8 for Radioactive Effluents Venting or
Purging to allow the containment drywell to be vented through the hardened
torus vent following Type A Integrated Leakage Rate Testing.

Date of issuance: August 30, 1993

Effective date: August 30, 1993

Amendment No.: 58

Facility Operating License No. NPF-57: This amendment revised the
Technical Specifications.

Date of initial notice in FEDERAL REGISTER: May 26, 1993 (58 FR 30200)
The Commission's related evaluation of the amendment is contained in a
Safety Evaluation dated August 30, 1993.

No significant hazards consideration comments received: No

Local Public Document Room location: Pennsville Public Library, 190 S.
Broadway, Pennsville, New Jersey 08070

Original signed by:

9309020070 930830
CF ADOCK 05000354
CF

Michael J. Davis, Acting Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II

DISTRIBUTION

✓ Docket File MBoyle MDavis
PDI-2 Reading MO'Brien(2) OGC

NRC FILE CENTER COPY

OFC	: PDI-2/A	: PDI-2/PM	: OGC	: PDI-2/D	:
NAME	: MO'Brien	: MDavis:rb	: RBochmann	: MBoyle	:
DATE	: 8/29/93	: 8/12/93	: 8/17/93	: 8/27/93	:

CP-1
JFB
10



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 30, 1993

MEMORANDUM FOR: Sholly Coordinator

FROM: Michael J. Davis, Acting Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC NO. M86306)

Public Service Electric & Gas Company, Docket No. 50-354, Hope Creek
Generating Station, Salem County, New Jersey

Date of application for amendment: April 23, 1993

Brief description of amendment: This amendment revises TS 3.11.2.8 and
Surveillance Requirement 4.11.2.8 for Radioactive Effluents Venting or
Purging to allow the containment drywell to be vented through the hardened
torus vent following Type A Integrated Leakage Rate Testing.

Date of issuance: August 30, 1993

Effective date: August 30, 1993

Amendment No.: 58

Facility Operating License No. NPF-57: This amendment revised the
Technical Specifications.

Date of initial notice in FEDERAL REGISTER: May 26, 1993 (58 FR 30200)
The Commission's related evaluation of the amendment is contained in a
Safety Evaluation dated August 30, 1993.

No significant hazards consideration comments received: No

Local Public Document Room location: Pennsville Public Library, 190 S.
Broadway, Pennsville, New Jersey 08070

A handwritten signature in cursive script, appearing to read "Michael J. Davis".

Michael J. Davis, Acting Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II