INITIAL SUBMITTAL

VOGTLE EXAM 50-424, 425/2001-301

MAY 14 - 18 & 21 - 25, 2001

INITIAL SUBMITTAL JPMS

ADMINISTRATIVE JPMs/QUESTIONS SIMULATOR JPMs, IN-PLANT JPMs, AND INITIAL ADMIN TOPICS OUTLINE (ES-301-1), CONTROL ROOM SYSTEMS & FACILITY WALK-THROUGH OUTLINE (ES-301-2)

ES-301

Administrative Topics Outline

Form ES-301-1

Facility: Vogtle Electric Generating Plant Date of Examination: 5/15-24/01 Examination Level (circle one): RO / SRO Operating Test Number:				
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions		
A.1	JPM	Calculate Keff for Withdrawal of Shutdown Banks		
	JPM	Evaluate Operator Overtime Usage		
		NRC-2		
A.2	JPM	Determine Axial Flux Difference With AFD Monitor Inoperable		
	· · · · · · · · · · · · · · · · · · ·	NKC-1		
A.3	JPM	Calculate Stay Time for Maintenance Work NRC-3		
A.4	JPM	Classify Event and Make Protective Action Recommendation (SRO)		
		Make Emergency Notification		
•		40101-002-01a		
		(RO)		

ES-301 Control Room Systems and Facility Walk-Through Test Outline

Form ES-301-2

Facility: Vogtle Electric Generating Plant	Date of Exar	nination: 5/15	-24/01
Exam Level (circle one): RO / SRO(I) / SRO(U)	Operating Te	est No.:1_	<u> </u>
B.1 Control Room Systems			
System / JPM Title		Type Code*	Safety Function
a. Place Letdown in service TI 130 Fails NRC-4	(U)	N/A/S	3
o. Respond to Failure of RCP Seal #1 16401-003-01		D/L/S	2
c. Transfer Containment Spray Recirculation 37113-001-02		M/A/S	5
d. Establish Required Subcooling For RCS Depressurizat RQ-JP-37311-001	tion (U)	N/A/L/S	4
e. Trip Protection System Bistables (Pzr Press) 60301-007-01C	(U)	D/C	7
f. Respond to CVI with Failure of Dampers to Close 13125-001		N/A/S	6
g. Dilute Containment With Service Air		D/C	9
B.2 Facility Walk-Through			
a. Operate Containment H2 Recombiner 37061-001-01	(U)	D	5
 Manually Rack 4160v Breaker 13435-001 		D/lab	6
c. Locally Isolate RCP Seals 37031-001-01	(U)	D/R	2
* Type Codes: (D)irect from bank, (M)odified from bank, ((S)imulator, (L)ow-Power, (R)CA	N)ew, (A)ltern	nate path, (C)c	ontrol room,



Energy to Serve Your World[™]

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC EXAM HL-11

CALCULATE SHUTDOWN MARGIN KEFF DETERMINED TO BE UNSAT TO WITHDRAW SHUTDOWN BANKS

March 24, 2001

JPM INFORMATION

OPERATOR'S NAME			
EVALUATION DATE:	//		
JPM TITLE: CALCUL BE UNS	ATE SHUTDOWN MARGIN K _{eff} Determined to AT TO WITHDRAW SHUTDOWN BANKS		
COMPLETION TIME:	30 minutes		
Application:	RO/SRO		
Task Number:			
K/A Number:			
Evaluation Method	[] Performed[] Simulated		
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2		
Performance Time:	minutes		

OVERALL JPM EVALUATION	[] SATISFACTORY	[] UNSATISFACTORY
Examiner Comments:		

Examiner's Signature:

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 14005-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

1. 14005-1, Shutdown Margin and Keff Calculations

- 2. Plant Technical Data Book (Unit 1)
- 3. Data sheet at end of this JPM

SIMULATOR SETUP:

Performance of this JPM does not require the simulator. This JPM is based on Unit 1 Cycle 10 data.

DIRECT	TIONS	то	OPER	ATOR
DINEO				

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

 INITIAL CONDITIONS:
 The crew is performing a reactor startup following a trip from 100% power, steady state conditions.

 Assigned Task:
 In accordance with UOP 12003, the USS has directed you to "Determine K_{eff} for withdrawal of the shutdown banks using 14005".

 Task Standard:
 K_{eff} calculated for withdrawal of the Shutdown Banks.

JPM STEPS

START TIME: _____

STEP 1			
CRITICAL (+)			
SAT 🗆 🖉	UNSAT De		
Select appropriate Dat	ta Sheet		
 >□ ◆ Data Sheet 3 >□ • Current cond 	3 selected ditions recorded		

STEP 2

CRITICAL (+)

SAT DE UNSAT DE

Determine reactivity values using PTDB

Note: If a discrepency exist in the values of this JPM and the values calculated by the examinee, all work performed by the examinee should be collected and evaluated to determine where error exist. If the error is determined to be a math or interpolation error and the error does not affect the acceptance criteria, then the JPM should be considered as satisfactory If the error is due to improper usage of the procedure or the tables in the PTDB, then the JPM should be considered unsatisfactory.

- ► Xe/Sm free integral boron worth (J1) of 3857 pcm
- ►□ Xe/Sm free critical boron worth (J2) of 688 ppm
- ∞□ Xe/Sm free integral boron worth (J3) of 6514 pcm
- Boron correction factor (J4) of 0.91916
- Corrected Xe/Sm worth (J6) of 3285 pcm
- Shutdown reactivity (J8) of 628 pcm

JPM STEPS

ST	ΈP	3

CRITICAL (+)

SAT 🗆 🖉 UNSAT 🗖 🖉

Determine K_{eff}

Note: Interpolation and rounding may result in values slightly different from those provided.

 \mathbb{Z} \clubsuit K_{eff} of 0.994 calculated

	STEP 4		
	CRITICAL (+)		
	SAT 🗆 🖉 UNSAT 🗆 🖉		
Į	Report to USS		
~	Sum ♦ Keff is NOT acceptable for SD bank withdrawal		

STOP TIME: _____

Field Notes

DATA REQUIRED FOR KEFF CALCULATION

PROVIDE THIS SHEET TO THE CANDIDATE

Power History	100% for 410 days
Cycle Burnup	19,000 MWD/MTU
Boron Concentration	400 ppm
Tavg	557 °F
Current Rod Height	All rods are inserted
Delta AO x Delta Bu	0 % MWD/MTU
Length of shutdown	28 hours
Boron-free Xenon plus Samarium Worth Obtained from Rx Engineering	3574 pcm

Approved Ε Γ. Ε. Τγ	nan	Vog	tle Electric Generating Plant	\mathbf{A}	14005-1 (19
ate Appro /9/00	ved	SHUTDO	WN MARGIN AND KEFF CALCUL	ATIONS	Page Number 14 of 17
			DATA SHEET 3	Sheet	2 of 2
J.	KEFF CZ	ALCULATION			
			NOTE		
		For all ca of the rea	alculations, record the <u>ABSO</u> activity values obtained from	LUTE VALUES m the PTDB.	
J.1	Xe/Sm ((H.2), (PTDB 7	free Integral Boron Concen TAB 1.3.1)	Boron Worth at ARI, Tempera tration (H.4) and Burnup (G.	1ture 2) +	3857pcm
J.2	Xe/Sm Banks ((G.2)	free Critical Only Inserted (PTDB TAB 1.3	Boron Concentration with Co , Temperature (H.2) and Burn .5)	ontrol uup +	<u>688</u> ppm
J.3	Xe/Sm : (H.2), (G.2)	free Integral Critical Bor (PTDB TAB 1.3	Boron Worth at ARI, Tempera on Concentration (J.2) and E .1)	ature Burnup + _	<u>6514</u> pcm
J.4	Correct Samari 1.4.5)	tion factor f um at Critica	or Boron effect on Xenon and 1 Boron Worth (J.3) (PTDB TA	ł AB 	91916
J.5	Boron after (G.2)	free Xenon pl shutdown from (obtain from	us Samarium Worth at (H.3) h Power Level (G.3) and Burnu Reactor Engineering.)	nours 1p + _	3574pcm
J.6	Correc (J.5)]	ted Xenon plu	s Samarium Worth: [(J.4) x	+	<u>3285</u> pcm
J.7	Axial Engine	Offset Reacti ering)	vity Correction (From Reacto	or + _	_0 pcm
J.8	Shutdo [(J.1)	wn Reactivity - (J.3) + (J	r: [.6) - (J.7)] =		
	<u>_3857</u>	- <u>6514</u> + <u>3</u>	<u>285</u> - <u>0 </u>	()	<u>628</u> pcm
J.9	Keff:	1.0000 / [1.	0000 + ((J.8)/100,000)] =		1
	1.0000	/ [1.000 + ((628/100,000)] =	+ _	994'
	ACCEPT	ANCE CRITERIA	<u>.</u>		
	Keff (J.9) shall be	e less than +0.99.		
	[] YE	S [X] NO			
Comp	leted By	<i>/</i> :	Signature	Date/Time	
Veri	fied By:	:			

Printed May 7, 2001 at 10:42

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:	The crew is performing a reactor startup following a trip from 100% power, steady state conditions.
<u>Assigned Task</u> :	In accordance with UOP 12003, the USS has directed you to "Determine K_{eff} for withdrawal of the shutdown banks using 14005".
TASK STANDARD:	K _{eff} calculated for withdrawal of the Shutdown Banks.



Energy to Serve Your World™

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

EVALUATE OPERATOR OVERTIME USAGE

April 15, 2001

JPM INFORMATION

OPERATOR'S NAME	Ξ:
EVALUATION DATE	:://
JPM TITLE:	Evaluate Operator Overtime Usage
REVISION:	0
COMPLETION TIME	: 15 minutes
Application:	RO/SRO
Task Number: K/A Number: 10CFR55.45 Ref.:	G2.1.1 3.7/3.8 41.1/45.3
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVA	LUATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments	S:
Examiner's Signatur	re:

INSTRUCTIONS TO EXAMINER

REQUIRED ITEMS: TS 5.2.2

SIMULATOR SETUP: N/A

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: The following is the schedule of 2 operators for a seven day period.

ASSIGNED TASK: Using the attached schedule, determine whether overtime guidelines may have been violated. Consider each case seperately and list all applicable violations.

TASK STANDARD: Overtime Usage Correctly Evaluated.

JPM STEPS

START TIME: _____

STEP 1 CRITICAL (♦) SAT □ ≤ UNSAT □ ≤

Determines Overtime Limitations

STEP 2 CRITICAL (♦) SAT □ ≤ UNSAT □ ≤

Evaluates overtime usage of both opertors.

>>□ • Determines hours worked each day for both operators.

STEP 3 CRITICAL (♦) SAT □ ≤ UNSAT □ ≤

Evaluates hours worked against overtime limitations.

 \simeq (\checkmark) Determines overtime usage in accordance with answer key. (4/5)

STOP TIME: _____

Field Notes

	Operator #1 (Dayshift)	Operator #2 (Dayshift)
Mon.	0600-1800 (12)	0600-1800 (12)
Tues.	0700-1900 (12) (came in late, holdover)	0600-1800 (12)
Wed.	0200-1800 (16) (called in early)	0600-1800 (12)
Thurs.	0600-1800 (12)	0600-1200 (6) (call out, day off)
Fri.	OFF	0600-1300 (7) (went home sick)
Sat.	0600-1800 (12)	0600-1800 (12)
Sun.	0600-1800 (12)	0600-1800 (12)
>72 hour < 8 hours >24 hour Tues/We	rs in 7 days s rest Tuesday/Wednesday rs in 48 hours ed & Wed/Thur (2)	>72 hrs in 7 days

ANSWER KEY

Initial Conditions:

The following is the schedule of 2 operators for a seven day period.

Initiating Cue: Using the attached schedule, determine whether overtime guidelines may have been violated. Consider each case seperately and list all applicable violations.

	Operator #1 (Dayshift)	Operator #2 (Dayshift)
Mon.	0600-1800	0600-1800
Tues.	0700-1900 (came in late, holdover)	0600-1800
Wed.	0200-1800 (called in early)	0600-1800
Thurs.	0600-1800	0600-1200 (call out, day off)
Fri.	OFF	0600-1300 (went home sick)
Sat.	0600-1800	0600-1800
Sun.	0600-1800	0600-1800

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	The following is the schedule of 2 operators for a seven day period.
Assigned Task:	Using the attached schedule, determine whether overtime guidelines may have been violated. Consider each case seperately and list all applicable violations.

Task Standard:

Use of Overtime evaluated.



Energy to Serve Your World[™]

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

DETERMINE AXIAL FLUX DIFFERENCE

April 15, 2001

JPM INFORMATION

OPERATOR'S NAMI	E:	
EVALUATION DATE	E://	
JPM TITLE:	Calculate AFD	
COMPLETION TIME	E: 15 minutes	
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 015000A105 RO:	3.7 SRO: 3.9
Evaluation Method	[] Performed	[] Simulated

Evaluation Method [] Ferformed	
Evaluation Location [] Simulator	[] Control Room [] Unit 1 [] Unit 2
Performance Time:minutes	
OVERALL JPM EVALUATION	[] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

This JPM is based on the latest rev of 14915-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to examinee during performance of this JPM.

REQUIRED ITEMS:	1. 2.	14915, Special Conditions Su Plant Technical Data Book	irveillance Logs
SIMULATOR SETUP:	1. 2.	Reset to 74 % IC 92 power v AFD readings: 41C -15 43C -20	vith NI 42C reads 69.5 . 42C -21 44C -15
The sin	nulator	should remain in FREEZE durii	ng the performance of this JPM
		Setun time: 3 min	utes

This JPM is based on the Current Unit 1 Cycle.

DIRECTIONS TO O	PERATOR
-----------------	---------

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions: Unit 1 has recently recovered from a load rejection. The unit is at 74% power. NI-42C has a failed detector, the channel has been BTI per 13509. Instrument power fuses are currently installed for troubleshooting and repair.

Assigned Task: I&C has reported that the AFD monitor alarm ALB10-F6 is inoperable. The USS has directed you to determine the required actions and perform any necessary surveillences for this condition.

TASK STANDARD: AFD calculated and LCO evaluated oubleshooting per13509-C.

START TIME:

STEP 1 CRITICAL (+) UNSAT ⊡∉ SAT 🛛 🗷

Determines AFD must be determined for each OPERABLE excore channel within 1 hour using 14915-1 Tab 6.0 .

• Reviews TS 3.2.3 and refers to 14915-1. $\Box \varnothing$

STEP 2 CRITICAL (+) SAT 🗆 🖉 UNSAT De

Determine upper and lower limits of AFD from PTDB Tab 6.0

• Upper and lower limits recorded $\Box_{\mathscr{B}}$

STEP 3

CRITICAL () UNSAT 🛛 🗷 SAT 🛛 🖉

Determine AFD

• 1-NI-41C value recorded. -15 \Box

 1-NI-42C value recorded (Note: instrument is inoperable and reading -21) $\Box_{\mathscr{A}}$

 1-NI-43C value recorded -20 \Box -15

• 1-NI-44C value recorded $\Box \varnothing$

Recognizes 1-NI-42C is not operable and records N/A on data sheet.

STEP 4 SAT □ ∞ UNSAT □ ∞

Verify AFD is within limits of PTDB 6.0

>>□ (●) AFD within limit of PTDB

STOP TIME: _____

Field Notes

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	Unit 1 has recently recovered from a load rejection. The unit is at 74% power. NI-42C has a failed detector , the channel has been BTI per 13509. Instrument power fuses are currently installed for troulbleshooting and repair
Assigned Task:	I&C has reported that the AFD monitor alarm ALB10-F6 is inoperable. The
	necessary surveillences for this condition.

Task Standard:

AFD calculated and LCO evaluated.



Energy to Serve Your World"

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC EXAM HL-11

CALCULATE WORKER STAY TIME TO PERFORM MAINTENANCE ON VALVE

April 24, 2001

JPM INFORMATION

OPERATOR'S NAME:			
EVALUATION DATE: / /			
JPM TITLE: CALCULATE WORKER STA	AY TIME TO PERFORM MAINTENA		E
COMPLETION TIME: 20 minutes			
Application: RO/SRO			
Task Number:			
K/A Number:			
Evaluation Method [] Performed	[] Simulated		
Evaluation Location [] Simulator	[] Control Room	[] Unit 1	[] Unit 2
Performance Time:minutes			
OVERALL JPM EVALUATION	[] SATISFACTORY	[] UNSATI	SFACTORY
Examiner Comments:			
Examiner's Signature:	<u> </u>		

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: After Unit One refueling outage the RCDT discharge header isolation from containment drain valve 1-1901-X4-028 has developed a bad packing leak which requires repair. The RCDT System has been tagged and drained to support the work by operations. Two mechanics have been assigned the task. Listed below is the workers accumulated yearly dose following the refueling outage.

Worker #1 4450 mrem

Worker #2 4375 mrem

Assigned Task: Using the Fuel Handling Building HP Room survey maps provided calculate how long each worker may remain in the area to perform the maintenance before reaching the administrative exposure limits for plant Vogtle.

TASK STANDARD: EACH MAINTENANCE WORKERS MAXIMUM STAY TIME CALCULATED.

JPM STEPS

START TIME: _

STEP 1

SAT De UNSAT De

Worker #1(4500- 4450 = 50 mrem)General radiation dose in area is 5 mrem/hr 50mren + 5mrem/hr = <u>10</u> hours

Worker #2 (4500- 4375 = 125 mrem) General radiation dose in area is 5 mrem/hr 125mrem + 5 mrem/hr = <u>25</u> hours

Stop Time _____

Field Notes

Plant Vogtle Radiological Information Survey

P	pe penetration F	Room (1F	HBA10)	Survey	#
				Date/Ti	me
					Smear Results DPM/100cm2 *indicates Alpha Sme 01) 02) 03) 04) 05) 06) 07) 08) 09) 10) 11) 12) 13) 14) 15) 16) 17) 18) 19) 20) 21) 22) 23) 24)
		R	CDT Discharfe Rain valve /-	<u>e</u> Header :/90/- <i>x</i> 4-028	
KEEP OUT RCA/DOS BEGD /RWP BEGD RADIATION AREA HIGH PADIATION AREA CONTAMINATED AREA HP ESCORT REGD FOR ENTRY NOTIFY HP PROR TO ENTRY HP TO SURVEY PRIOR TO ENTRY RADIOACTIVE MATERIALS		ju. n	ite; Valva t. Nwo # Xxxx	be Reparked	(#) = Smear Location NO. = Gamma Dase Rate NO. = Contact Gamma mRAD/h = Beta Dase Rate mRAD/h = Contact Beta △= Neutron Dase Rate •) = Alt Samole Location ALL DOSE RATE ARE IN mREM/h UNLESS OTHERWISE NOTED
Performed By:				% Reactor Reactor Me System Ru	Power: ode: Inning:
Purpose:					
arks:					
	Derticulato	DAC	inst Type	Ser #	Cal Due

Plant Vogtle Radiological Information Survey



Plant Vogtle Radiological Information Survey



This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	After Unit One refueling outage the RCDT discharge header isolation from containment drain valve 1-1901-X4-028 has developed a bad packing leak which requires repair. The RCDT System has been tagged and drained to support the work by operations. Two mechanics have been assigned the task. Listed below is the workers accumulated yearly dose following the refueling outage. Worker #1 4450 mrem Worker #2 4375 mrem
<u>Assigned Task</u> :	Using the Fuel Handling Building HP Room survey map provided calculate how long each worker may remain in the area to perform the maintenance before reaching the administrative exposure limits for plant Vogtle.
TASK STANDARD:	EACH MAINTENANCE WORKERS MAXIMUM STAY TIME CALCULATED.

2

SOUTHER		
COM Energy to Serve Y	PAN Y our World™	
PLANT VO	GTLE	
CONTROL ROOM	OPERATOR	
JOB PERFORMANC	CE MEASURE	
	02-01 0	
Revision June 1, 20	2 000 Neel Shee	ENH QUE to GUE TO
Written By : M. C. Henry	Date:	6/01/2000
Approved By : R. D. Brigdon	Date:	6/13/2000

.

 \geq

OPERATOR'S NAME:					
EVALUATION DATE:	//				
JPM TITLE:	Make Emergency	Notifications			
REVISION:	2 June 1, 2000				
COMPLETION TIME:	15 minutes TI	IME CRITICAL	Θ		
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO / SRO 40003 194001A1.16 11	RO: 3.1	SRO:	4.4	
Evaluation Method	[] Performed	[] Simula	ated		
Evaluation Location	[] Simulator	[] Contro	l Room		
Performance Time:	minutes				
OVERALL JPM EVALUATION		[] SATISFACTORY		[] UNSATISFACTORY	
Examiner Comments:					
Examiner's Signature:				-	

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 91002-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:	1. 2.	Proce VEG	edure 91002-C, Emergency Notifications, Checklist 2 P Emergency Response Telephone Directory		
SIMULATOR SETUP:		Simulator not required for JPM performance			
Notes to Examiner:		(1)	Checklist 2, Sheet 2, Emergency Notification, should be completed with the exception of Steps 3, 4, and 6 prior to the start of this JPM. Step 1.A, THIS IS A DRILL, should always be recorded.		
		(2)	Step 3 of the Emergency Notification form must be completed within 15 minutes of the time documented in Step 6.A. The start time of this JPM should be the time recorded in Step 6.A.		
		(3)	ENSURE that the ENN telephone jack in the rear of the ENN telephone has the "Simulator" line installed.		

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

This is a TIME CRITICAL JPM

INITIAL CONDITIONS: An emergency has been declared and the Shift Superintendent has assumed the duties of the Emergency Director.

ASSIGNED TASK: The Emergency Director has directed you to "Perform the duties of the ENN Communicator".

 TASK STANDARD:
 Communications established and the Emergency Notification form transmitted to all

 State and Local authorities.
 State and Local authorities.
START 1	
STEP 1 CRITIC/ SAT	AL(♦) Iac UNSAT ⊡ac
I /	Initiate roll call Note: The Emergency Response Telephone Directory, or the dial code card, should be consulted as needed for required ENN dial codes. The dial code, **, should be used initially to ring ALL required agencies.
	 Burke County notified (1) GEMA notified Aiken County notified SRS notified Allendale County notified State of South Carolina notified Barnwell County
CUES:	(1) When requested, provide cue that the emergency center hailed has responded.
STEP 2 SAT C] الع Transmit fascimile Note: On the Fax machine in the simulator, the pushbutton labelled "NOTIFY(Training)" should be depressed to simulate "NOTIFY", if necessary a cue to the examinee should be provided that for simulation purposes, the "NOTIFY (Training)" pushbutton should be used to transmit the fax.
26 26	 Place message face down in transmit tray NOTIFY(Training) pushbutton depressed

SAT		UNSAT 🗆 🔊
	Comm Note:	nunicate notification via ENN 87 Examiner should arbitrarily pick a number between 1 and 100 and verfiy that authentication code is correctly identified by examinee.
20 20 20 20 20	 Line Exa Line Con 	s 1 & 2 transmitted minee's name provided in Line 2, "Reported By" 3, Transmittal time & date completed <i>(1)</i> trol Room confirmation phone number transmitted
CUES:	(1)	After completion of ENN form line 3, "The State of South Carolina request that you authenticate number ."

STEP 4 CRITICAL (+) UNSAT De SAT 🗖 🛋

Message authentication

The authentication codes are located in the Emergency Response Telephone Directory. The codeword provided Note: should match the number given in the cue of JPM Step 3.

20 Authentication codeword correctly provided.

STEP 5 CRITICAL (+) UNSAT De SAT De

Transmit classification data

- Emergency Classification \Box
- Emergency declaration time and date 20
- Emergency description 20

STEP 6 CRITICAL (+) UNSAT De SAT De

Transmit current plant radiological conditions

- · Plant condition \Box Emergency rad release status 20
- Current meteorological data 20
- Recommended protective actions 20
- · ED approval,time, & date 20

STEP 7	t UNSAT ⊡.£
Re	cord Acknowledgements
≥.□ • F	Perform a second roll call and record names of individuals receiving the message (1)
CUES: (1)	Give names as appropriate for each agency
STEP 8 SAT De	unsat ⊡≪
Nc	otify ED

Field Notes:

Initial Emergency Notification completed

20



Energy to Serve Your World[™]

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC

CLASSIFY AN EMERGENCY EVENT - GENERAL EMERGENCY IMPLEMENT OFFSITE PROTECTIVE ACTION RECOMMENDATIONS - PAR 1

May 4, 2001

JPM INFORMATION

OPERATOR'S NAME:	
EVALUATION DATE://	
JPM TITLE: Classify an Emerger	ncy Event - General Emergency
COMPLETION TIME: 15 minutes	
Application: SRO ONLY Task Number: K/A Number:	
Evaluation Method [] Performed Evaluation Location [] Simulator Performance Time:minutes	[] Simulated [] Control Room [] Unit 1 [] Unit 2
OVERALL JPM EVALUATION	[] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

() This is a Time Critical JPM ()

1

Initial Conditions:	An emergency has been declared and the Shift Superintendent has assumed the duties of the Emergency Director.
Assigned Task:	The Emergency Director has directed you to "Perform the duties of the ENN Communicator".
Task Standard:	Communications established, and the Emergency Notification form transmitted, to all State and Local authorities.

This JPM is based on the latest rev of 91001-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues proceeded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 1. 91001-C, Emergency Classification and Implementing Instructions 2. 91305-C, "Protective action guidelines".

SIMULATOR SETUP: None

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

- **INITIAL CONDITIONS:** Unit 1 was at 90% Reactor Power to remove the "A" HDT Pump from service for maintenance when the loop #1 MFRV started drifting shut. The control room operators manually tripped the reactor and while stabilizing the plant in mode 3, S/G #4 developed a 750 gpm tube rupture. While performing the cooldown step in 19030-C the loop #4 ARV (1PV-3030) failed open. The crew had entered EOP-19131-C when the chemistry Forman reported the primary activity of 311 μ Ci/gm equivalent I-131. Local actions to isolate the loop #4 ARV (1PV-3030) were not successful due the high radiation levels in the south main steam valve room. Engineering dose assessment shows that severe core damage has not occurred and containment radiation monitors 1RE-005/1RE-006 are indicating 111mrem/hr. The IPC indicates the wind direction is from 111°.
- ASSIGNED TASK: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering past events, and their impact on the current plant conditions" and make the initial notification PAR recommendation.
- **TASK STANDARD:** Emergency event classified and PAR recommendation on the initial notification to offsite authorities.

STER	1		
CRIT	CAL (♦)		
SAT	□ ≠≤ UNSAT □ ≠≤		
	Classify the event		
 Plant conditions evaluated Emergency event classified as a General Emergency 			
STEP CRIT	2 CAL (♦) □ ≠ UNSAT □ ≠		
STEP	CAL (♦)		
CRIT	□ ★ UNSAT □ ★		
SAT	Determine correct Protective Action Recommendations		
STEP	CAL (♦)		
CRIT	□ ☞ UNSAT □ ☞		
SAT	Determine correct Protective Action Recommendations		
STEP	CAL (*)		
CRIT	Determine correct Protective Action Recommendations		
SAT	R1		
P/	* Evacuate Zone A		
STEP CRIT SAT	CAL (♦) □		

Field Notes

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Unit 1 was at 90% Reactor Power to remove the "A" HDT Pump from service for **Initial Conditions:** maintenance when the loop #1 MFRV started drifting shut. The control room operators manually tripped the reactor and while stabilizing the plant in mode 3, S/G #4 developed a 750 gpm tube rupture. While performing the cooldown step in 19030-C the loop #4 ARV (1PV-3030) failed open. The crew had entered EOP-19131-C when the chemistry Forman reported the primary activity of 311 µCi/gm equivalent I-131. Local actions to isolate the loop #4 ARV (1PV-3030) were not successful due the high radiation levels in the south main steam valve room. Engineering dose assessment shows that severe core damage has not occurred and containment radiation monitors 1RE-005/1RE-006 are indicating 111mrem/hr. The IPC indicates the wind direction is from 111°. You have been directed to "Determine the HIGHEST emergency classification Assigned Task: level based on events which are in progress, considering past events, and their impact on the current plant conditions" and make the initial notification PAR recommendation.

Task Standard:

Emergency event classified and PAR recommendation on the initial notification to offsite authorities.



Energy to Serve Your World[™]

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC

Return Normal Charging and Letdown to service

May 1, 2001

JPM INFORMATION

OPERATOR'S NAME	E:
EVALUATION DATE	://
JPM TITLE:	Return Normal Charging and Letdown to service
REVISION:	1 May 1, 2001
COMPLETION TIME	: 20 minutes
Application: RO/SR Task Number: K/A Number:	0

Evaluation Method [] Performed	[] Simulated
Evaluation Location [] Simulator	[] Control Room [] Unit 1 [] Unit 2
Performance Time:minutes	
OVERALL JPM EVALUATION	[] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 13006-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

1. 13006, Chemical and Volume Control System

SIMULATOR SETUP:

- 1. Reset to IC14 MOL 100%
- 2. Ensure LV-459,460 closed, HV-8149A,B,C, closed and HV-8152 and HV-8106 closed.
- 3. Ack/Reset alarms
- 4. Freeze simulator

Setup time: 7 minutes

INSTRUCTIONS TO EXAMINER

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: Unit 1 removed normal CVCS letdown from service 3 days ago to repair and leak on the REGEN heat exchanger. The repairs have been completed and the USS has directed you to restore normal charging and letdown to service using SOP-13006-1 section 4.4.2.

ASSIGNED TASK: Using SOP-13006-1 section 4.4.2 return normal charging and letdown to service.

TASK STANDARD: Normal charging and letdown inservice with a 75 gpm orifice.

START TIME: _____

STEP 1 CRITICAL (♦) SAT □ ∞ UNSAT □ ∞

Establish normal system alignment:

- Section 4.4.2 of 13006 selected
- Orifice isolations HV-8149A, B, & C CLOSED
- Letdown isolations LV-459 and LV-460 CLOSED
- Pressurizer AUX spray valve HV-8145 CLOSED
- ▶□ Letdown Pipe break isolation valve HV-15214 OPEN
- CVCS letdown isolation CNMT HV-8160 OPEN
- CVCS letdown isolation CNMT HV-8152 OPEN
- ▶□ Pressure controller PIC-131 in MAN at 50% to 75% demand
- Temperature controller TIC-0130 in MAN at 50% demand
- \simeq PRZR level verified > 17%
- ▶□ RCS normal charging to loop 1 HV-8146 OPEN (1)

CUES:

(1) If requested this is an even-numbered fuel cycle

L

STEP 2 CRITICAL (+) SAT DE UNSAT DE

Establish charging flow:

- \Box
- Charging line isolating HV-8106 OPEN
 Charging line isolation HV-8105 OPEN $\Box \varnothing$
- Adjust charging flow to between 80 to 90 gpm. 2
- Adjust RCP seal injection between 8 to 13 gpm. $\Box \varnothing$

STEP 3 CRITICAL (+)

SAT 🛛 🖉 UNSAT 🗖 🦉

Establish letdown flow

Letdown isolations LV-459 and LV-460 OPEN

- Science Sc
- ➢□ PIC-131 adjusted to attain 360 to 380 psig on PI-131A

STEP 4

SAT DE UNSAT DE

Place letdown controllers in automatic:

- B□ PIC-131 in AUTO
- ► Letdown pressure 360 to 380 psig on PI-131A
- >□ TIC-130 in AUTO
- > □ Letdown temperature ≤ 115 °F on TI-130

STEP SAT	5 ⊡∞ UNSAT ⊡∞
When on heat ex demin of	Verify proper system operation: checking Pressurizer level Simulator operator will fail 1TIS-130 to no cooling flow to the letdown xchanger this will result in high outlet temperature to the CVCS demins. When this happens the devert valve will fail to automatically devert to the VCT position.
 >□ >□ >□ >□ >□ temper 130 an 	 Regen heat exchanger outlet (letdown) on TI-127 verified < 380 °F Maintain PRZR level within 1% of program (1) Student isolates letdown. <u>OR</u> Student quickly takes manual control of TIC-130 and lowers temperature. <u>OR</u> Student delays in taking manual control of TIC-130 but recognizes the failure of the rature divert valve 1TV-0129 and bypasses the demin manually then takes manual control of TIC-nd lowers temperature OR isolates letdown.
CUES: The fol	 Illowing action will be considered satisfactory: (1) Student isolates letdown. (2) Student quickly takes manual control of TIC-130 and lowers temperature (3) Student delays in taking manual control of TIC-130 but recognizes the failure of the prature divert valve 1TV-0129 and bypasses the demin manually.

STOP TIME: _____

1

Field Notes Need TEMP of Resin for UNSITT Portonumarce

~1.5 · ·

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	Unit 1 removed normal CVCS letdown from service 3 days ago to repair a leak on the REGEN heat exchanger. The repairs have been completed and the USS has directed you to restore normal charging and letdown to service using SOP-13006-1 section 4.4.2.
Assigned Task:	Using SOP-13006-1 section 4.4.2 return normal charging and letdown to service.

Task Standard: Normal charging and letdown inservice with a 75 gpm orifice.



Energy to Serve Your World[™]

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

RQ-JP-16401-003-01

RESPOND TO FAILURE OF RCP SEAL #1

Revision 17

July 3, 2000

Written By	: M. C. Henry	Date:	7/3/2000
Approved By	: Richard D. Brigdon	Date:	7/4/2000

OPERATOR'S NAM	E:
EVALUATION DATE	:://
JPM TITLE:	Respond to Failure of RCP Seal #1
REVISION:	17 July 3, 2000
COMPLETION TIME	: 5 minutes TIME CRITICAL O
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 16008 00300A201 RO: 3.5 SRO: 3.9 3, 4, 6, 12
E	[] Performed [] Simulated
Evaluation Method	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EV	ALUATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comment	s:
Examiner's Signatu	re:

INSTRUCTIONS TO EXAMINER

This JPM is based on 13003-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

13003-1, Reactor Coolant Pump Operation

SIMULATOR SETUP:

1. Reset to IC7

1.

- 2. Ack/Reset alarms
- 3. Freeze simulator
- 4. Insert malfunction RP06A(B,C, or D) with a Final Value of 100% and a ramp time of 8 seconds

Setup time: 5 minutes

INSTRUCTIONS TO EXAMINER

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

This is a TIME CRITICAL JPM

INITIAL CONDITIONS: The plant is at 10% power. Preparations are underway to synch the generator to the grid.

ASSIGNED TASK: You have been directed by the USS to "Assume the duties of the RO".

TASK STANDARD: Plant conditions correctly diagnosed and corrective actions completed.

STEP 1 SAT □ ≤ UNSAT □ ≤

Determine RCP seal abnormality

Science → RCP Controlled Lkg Hi/Lo Flow annunciator in alarm 1A2-A05 (17008-1)

• Seal leakoff flow indications increasing

STEP 2 SAT ⊡ ≤ UNSAT □ ≤

Select procedure and section

►□ •13003, section 4.2.1 selected

STEP 3 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠

Evaluate RCP status

Note: RCP parameters may be monitored on IPC if available, but are not required for satisfactory performance.

S□ • Trend data listed in Table 2 of 13003. (1)

▲□ ◆ Determines #1 seal leakoff flow exceeds normal limits (> 5.5 gpm)

CUES:

(1) "The USS will ensure Table 2 data monitoring performed by BOP"

Indicate the following; Seal injection flow is 9 gpm; Seal injection temperature is 105°F"; Seal leakoff flow is offscale high on the high range recorder.

START TIME: ______ TIME CRITICAL ③

STEP 4 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠
Stop the RCP Note: RCP #2 and #3 have no associated spray valve and critical step would not apply
 START oil lift pump Initiate 18005-C, Partial Loss of Flow (1) STOP affected RCP If RCP #1 or #4 was stopped, place associated spray valve in MANUAL and CLOSE.(PIC-455C or PIC-455B) (See Note above for RCP #2 and #3.) CLOSE HV-8141A(B,C, or D) STOP oil lift pump
CUES: (1) "The USS will initiate 18005-C."
STOP TIME:

STEP 5 SAT 🗆 🖉 UNSAT 🗆 🖉

Report to USS

• The affected RCP has been stopped

Field Notes



8

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

③ This is a Time Critical JPM ④

Initial Conditions:	The plant is at 10% power. Preparations are underway to synch the generator to the grid.
Assigned Task:	You have been directed by the USS to "Assume the duties of the RO".

Task Standard: Plant conditions correctly diagnosed and corrective actions completed.

	SOU		
	Energy	to Serve Your World	SM
	PL	ANT VOGTLE	
	CONTRO	OL ROOM OPERAT	OR
	JOB PER	FORMANCE MEAS	URE
	RC TRANSFER CONTAINM	Q-JP-37113-001-02 ENT SPRAY SYSTEM TO R ALTERNATE PATH)	ECIRCULATION
		Revision 10-17 July 1, 1999 April 15, 200	Vew
Written By	: M. C. Henry	Date	
Approved By	Lon Rav	Date	-7726/1999

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	A large break LOCA has occured. The crew performed the cold leg recirculation lineup using 19013, and returned to 19010. After transitioning to 19010, RWST level decreased below 10%. The Auxiliary Building Operator is standing by the local Containment Spray suction and discharge pressure gauges with communications on line 1.
Assigned Task:	The USS has directed you to "Align Containment Spray for recirculation beginning with 19013, step 8".

Task Standard: Containment spray system operating in the recirculation mode.

	JPM	INF	ORM	ITAN	ON
--	------------	-----	-----	------	----

OPERATOR'S NAME:	
EVALUATION DATE:	//
JPM TITLE:	Transfer Containment Spray System to Recirculation
REVISION:	16 July 1, 1999
COMPLETION TIME:	8 minutes
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 37009 000011EA112 RO: 4.1 SRO: 4.4 6, 12
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVAL	UATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 19013-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

1. 19013, Transfer to Cold Leg Recirculation

SIMULATOR SETUP: 1. Reset to IC90 (MOL 100%)

REQUIRED ITEMS:

- 2. Insert malfunction RC03C (DBA LOCA)
 - 3. Trip all RCPs
 - 4. Throttle AFW flow to $\approx 200 \text{ gpm/SG}$
 - 5. When Containment Emergency Sump levels are ≈ 15": set RF: TK02 = 39% (RWST)
 - 6. Perform 19013-C steps 1 thru 6
 - 7. Set RF: TK02 = 10%
 - 8. Close HV-9001B (Remove after CS is reset)
 - 9. Ack/Reset alarms
 - 10. Freeze simulator

NOTE: Simulator operator ramp containment pressure up when CS Pump A is secured in JPM step 2. (8# to 15 # over 20 minutes.)

Setup time: 20 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:	A large break LOCA has occured. The crew performed the cold leg recirculation lineup using 19013, and returned to 19010. After transitioning to 19010, RWST level decreased below 10%. The Auxiliary Building Operator is standing by the local Containment Spray suction and discharge pressure gauges with communications on line 1.
Assigned Task:	The USS has directed you to "Align Containment Spray for recirculation beginning with 19013, step 8".
TASK STANDARD:	Containment spray system operating in the recirculation mode.

START TIME: STEP 1 CRITICAL (+) SAT 🗆 🔊 UNSAT De **Reset containment spray** Cntmt Spray reset handswitches HS-40058 and HS-40059 in RESET 20 ALB 06 D06 clear (Cnmt spray actuation) 20 STEP 2 CRITICAL (+) UNSAT De SAT 🛛 🔊 Align Train A for recirculation • Sump suctions HV-9002A epens and HV-9003A fails to OPEN (1) 20 Stop CS Pump 1A (2) $\square \varnothing$ CUES: (1) HV-900 is inaccessable due to High Radiation levels. If asked for: "Suction pressure (PI-972) is 2 psig; Discharge pressure (PI-974) is rapidly (2) oscillating from 15 psig to 75 psig". **STEP 3** CRITICAL (+) UNSAT De SAT De Align Train B for recirculation pert Sump suction HV-9002B and HV-9003B \Box RWST suction HV-9017B closed \Box • Local gauges for pump suction and discharge pressure verified (1) `∞□ CNMT pressure verified stable or decreasing (Containment pressure increasing) 20 • Verify Valve Alignment Incorrect and Opens HV-9001B Bold or Hill H `⊗.□ CUES: If asked for: "Suction pressure (PI-973) is 16 psig; Discharge pressure (PI-975) is 250 psig." (1) STEP 4 UNSAT De SAT ⊡∉ Report to USS Containment spray Pump B aligned for recirculation \square STOP TIME:

Field Notes



Energy to Serve Your World™

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC EXAM HL-11

ESTABLISH REQUIRED SUBCOOLING FOR RCS DEPRESSURIZATION

April 24, 2001

JPM INFORMATION

OPERATOR'S NAM	E:
EVALUATION DATE	E://
JPM TITLE:	Establish Required Subcooling for RCS Depressurization
COMPLETION TIME	E: 11 minutes
Application:	RO/SRO
Task Number:	
K/A Number:	

Evaluation Method [] Performed [] Simulated Evaluation Location [] Simulator [] Control Room [] Unit 1 Performance Time: minutes	[] Unit 2
OVERALL JPM EVALUATION [] SATISFACTORY	[] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	_

INSTRUCTIONS TO EXAMINER

This JPM is based on 19030-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

19030-C, Steam Generator Tube Rupture Response 1. REQUIRED ITEMS: Reset to IC14 1. SIMULATOR SETUP: Insert malfunction SG01A (B,C,or D) at 50% 2. Initiate manual Rx trip and SI 3. Throttle AFW flow to ≈ 200 gpm per SG 4. Verify ruptured SG level > 10% 5. Perform 19030 steps 3 through 5 6. Ensure ruptured SG pressure increases above 1100 psig 7. Block the Low Steam Line pressure SI/SLI (both trains) 8. Ensure the RCP are left in service to support the cooldown. 9. Ack/Reset alarms 10. Freeze simulator 11. Setup time: 8 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: A tube rupture has occurred on SG ____. The crew was transitioned from 19000 to 19030. Steps 1 through 5 of 19030 have been performed.

ASSIGNED TASK: The USS has directed you to "Cooldown the RCS to obtain the core exit temperature required for RCS depressurization using step 6 of 19030".

TASK STANDARD: Core exit thermocouple temperatures less than required for RCS depressurization.

START TIME: _____

STEP 1

SAT DE UNSAT DE

Determine required core exit temperature

• Ruptured SG pressure between 1100 and 1200 psig

• Required core exit temperature determined to be 518°F (530 too high) (Possibly a critical step if applicant chooses target temperature significantly lower than 518)

CUES:

STEP 2				
CRITICAL (+)	al huid steps			
SAT DE UNSAT DE	MAKE Addraw			
Initiate RCS cooldown				
Note: When the operator to takes the steam dumps to the bypass interlock position the simulator operator will insert a C-9 failure. The operator must recognize the problem and continue RCS cooldown with the ARV's on the intact S/G's.				
 AFW flow increased to intact SGs HS-500C in STEAM PRESSURE MODE. HS-500A and HS-500B in BYP INTLK (required when RCS temp < 550 °F). With C-9 failure the Steam Dumps will not be available and the operator must cooldown using the intact S/G ARV's (1) 				
CUE: (1) After the student establishes the coold the cooldown per 19030-C step 6.	lown using the ARV's inform them that the BOP will continue			

STOP TIME: _____
This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	A tube rupture has occurred on SG The crew was transitioned from 19000 to 19030. Steps 1 through 5 of 19030 have been performed.
<u>Assigned Task</u> :	The USS has directed you to "Cooldown the RCS to obtain the core exit temperature required for RCS depressurization using step 6 of 19030".
<u>Task Standard</u> :	Core exit thermocouple temperatures less than required for RCS depressurization.

<u>. 11 1</u> 11 11				
	SOUTHEF COM			
	Energy to Serve	Your World™		
	PLANT V	OGTLE		
	CONTROL ROOM	M OPERATOR		
	JOB PERFORMA	NCE MEASURI	E	
	RQ-JP-6030	1-007-01C		
	TRIP PROTECTION S PRESSURIZER PRES	YSTEM BISTABLES SSURE CHANNEL		
	Revisio	on 1		
	March 9	, 1998		
Written By	:George Gunn	Date:	3/9/98	
Approved By	:Leon Ray	Date:	3/9/98	

OPERATOR'S NAME:	
EVALUATION DATE:	//
JPM TITLE:	Trip Protection System Bistables - Pressurizer Pressure Channel
REVISION:	1 March 9, 1998
COMPLETION TIME:	6 minutes
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 60029 012000A404 RO: 3.3 SRO: 3.3
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVAL	UATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 18001-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

18001-C Process System Protection Cabinets Key

COMPONENT LOCATION: Main Control Room, 7300 Rx Protection Cabinets

1.

2.

CARD LOCATION REFERENCE:

3 56 7	3 5 5 7	3 5 4 7	3 5 3 7	3 5 2 7	3 51 7	3 50 7	2 4 9 6	2 48 6	2 4 7 6	2 46 6	2 4 5 6	2 4 4 6	2 4 3 6	2 4 2 6	2 4 1 6
						CARD	SLO	rs 21	hr u 36						
						CARD	SLO	TS 41	fm u 56						
						CARL	o slo	TS 61	fr u 76	5					

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

> **REMEMBER:** All steps required for this task are to be simulated. Plant equipment is not to be operated.

INITIAL CONDITIONS: Unit ___ Pressurizer pressure channel ___ PT-455 has failed. The control room operators have stabilized the plant in accordance with the AOP.

Assigned Task: The USS has directed you to "Trip the Pressurizer pressure channel __ PT-455 bistables listed in Table C1 of 18001-C and place the associated Master Test Switch in TEST".

TASK STANDARD: The failed instrument channel placed in a tripped condition.

START TIME:

Permisssion should be obtained from the applicable Control Room staff in order to access the 7300 Protection Cabinet.

STEP 1 SAT I & UNSAT I &
Locate protection cabinet
Protection Cabinet 1 located
STEP 2 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠
Place Bistables in a Tripped condition
 Card 46, B/S switches 1, 3, & 4 placed in TEST Card 22, B/S switches 3 & 4 placed in TEST
STEP 3 SAT பிக UNSAT பிக
Place Master Test switch in TEST
 Card 74, TEST switch 5 placed in TEST Card 72, TEST switch 1 placed in TEST
STEP 4 SAT De UNSAT De
Report to USS
Bistables are tripped and the Master test Switch is in TEST.

Need Feedback cues/defails

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

1

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.						
Initial Conditions:	Unit Pressurizer pressure channel PT-455 has failed. The control room operators have stabilized the plant in accordance with the AOP.					
Assigned Task:	The USS has directed you to "Trip the Pressurizer pressure channel PT-455 bistables listed in Table C1 of 18001-C and place the associated Master Test Switch in TEST".					

The failed instrument channel placed in a tripped condition. Task Standard:



JPM INFORMATION

OPERATOR'S N	AME:	
EVALUATION DA	ATE://	
JPM TITLE:	RESPOND TO CVI WITH FAILURE OF DAMPERS TO CI	LOSE
COMPLETION T	IME: 15 minutes	
Application:	RO/SRO	
Task Number:		
K/A Number:		
N/A Number.		
Evaluation Metho	od [] Performed[] Simulated	
Evaluation Metho	od [] Performed[] Simulated ion [] Simulator [] Control Room [] Unit 1	[] Unit 2
Evaluation Metho Evaluation Locati Performance Tim	od [] Performed[] Simulated ion [] Simulator [] Control Room [] Unit 1 ne:minutes	[] Unit 2
Evaluation Metho Evaluation Locati Performance Tim	od [] Performed[] Simulated ion [] Simulator [] Control Room [] Unit 1 ne:minutes EVALUATION [] SATISFACTORY	[] Unit 2 [] UNSATISFACTORY
Evaluation Metho Evaluation Locati Performance Tim OVERALL JPM E	od [] Performed[] Simulated ion [] Simulator [] Control Room [] Unit 1 ne:minutes EVALUATION [] SATISFACTORY ents:	[] Unit 2 [] UNSATISFACTORY
Evaluation Metho Evaluation Location Performance Tim OVERALL JPM E Examiner Comm	od [] Performed[] Simulated ion [] Simulator [] Control Room [] Unit 1 ne:minutes EVALUATION [] SATISFACTORY ents:	[] Unit 2 [] UNSATISFACTORY
Evaluation Metho Evaluation Locati Performance Tim OVERALL JPM E Examiner Comm	od [] Performed[] Simulated ion [] Simulator [] Control Room [] Unit 1 ne:minutes EVALUATION [] SATISFACTORY ents:	[] Unit 2 [] UNSATISFACTORY
Evaluation Metho Evaluation Locati Performance Tim OVERALL JPM E Examiner Comm	od [] Performed[] Simulated ion [] Simulator [] Control Room [] Unit 1 ne:minutes EVALUATION [] SATISFACTORY ents:	[] Unit 2 [] UNSATISFACTORY

Examiner's Signature: _____

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 13125-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues proceeded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

13125, Containment Purge System

SIMULATOR SETUP:

Reset to IC14

1.

1.

- 2. Place the Containment Mini-Purge System in service
- 3. Override dampers 1-HV-2629B and 1-HV-2628B open.
- 3 Ack/Reset alarms
- 4. Freeze simulator

Setup time: 10 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: The plant is at 100% power.

ASSIGNED TASK: The USS has directed you to, "Assume the duties of the Balance of Plant Operator (BOP)".

TASK STANDARD: Plant conditions correctly diagnosed and corrective actions completed.

START TIME:

STEP 1

UNSAT D& SAT De

Determine CVI signal has actuated

 ARP referenced for "CNMT VENT ISO ACTUATION" \Box (ALB06 E01) and HIGH Radiation (ALB05 C03) due to 1RE-2565 failing high.

CUES:

NOTE: Simulator operator is to fail 1-RE-2565 "HIGH" after the student assumes the BOP position.

STEP 2

CRITICAL (+)

UNSAT De SAT De

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION".

• Using the QMCB MLB's verify proper CVI alignment. $\Box \varnothing$

Note: student may refer to Plant Computer (IPC) indications to verify CVI or they may use individual damper indications on control panels.

 CNMT MINI PURGE EXH damper 1-HV-2628B SHUT (1) 20

◆ CNMT MINI PURGE EXH damper 1-HV-2629B SHUT (1) $\Box \varnothing$

CUES:

Note: Simulator operator is to remove the handswitch override for 1-HV-2628B and 1-HV-2629B when the operator places the handswitch to the shut position.

(1) The SOP-13125-1 may be used to remove Containment Mini-Purge from service, but is only required to check the CVI dampers SHUT for satisfactory perfomance.

STOP TIME

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	The plant is at 100% power.
Assigned Task:	The USS has directed you to, "Assume the duties of the Balance of Plant Operator (BOP)".
Task Standard:	Plant conditions correctly diagnosed and corrective actions completed.



JPM INFORMATION

OPERATOR'S NAME:
EVALUATION DATE://
JPM TITLE: RESPOND TO CVI WITH FAILURE OF DAMPERS TO CLOSE
REVISION: 1 April 25, 2001
COMPLETION TIME: 15 minutes
Application: RO/SRO
Task Number:
K/A Number:
Evaluation Method [] Performed [] Simulated
Evaluation Location [] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:minutes
OVERALL JPM EVALUATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:
Examiner's Signature:

This JPM is based on the latest rev of 13125-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues proceeded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

13125, Containment Purge System

SIMULATOR SETUP:

Reset to IC14

1.

1.

- 2. Place the Containment Mini-Purge System in service
- 3. Override dampers 1-HV-2629B and 1-HV-2628B open.
- 3 Ack/Reset alarms
- 4. Freeze simulator

Setup time: 10 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: The plant is at 100% power.

ASSIGNED TASK: The USS has directed you to, "Assume the duties of the Balance of Plant Operator (BOP)".

TASK STANDARD: Plant conditions correctly diagnosed and corrective actions completed.

START TIME: _____

STEP 1

SAT 🗆 🖉 UNSAT 🗆 🖉

Determine CVI signal has actuated

• ARP referenced for "CNMT VENT ISO ACTUATION" (ALB06 E01) and HIGH Radiation (ALB05 C03) DUE TO 1RE-2665failing high.

CUES:

NOTE: Simulator operator is to fail 1-RE-2565 "HIGH" after the student assumes the BOP position.

STEP 2

CRITICAL (+)

SAT DE UNSAT DE

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for CNMT AIR RAD MONITOR INL/OUT isolation dampers.

B → CNMT AIR RAD MONITOR INL damper 1-HV-12975 SHUT

CNMT AIR RAD MONITOR INL damper 1-HV-12976 SHUT

- CNMT AIR RAD MONITOR OUT damper 1-HV-12977 SHUT

CUES:

STEP 3

CRITICAL (+)

SAT 🛛 🗉 UNSAT 🖵 🖉

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for CNMT PREACCESS PURGE SUPPLY isolation dampers.

• CNMT PREACCESS PURGE SUPPLY damper 1-HV-2626A SHUT (1)

SI ● CNMT PREACCESS PURGE SUPPLY damper 1-HV-2627A SHUT (1)

CUES:

(1) The QMCB MLB's or the IPC cpmputer point may be used to verify position.

CRITICAL (+)

SAT 🗆 🔊 UNSAT 🗆 🔊

.

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for CNMT MINI PURGE SUPPLY isolation dampers.

• CNMT MINI PURGE SUPPLY damper 1-HV-2626B SHUT (1)

• CNMT MINI PURGE SUPPLY damper 1-HV-2627B SHUT (1)

CUES:

(1) The SOP-13125-1 may be used to remove Containment Mini-Purge from service, but is only required to check the CVI dampers SHUT for satisfactory perfomance.

STEP 5

SAT DE UNSAT DE

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for CNMT PREACCESS PURGE EXH isolation dampers.

SI ● CNMT PREACCESS PURGE EXH damper 1-HV-2628A SHUT (1)

► ONMT PREACCESS PURGE EXH damper 1-HV-2629A SHUT (1)

CUES:

(1) The QMCB MLB's or the IPC computer point may be used to verify position.

CRITICAL (+)

SAT De UNSAT De

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for CNMT MINI PURGE EXH isolation dampers.

B□ ◆ CNMT MINI PURGE EXH damper 1-HV-2628B SHUT (1)

► CNMT MINI PURGE EXH damper 1-HV-2629B SHUT (1)

CUES:

Note: Simulator operator is to remove the handswitch override for 1-HV-2628B and 1-HV-2629B when the operator places the handswitch to the shut position.

(1) The SOP-13125-1 may be used to remove Containment Mini-Purge from service, but is only required to check the CVI dampers SHUT for satisfactory perfomance.

CRITICAL (+)

SAT 🗆 🖉 UNSAT 🗆 🕿

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for CTM POST LOCA PURGE EXH isolation dampers.

SCI ● CTM POST LOCA PURGE EXH damper 1-HV-2624A SHUT

➢□ ● CTM POST LOCA PURGE	E EXH damper	1-HV-2624B SHUI
--------------------------	--------------	-----------------

CUES:

STEP 8

CRITICAL (+)

SAT DE UNSAT DE

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for AUX BLDG VENT SYS SUPPLY/RETURN isolation dampers.

► AUX BLDG VENT SYS SUPPLY damper 1-HV-12604 SHUT

B□ • AUX BLDG VENT SYS RETURN damper 1-HV-12605 SHUT

B → AUX BLDG VENT SYS RETURN damper 1-HV-12606 SHUT

• AUX BLDG VENT SYS SUPPLY damper 1-HV-12607 SHUT

CUES:

CRITICAL (+)

SAT DE UNSAT DE

Verify proper CVI alignment per ARP (ALB06 E01) " CNMT VENT ISO ACTUATION" for RECYCLE HOLDUP TANK isolation dampers.

► RECYCLE HOLDUP TANK damper 1-HV-12596 SHUT

CUES:

NOTE: When damper alignment is complete, inform student the "SSS will complete the ARP actions".

STOP TIME: _____

Field Notes

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	The plant is at 100% power.
<u>Assigned Task</u> :	The USS has directed you to, "Assume the duties of the Balance of Plant Operator (BOP)".
Task Standard:	Plant conditions correctly diagnosed and corrective actions completed.



OPERATOR'S NAME:	
EVALUATION DATE:	//
JPM TITLE:	Dilute Containment with Service Air
REVISION:	1 May 4, 2001
COMPLETION TIME:	7 minutes
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 37009 000028A4.01 RO: 4.0 SRO: 4.0 6
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVAL	UATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

INSTRUCTIONS TO EXAMINER

This JPM is based on 13130-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 13130, Post-Accident Hydrogen Control

SIMULATOR SETUP: N/A (To be performed in plant)

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: A LOCA has occurred on Unit 1. The crew is performing step 19 of 19010-C. The TSC has requested that Service Air be aligned to Containment to reduce the hydrogen concentration of the Containment atmosphere.

ASSIGNED TASK: The USS has directed you to "Dilute the Containment hydrogen concentration using Service Air".

TASK STANDARD: Service Air aligned to Containment atmosphere.

START TIME: __

STEP 1 SAT ⊡ ∞ UNSAT □ ∞ Appropriate procedure selected
► 13130, Section 4.4.2 selected
STEP 2 CRITICAL (♦) SAT □ & UNSAT □ &
Align Service Air to Containment
 HS 40120 and 40122 positioned to RESET (CIA) (1) HS 9385A positioned to OPEN (spring return to auto) (2) HS 9385B held in OPEN position until HV 9386 fully opened (2) (spring return to auto) (2)
 CUE: (1) When both the control room CIA reset handswitches are simulated to be positioned to the reset position, <u>CUI</u> that the CIA annuncaitor has <u>CLEARED</u>. (2) When <u>BOTH</u> the HS-9385A and HS-9385B handswitches are simulated to be position to the open position, <u>CUE</u> that the green light is <u>OFF</u> for both handswitches and the the red light is <u>ON</u>. If only one handswitch is placed in the open position then the green lights remain on and the red light stays off. 9385A dual repost control 9385B. was selected approximately open.
STEP 3 CRITICAL (+) SAT Der UNSAT Der coents follows each stop Initiate Service Air Purge
 ► HV 9380A - OR - HV 9380B opened (1) (spring return to auto) ► Verify Service Air pressure > 80 psig (2) ► Monitor CNMT H₂ concentration (3) ► Verify CNMT pressure remains < 40 psig (4)
 CUE: When <u>EITHER</u> the HS-9380A <u>OR</u> HS-9380B handswitch is simulated to be position to the open position <u>CUE</u> that the green light is <u>OFF</u> for the selected handswitch and the the red light is <u>ON</u>. When service air pressure indication is referenced (PT-9377), <u>CUE</u> that pressure is at 110 psig. When requested, "The Extra RO will monitor H₂ concentration." When requested, "The Extra RO will monitor containment pressure."

STEP 4 SAT □ ≤ UNSAT □ ≤	
Report to USS	
Service Air aligned to CNMT atmosphere	

STOP TIME: _____

Field Notes

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	A LOCA has occurred on Unit 1. The crew is performing step 19 of 19010-C. The TSC has requested that Service Air be aligned to Containment to reduce the hydrogen concentration of the Containment atmosphere.
Assigned Task:	The USS has directed you to "Dilute the Containment hydrogen concentration using Service Air".

Task Standard:Service Air aligned to Containment atmosphere.

F

	SOUTH	IERN ANY		
	Energy to S	erve Your World™		
	PLAN	T VOGTLE		
CONTROL ROOM OPERATOR				
	JOB PERFOR	MANCE MEASUR	E	
	RQ-JP-	37061-001-01		
	OPERATE CONTAINME	ENT HYDROGEN RECOM	BINER	
	Re	evision 18		
	Jur	ne 1, 2000		
Written By	: M. C. Henry	Date:	6/01/2000	
	T A Polito	Date:	6/02/2000	

FERATOR S NAME.	
EVALUATION DATE:	//
JPM TITLE:	Operate Containment Hydrogen Recombiner
REVISION:	18 June 1, 2000
COMPLETION TIME:	7 minutes
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 29014 028000A401 RO: 4.0 SRO: 4.0 6, 12
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVAL	JATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	

INSTRUCTIONS TO EXAMINER

This JPM is based on 13130-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

- 13130, Post Accident Hydrogen Control
- 1. PTDB Tab 13, H₂ Recombiner Reference Power 2.
- 3. Calculator

COMPONENT LOCATION: Control Building 1E 480 VAC Swgr Rooms (not provided in procedure)

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.

INITIAL CONDITIONS:	The crew has implemented 19251 following a large LOCA on Unit The following containment parameters have been recorded:		
	H ₂ concentration - 5% pre-LOCA temperature - 90°F post-LOCA pressure - 8 psig.		
Assigned Task: Per 19251-C, the USS has directed you to "Start Unit Hydrogen Recombiner by initiating 13130, Post Accident Hydrogen Control".			
TASK STANDARD:	ASK STANDARD: Containment hydrogen recombiner operating at the post-LOCA power setting.		

SAT	1 ⊡∉ UNSAT ⊡∉
	Determine recombiner pressure factor
<u>a</u> D	Pressure factor of 1.35 to 1.38 determined using Figure 1
STEP CRITI SAT	2 CAL (♦) □ & UNSAT □ & Energize the hydrogen recombiner
	 Power Available light lit Power Adjust Potentiometer at 0 demand Power Out switch in ON Red power out light lit
STEP SAT	3 □ ∞ UNSAT □ ∞ Warm up hydrogen recombiner
80	 Power Adjust potentiometer raised to attain: (1) 4 to 6 KW for 10 minutes 9 to 11 KW for 10 minutes 18 to 22 KW for 5 minutes
CUES	(1) At each level inform the operator the stated times have been attained.

Reference power setting determined using PTDB Tab 13
 Post-LOCA power setting determined within acceptable band

STEP CRITI SAT	5 CAL (+) 🗆 æ) UNSAT □æ		
	Increa Note:	ase recombiner power to the post-LOCA setting H2 Recombiner Post-LOCA Settings: 1A: 54 – 55.2 kW 1B: 58.3 - 59.6 kW 2A: 60.8 – 62.1 kW 2B: 58.2 – 59.5 kW		
 Power Adjust potentiometer raised to attain post-LOCA power setting Requests containment hydrogen concentration sampling. (1) 				
CUES	UES: (1) "The SSS is directing sampling per Sections 4.2.1 and 4.2.2."			
STEP SAT	°6 □£	UNSAT De		
	Repo	ert to USS		
20	• Reco	ombiner in service		

Field Notes

PTDB HYDROGEN RECOMBINER REFERENCE POWER SETTINGS

From PTDB Tab 13

Unit 1 Train A: 40 KW

Unit 1 Train B: 43.2 KW

Unit 2 Train A: 45 KW

Unit 2 Train B 43.12 KW

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.				
Initial Conditions: The crew has implemented 19251 following a large LOCA on Unit_ The following containment parameters have been recorded:				
	H ₂ concentration pre-LOCA temperature post-LOCA pressure	- - -	5% 90°F 8 psig.	
Assigned Task: Per 19251-C, the USS has directed you to "Start Unit Hydrong Recombiner by initiating 13130, Post Accident Hydrog Control".				

Task Standard:Containment hydrogen recombiner operating at the post-LOCA power
setting.
	SOUTHEI CON Energy to Serve	RNAR WPANY e Your World ^{**}		
	PLANT I	OGTLE		
	CONTROL ROO	M OPERATOR		
	JOB PERFORMA	NCE MEASURI	E	
	RQ-JP-13	435-001		
	MANUALLY RACK A 416	0V CIRCUIT BREAKI	ER	
	Revisi	on 7		
	November	13, 2000		
	-			
Written By	: M. C. Henry	Date:	11/13/2000	
Approved By	R. D. Brigdon	Date:	11/19/2000	

//		
Manually Rack a 4160V Circuit Breaker		
7 November 13, 2000		
5 minutes		
RO/SRO 01017 062000A401 RO: 3.3 SRO: 3.1		
[] Performed [] Simulated		
[] Simulator [] Control Room [] Unit 1 [] Unit 2		
minutes		
UATION [] SATISFACTORY [] UNSATISFACTORY		
Examiner Comments:		

INSTRUCTIONS TO EXAMINER

This JPM is based on 13435-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM. This JPM should be performed using the Training Switchgear in the Electrical Maintenance Lab. The examiner should not require the operator to locate the breaker in the plant. To access the Training Switchgear, contact the Electrical Maintenance Training Supervisor.

REQUIRED ITEMS:

- 1. 13435-C, Circuit Breaker Racking Procedure
- 2. Electrical Lab key
- 3. 4160V racking tool

COMPONENT LOCATION: To establish the proper switchgear setup, the following should be performed on the 4160V Training Switchgear breaker:

- 1. Ensure the Training Switchgear is Energized
- 2. Place the charging motor power control switch in OFF
- 3. Rack the breaker to the DISCONNECT position.
- 4. Remove the breaker from the cubicle enough to discharge the closing springs
- 5. Rack the breaker to the TEST position
- 6. Close the control power circuit breaker
- 7. Verify all switches in the rear of the breaker cabinet are aligned to the position highlighted in "black".

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

	REMEMBER: All steps required for this task are to performed in the Maintenance Lab of the Training Center. Plant equipment is not to be operated!
INITIAL CONDITIONS:	Electrical maintenance personnel have completed a routine PM on a 4160 breaker. The breaker has been restored to the TEST position.
Assigned Task:	The USS has directed you to "Rack breaker 1AA02-07 to the CONNECT position using 13435-C."
TASK STANDARD:	4160V circuit breaker in the connect position and aligned for operation.

JPM STEPS

START TIME: _____

STEF SAT	P1 ⊡∞ UNSAT ⊡∞
	Prepare circuit breaker for racking Note: The operator must open the cubicle doors to perform these steps.
80 80 80 80 80 80	 13435-C section 4.1.5 selected Control Room directed to place the Maintenance control switch 1MS-1AA02 in MAINT (1) Verify no clearances exist on breaker Verify Charging Spring Motor Power control switch is OFF & closing springs DISCHARGED Control Power circuit breaker OPEN Mechanical breaker position indicator verified OPEN
CUES	S: (1) "1MS-1AA02 is in MAINTENANCE."
STEF CRIT SAT	D2 ICAL (♦) □ ☞ UNSAT □ ☞ Engage racking crank

- Breaker cubicle door CLOSED
- Subject to a straight a straight and a straight a s
- Unlocking lever rotated clockwise and held
- Backing crank rotated clockwise ≥1/4 turn
- Unlocking lever released

STEP 3 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠

Rack circuit breaker to the connect position

Sa□ ◆ Racking crank rotated clockwise until automatically stopped

- Breaker in CONNECT
- Unlocking lever in the locked position

JPM STEPS

ſs	STEP 4		
c			
	SAT Der UNSAT Der		
	Remove racking crank		
8	♦ Trip pushbutton verified FLUSH with breaker front		
>	• Racking crank disengaged and removed		
8	• Cubicle sliding door CLOSED		
	STEP 5 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠		
	Prepare circuit breaker for operation		
8	Remote circuit breaker fuses verified installed		
2	▲ Control Power circuit breaker CLOSED		
2	Charging Motor Power Control switch in ON		
8	Closing Springs CHARGED		
2	▲□ ◆ Cubicle doors CLOSED		
8	• TS-LR's green light lit		
8	Control Room directed to place bus maintenance switch 1MS-1AA02 in NORMAL (1)		
ō			
L	(1) "1MS-1AAU2 IN NORMAL.		
/ []	STEP 6		
5	SAT De UNSAT De		
	Report to USS		
2	● 1AA02-07 racked to CONNECT		
-			
5	Field Notes		

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

	REMEMBER: All steps required for this task are to performed in the Maintenance Lab of the Training Center. Plant equipment is not to be operated!
Initial Conditions:	Electrical maintenance personnel have completed a routine PM on a 4160 breaker. The breaker has been restored to the TEST position.
Assigned Task:	The USS has directed you to "Rack breaker 1AA02-07 to the CONNECT position using 13435-C".

7

Task Standard:4160V circuit breaker in the connect position and aligned for operation.



OPERATOR'S NAME	
EVALUATION DATE	://
JPM TITLE:	Locally Isolate RCP seals
REVISION:	12 May 19, 1997
COMPLETION TIME	: 30 minutes
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 37018 000055EG06 RO: 3.8 SRO: 4.1 4, 6, 12
· · · ·	
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EV/	ALUATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comment	S:
Examiner's Signatur	re:

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 19100-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:	1. 2.	RWP and associated dosimetry Hearing Protection
COMPONENT LOCATI	ION:	<u>UNIT 1</u> 1979 (AB-A12); 8103A/B (AB-A09); 8103C/D (FHB-A10); and 8100 (AB-A09)
		<u>UNIT 2</u> 1979 (AB-A105); 8103A/B (AB-A103); 8103C/D (FHB-A01); and 8100 (AB-A103)

INSTRUCTIONS TO EXAMINER

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.

INITIAL CONDITIONS: The crew is responding to a loss of all AC power on Unit_____ per 19100. Power has been lost for 12 minutes and is not expected to be restored in the near future.

Assigned Task: The USS has directed you to "Locally close the following Unit_____ valves:

- ACCW supply isolation outside, ____-HV-1979(_____)
- RCP seal injection isolation valves, ____-HV-8103A/B(_____), and __-HV-8103C/D(_____),

RCP seal return isolation outside, ____-HV-8100(_____)".

TASK STANDARD:

RCP seals locally isolated.

JPM STEPS

START TIME: _____

STEP 1 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠

Isolate ACCW Return from RCPs

- ACCW containment isolation HV-1979 located.
- >>□ + HV-1979 closed.

STEP 2 CRITICAL (♦)

SAT De UNSAT De

Isolate RCP seal injection

Note: If these values are inaccessible, the path of ingress should be to the closest point allowed by radiological conditions.

- BCP seal injections HV-8103A and B located.
- ► HV-8103A and B closed.
- ► RCP seal injections HV-8103C and D located.
- >>□ ♦ HV-8103C and D closed.

STEP 3 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠

Isolate RCP seal return

Note: If this value is inaccessible, the path of ingress should be to the closest point allowed by radiological conditions.

- Seal return HV-8100 located.
- B□ ♦ HV-8100 closed.

STEP SAT	P4 □≤ UNSAT □≤
	Report to USS
20	RCP seals are locally isolated

STOP TIME: _____

Field Notes

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.		
Initial Conditions:	The crew is responding to a loss of all AC power on Unit per 19100. Power has been lost for 12 minutes and is not expected to be restored in the near future.	
Assigned Task:	The USS has directed you to "Locally close the following Unit valves:	
	ACCW supply isolation outside,HV-1979()	
	 RCP seal injection isolation valves,HV-8103A/B(),HV-8103C/D(), 	
	RCP seal return isolation outside,HV-8100()".	

Task Standard:

RCP seals locally isolated.