

Mr. Harold W. Keiser  
 Chief Nuclear Officer & President-  
 Nuclear Business Unit  
 Public Service Electric & Gas  
 Company  
 Post Office Box 236  
 Hancocks Bridge, NJ 08038

Oct 1, 1998

SUBJECT: HOPE CREEK GENERATING STATION, ISSUANCE OF AMENDMENT,  
 INSERVICE LEAK AND HYDROSTATIC TESTING REQUIREMENTS  
 (TAC NO. MA1750)

Dear Mr. Keiser:

The Commission has issued the enclosed Amendment No.112 to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 13, 1998.

This amendment revises TS 3/4.10.8, "Inservice Leak and Hydrostatic Testing," to delete the requirement for an operable High Drywell Pressure trip function. Specifically, TS 3.10.8.a is being revised to remove the reference to the Secondary Containment Isolation Actuation Instrumentation trip function 2.b.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

original signed by:

Richard B. Ennis, Project Manager  
 Project Directorate I-2  
 Division of Reactor Projects - I/II  
 Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosures: 1. Amendment No.112 to  
 License No. NPF-57  
 2. Safety Evaluation

*DFD 1/1*

cc w/encls: See next page

*050059*

**DISTRIBUTION**

Docket File	RCapra	JWermiel	THarris (E-Mail SE)
PUBLIC	REnnis	LMarsh	GHill(2)
PDI-2 Reading	TClark	CBerlinger	JLinville, RGN-I
JZwolinski	WBeckner	OGC	ACRS

OFFICE	PDI-2/PM	PDI-3/LA	TSB/BC	HICB/BC	SPLB/BC	SCSB/BC	OGC	PDI-2/D
NAME	REnnis*	TClark*	WBeckner*	JWermiel	LMarsh	CBerlinger	OGC	RCapra
DATE	8/19/98	8/25/98	8/31/98	9/18/98	1/1/98	9/16/98	9/17/98	9/29/98

OFFICIAL RECORD COPY  
 DOCUMENT NAME: HCMA1750.AMD

9810050272 981001  
 PDR ADOCK 05000354  
 PDR

*Nothing*  
*SPLB*  
 \*Previously Concurred  
*AW*

**NRC TRAIN CENTER COPY**

Mr. Harold W. Keiser  
Public Service Electric & Gas  
Company

Hope Creek Generating Station

cc:

Jeffrie J. Keenan, Esquire  
Nuclear Business Unit - N21  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Manager - Joint Generation  
Atlantic Energy  
6801 Black Horse Pike  
Egg Harbor Twp., NJ 08234-4130

Hope Creek Resident Inspector  
U.S. Nuclear Regulatory Commission  
Drawer 0509  
Hancocks Bridge, NJ 08038

Richard Hartung  
Electric Service Evaluation  
Board of Regulatory Commissioners  
2 Gateway Center, Tenth Floor  
Newark, NJ 07102

Mr. Louis Storz  
Sr. Vice President - Nuclear Operations  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township  
c/o Mary O. Henderson, Clerk  
Municipal Building, P.O. Box 157  
Hancocks Bridge, NJ 08038

General Manager - Hope Creek Operations  
Hope Creek Generating Station  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Elbert Simpson  
Senior Vice President-  
Nuclear Engineering  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Manager - Licensing and Regulation  
Nuclear Business Unit - N21  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Dr. Jill Lipoti, Asst. Director  
Radiation Protection Programs  
NJ Department of Environmental  
Protection and Energy  
CN 415  
Trenton, NJ 08625-0415



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

October 1, 1998

Mr. Harold W. Keiser  
Chief Nuclear Officer & President-  
Nuclear Business Unit  
Public Service Electric & Gas  
Company  
Post Office Box 236  
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION, ISSUANCE OF AMENDMENT,  
INSERVICE LEAK AND HYDROSTATIC TESTING REQUIREMENTS  
(TAC NO. MA1750)

Dear Mr. Keiser:

The Commission has issued the enclosed Amendment No.112 to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 13, 1998.

This amendment revises TS 3/4.10.8, "Inservice Leak and Hydrostatic Testing," to delete the requirement for an operable High Drywell Pressure trip function. Specifically, TS 3.10.8.a is being revised to remove the reference to the Secondary Containment Isolation Actuation Instrumentation trip function 2.b.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "R B Ennis".

Richard B. Ennis, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosures: 1. Amendment No. 112 to  
License No. NPF-57  
2. Safety Evaluation

cc w/encls: See next page



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-354

HOPE CREEK GENERATING STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 112  
License No. NPF-57

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment filed by the Public Service Electric & Gas Company (PSE&G) dated May 13, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-57 is hereby amended to read as follows:


9810050273 981001  
PDR ADDCK 05000354  
P PDR

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 112, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into the license. PSE&G shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance, to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: October 1, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 112

FACILITY OPERATING LICENSE NO. NPF-57

DOCKET NO. 50-354

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change. An overleaf page has been provided.\*

Remove

3/4 10-7\*

3/4 10-8

Insert

3/4 10-7\*

3/4 10-8

SPECIAL TEST EXCEPTIONS

3/4.10.8 INSERVICE LEAK AND HYDROSTATIC TESTING

LIMITING CONDITION FOR OPERATION

=====

3.10.8 When conducting inservice leak or hydrostatic testing, the average reactor coolant temperature specified in Table 1.2 for OPERATIONAL CONDITION 4 may be increased to 212°F, and operation considered not to be in OPERATIONAL CONDITION 3, to allow performance of an inservice leak or hydrostatic test provided the following OPERATIONAL CONDITION 3 LCO's are met:

- a. 3.3.2, "ISOLATION ACTUATION INSTRUMENTATION", Functions 2.a, 2.c, 2.d and 2.e of Table 3.3.2-1;
- b. 3.6.5.1, "SECONDARY CONTAINMENT INTEGRITY";
- c. 3.6.5.2, "SECONDARY CONTAINMENT AUTOMATIC ISOLATION DAMPERS"; and
- d. 3.6.5.3, "FILTRATION, RECIRCULATION AND VENTILATION SYSTEM."

APPLICABILITY: OPERATIONAL CONDITION 4, with average reactor coolant temperature > 200°F.

ACTION:

With the requirements of the above specification not satisfied, immediately enter the applicable condition of the affected specification or immediately suspend activities that could increase the average reactor coolant temperature or pressure and reduce the average reactor coolant temperature to ≤ 200°F within 24 hours.

SURVEILLANCE REQUIREMENTS

=====

4.10.8 Verify applicable OPERATIONAL CONDITION 3 surveillances for specifications listed in 3.10.8 are met.

SPECIAL TEST EXCEPTIONS

3/4.10.7 SPECIAL INSTRUMENTATION - INITIAL CORE LOADING

LIMITING CONDITION FOR OPERATION

3/4.10.7 The material originally contained in Section 3/4.10.7 was deleted with the issuance of Amendment No. 14. However, to maintain the historical reference to this section, Section 3/4.10.7 is intentionally left blank.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 112 TO FACILITY OPERATING LICENSE NO. NPF-57

PUBLIC SERVICE ELECTRIC & GAS COMPANY

ATLANTIC CITY ELECTRIC COMPANY

HOPE CREEK GENERATING STATION

DOCKET NO. 50-354

1.0 INTRODUCTION

By letter dated May 13, 1998, the Public Service Electric & Gas Company (the licensee) submitted a request for changes to the Hope Creek Generating Station (HCGS), Technical Specifications (TSs). The requested changes would revise TS 3/4.10.8, "Inservice Leak and Hydrostatic Testing," to delete the requirement for an operable High Drywell Pressure trip function. Specifically, TS 3.10.8.a would be revised to remove the reference to the Secondary Containment Isolation Actuation Instrumentation trip function 2.b. The proposed change is consistent with NUREG-1433, Revision 1, "Standard Technical Specifications, General Electric Plants, BWR/4."

2.0 BACKGROUND

HCGS TS Table 1.2 defines five OPERATIONAL CONDITIONS. OPERATIONAL CONDITION 4 (COLD SHUTDOWN) requires the reactor mode switch to be in the shutdown position and the average reactor coolant temperature to be less than or equal to 200 °F. OPERATIONAL CONDITION 3 (HOT SHUTDOWN) also requires the reactor mode switch to be in the shutdown position but allows the average reactor coolant temperature to be greater than 200 °F.

On April 18, 1994, the NRC issued a Safety Evaluation for Amendment No. 69 to the HCGS TSs. The amendment added a new Special Test Exception, TS 3/4.10.8, "Inservice Leak and Hydrostatic Testing." TS 3/4.10.8 permits the average reactor coolant temperature specified in TS Table 1.2 for OPERATIONAL CONDITION 4 to be increased to 212 °F, during performance of inservice leak and hydrostatic testing, provided that certain OPERATIONAL CONDITION 3 Limiting Conditions for Operation (LCOs) for secondary containment isolation, secondary containment integrity, and filtration, recirculation and ventilation system (FRVS) operability are met.

One of the OPERATIONAL CONDITION 3 LCO requirements specified in TS 3.10.8.a includes the "High Drywell Pressure" Secondary Containment Isolation trip function (TS Table 3.3.2-1, Trip Function 2.b). As discussed in HCGS Updated Final Safety Analysis Report (UFSAR) Section 7.2.1.1.8, drywell pressure (i.e., Primary Containment pressure) is monitored by four pressure transmitters. Each of the four transmitters provides an input to its corresponding trip

9810050274 981001  
PDR ADOCK 05000354  
P PDR

logic channel. High pressure in the drywell may indicate a break in the reactor coolant pressure boundary. As shown in TS Table 3.3.2-2, trip function 2.b, the High Drywell Pressure trip setpoint is 1.68 psig. TS 3.6.1.1 only requires PRIMARY CONTAINMENT INTEGRITY to be maintained in OPERATIONAL CONDITIONS 1, 2, and 3. Since TS 3.10.8 is only applicable to OPERATIONAL CONDITION 4, PRIMARY CONTAINMENT INTEGRITY does not need to be maintained during performance of inservice leak and hydrostatic testing. If the primary containment is open, the drywell pressure transmitters cannot be considered operable since the finite volume, for which the associated trip setpoints were selected, does not exist. Therefore, regardless of the surveillance status of the High Drywell Pressure trip function, the primary containment conditions would most likely prevent this function's initiation of a secondary containment isolation signal.

The above condition results in a conflict between the HCGS TS definition of OPERABLE and the TS 3.10.8.a requirement for an operable High Drywell Pressure trip function. The current HCGS TS requirements impose a requirement that cannot be met without defeating the purpose of having access to the primary containment for the TS 3/4.10.8 testing. Therefore, the licensee has requested that TS 3.10.8.a be revised to delete the requirement for an operable High Drywell Pressure trip function. The changes proposed in this submittal would make HCGS TS 3.10.8.a consistent with NUREG-1433, Revision 1, TS 3.10.1.a.

### 3.0 EVALUATION

The purpose of HCGS TS 3/4.10.8 is to allow inservice leak and hydrostatic tests to be performed in OPERATIONAL CONDITION 4 when the average reactor coolant temperature is greater than 200 °F (i.e., temperature that would normally correspond to OPERATIONAL CONDITION 3). This Special Test Exception effectively provides an exception to the OPERATIONAL CONDITION 3 requirement for PRIMARY CONTAINMENT INTEGRITY. This exception allows the primary containment to be open for performance of the tests as previously evaluated in the Safety Evaluation for Amendment No. 69 to the HCGS TSs.

TS 3/4.10.8 includes requirements that certain OPERATIONAL CONDITION 3 LCOs for secondary containment isolation, secondary containment integrity, and filtration, recirculation and ventilation system (FRVS) operability are met during performance of the inservice and hydrostatic testing. These requirements are intended to ensure that any radioactive material that leaks from the primary containment is contained and processed in order to limit release of radioactivity to the environment.

As discussed in HCGS UFSAR Sections 6.2.3.1, 7.3.1.1.10, 9.4.2.2.7, and 9.4.2.3, the Reactor Building (i.e., secondary containment), in conjunction with the FRVS, is designed to limit radiation doses during a design basis accident (DBA). The Reactor Building is automatically isolated, and the FRVS is automatically started upon receipt of any one of the following signals:

1. Low reactor water level (level 2);
2. High drywell pressure;

3. High radiation in the refueling area exhaust ducts;
4. High radiation in the Reactor Building exhaust ducts; or
5. Manual initiation signal from the control room.

The five signals listed above correspond to the five Secondary Containment Isolation trip functions currently required by TS 3.10.8.a (i.e., TS Table 3.3.2-1, Trip Functions 2.a, 2.b, 2.c, 2.d, and 2.e). As discussed above, the licensee has requested to delete the requirement for an operable High Drywell Pressure trip function. High drywell pressure can indicate a break in the reactor coolant pressure boundary. An isolation of the secondary containment and actuation of the FRVS are initiated in order to minimize the potential of an offsite dose release. The isolation on high drywell pressure supports actions to ensure that any offsite releases are within the limits calculated in the safety analysis. However, the High Drywell Pressure trip function associated with secondary containment isolation is not assumed in any UFSAR accident or transient analyses. The High Drywell Pressure trip function is required to be OPERABLE in OPERATIONAL CONDITIONS 1, 2, and 3 when considerable energy exists in the reactor coolant system (RCS) (i.e., there is a probability of pipe breaks resulting in significant releases of radioactive steam and gas). This function is not required in OPERATIONAL CONDITIONS 4 and 5 because the probability and consequences of these events are low due to the RCS pressure and temperature limitations of these OPERATIONAL CONDITIONS.

As discussed in the NRC Safety Evaluation for HCGS TS Amendment No. 69, the leak and hydrostatic tests are performed with the RCS near water solid and with all control rods fully inserted. Therefore, the stored energy in the reactor core would be very low and the potential for causing fuel failures with a subsequent increase in coolant activity is minimal. Even without an operable High Drywell Pressure trip function, the remaining TS 3/4.10.8 requirements associated with secondary containment isolation, secondary containment integrity, and FRVS operability would ensure that leaks from the primary containment are contained and processed in order to limit release of radioactivity to the environment.

In the event of a large loss-of-coolant accident during a leak or hydrostatic test, the RCS would rapidly depressurize thereby permitting the low pressure Emergency Core Cooling Systems, required by TS 3.5.2, to actuate and thereby keep the core flooded. This action would prevent the fuel from overheating and releasing radioactive materials. The RCS inspections required to be performed as part of the leak and hydrostatic tests would continue to be expected to detect small leaks before a significant inventory of coolant was lost.

Based on the foregoing analysis, the staff concludes that the proposed TS changes will assure acceptable consequences of any postulated accidents, are enveloped by the previously accepted analyses, and are, therefore, acceptable.

#### **4.0 STATE CONSULTATION**

In accordance with the Commission's regulations, the New Jersey State Official was notified of the proposed issuance of the amendment. The State official had no comments.

#### **5.0 ENVIRONMENTAL CONSIDERATION**

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (63 FR 35994). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

#### **6.0 CONCLUSION**

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: R. Ennis

Date: October 1, 1998